



CITY OF LIGHTS

ROBERT J. O'CONNOR
Mayor

Procurement Division | Finance Department

Joan M. Schouten, MBA CPIM CPPB
Director of Procurement

DATE: March 9, 2017
TO: Prospective Bidders
FROM: Joan M. Schouten, Director of Procurement
RE: **CITY OF AURORA REQUEST FOR QUOTATIONS 17-13 – ADDENDUM #1
UPS BATTERY REPLACEMENT AND PREVENTATIVE MAINTENANCE FOR
THE MIS DIVISION**

This addendum forms a part of the Invitation to Bid 17-13 UPS Battery Replacement and Preventative Maintenance for the MIS Division. All other information pertaining to the Invitation to Bid shall remain the same.

Bidder must submit an original bid response and shall have provided all requested information, and submitted all appropriate forms, certificates, affidavits and addendum acknowledgements in each copy in order to be considered responsive. **Sealed Bids will be accepted prior to 2:00 pm, Wednesday, March 15, 2017 at the Office of the City Clerk, 44 E. Downer Place, Aurora, IL 60507.**

Please attach a copy of this addendum as acknowledgement of this addendum with your quotation form. Failure to do so may subject Bidder to disqualification.

Responses/Clarifications to questions received by 5:00 pm, Tuesday, March 7, 2017:

- 1) Please confirm if the City plans to make payment annually or upfront for the three year renewal coverage.

The City intends to pay annually for the three year renewal coverage.

- 2) I am reviewing the battery replacement requirements and I see a condition asking for “only OEM batteries being accepted.” Can you tell me if an equivalent will still be accepted? If not, what is the reason for only OEM batteries being accepted into this particular bid?

OEM batteries are required by Eaton to maintain warranties.

3) Can you please verify the model of the batteries that are to be installed in the PW9390-60 Blade UPS and the external Battery Modules?

Powerware 9390-60 Blade UPS	60	TB271A0616	1	4	10305977-5591	City Hall
		TB232A0265	1	4	10305977-5591	44 E. Downer Place
		TB232A0266	1	4	10305977-5591	Aurora, IL 60505
		TB232A0267	1	4	10305977-5591	
		TB232A0268	1	4	10305977-5591	
		EBM/103005977-551	2	20	58700033	
		EBM/103005977-551	2	20	58700033	
		EBM/103005977-551	2	20	58700033	
		EBM/103005977-551	2	20	58700033	
		EBM/103005977-551	2	20	58700033	

We do not have the battery model. I suggest the vendor contact Eaton for their OEM model.

End of Addendum #1