



City of Aurora

Fire Prevention Bureau • 5 E Galena BL #G • Aurora, Illinois 60505-3305 • (630) 256-4130
Fax (630) 256-4139

Aurora University
Carmella Moran
347 S. Gladstone Avenue
Aurora, IL 60506

Tuesday, September 25, 2018

Re: Aurora University - Part Of 347 S Gladstone, 1424 Southlawn, 1419 Prairie & 1433 Prairie - Final Plan For A Parking Deck
Project # 18-00000125

(630) 844-5132

cmoran@aurora.edu

Dear Aurora University

Fire Prevention Bureau - The Fire Prevention Bureau has reviewed the proposal and has the following comments.

- ⇒ **With The Following Condition(s) as required and in compliance with the 2015 International Fire Code as adopted and/or amended by the City of Aurora:**
1. Provide supply hose coverage so that the distance between 2 fire lanes or staging areas is no greater than 300'/400' per the International Fire Code, Section 503.1.1.
 2. Provide gates with a minimum 20' width with **Supra** lockboxes for emergency access to fire access roads per the International Fire Code, Sections 503.6 and D103.5.
 3. Resubmittal is required for the Fire Prevention Bureau.

If there are any questions regarding this review, please contact Javan Cross at the e-mail address listed below or you may call (630) 256-4130.

Javan Cross

JCross@aurora-il.org