GENERAL NOTES

- . REFER TO DRAWING G100 FOR PROJECT GENERAL NOTES.
- COORDINATE FIRE-RESISTANCE-RATED ASSEMBLIES INFORMATION CONTAINED ON DRAWING G300 WITH THE WORK OF ALL CONTRACTS.
- . IDENTIFY FIRE-RATED ASSEMBLIES WITH STENCILED PAINTED LETTERING OR VINYL APPLIED LETTERING IN CONCEALED SPACES ABOVE CEILINGS AT 30' (MAX.) INTERVALS AND NOT MORE THAN 15' FROM THE ENDS OF WALLS. REFER TO SPECIFICATION SECTIONS 07 05 53 -FIRE AND SMOKE ASSEMBLY IDENTIFICATION FOR ADDITIONAL INFORMATION.
- CEILINGS AT 30' (MAX.) INTERVALS AND NOT MORE THAN 15' FROM THE ENDS OF WALLS ON WALLS THAT DEFINE PLENUMS. PROVIDE ASSEMBLY IDENTIFICATION FOR ADDITIONAL INFORMATION. REFER TO MECHANICAL DRAWINGS FOR LOCATIONS OF PLENUM CEILINGS.

NOTE: SCALES DEPICTED ON THIS DRAWING ARE NOT CORRECT UNLESS PLOTTED SHEET SIZE IS 30 X 42 INCHES.

- IN GYPSUM BOARD PARTITIONS AND WALLS, PROVIDE 2X WOOD BLOCKING FOR WALL-MOUNTED ITMES REQUIRING MECHANICAL
- 6. LOCATE EDGES OF DOOR FRAMES 3" OFF CORNER UNLESS DOOR LOCATION IS DIMENSIONED OTHERWISE.
- PROVIDE FIRE DEPARTMENT LOCK BOX(ES) AT LOCATION(S) ACCEPTABLE TO FIRE DEPARTMENT AND AUTHORITY HAVING JURISDICTION.
- 3. IN WALLS WITH COMBUSTIBLE FRAMING, PROVIDE 2X FIREBLOCKING IN STUD CAVITIES AT 10'0" O.C. (MAX.), VERTICALLY.

SHEET TITLE FIRST FLOOR

CHECKED

SHEET NUMBER

FIRST FLOOR PLAN SCALE: 1/4" = 1'-0"

—(06.473) 15'-7" MERCHANDISE CHECK-IN 06.473 12'-0" OFFICE 114 06.473 CENTER WALL ON GRIDLINE 25'-10"± SECURITY FRIDGE | ROLLING CART WORKBENCH 13 A1201 27'-3" 27'-9"

27'-3"

DISTANCE BETWEEN TRASH ENCLOSURE AND BUILDING IS NOT

SHOWN TO SCALE; REFER TO

CIVIL DRAWINGS, SUBMITTED SEPARATELY, FOR ACTUAL

RELATIVE TO BUILDING.

LOCATION OF TRASH ENCLOSURE

27'-9"

24'-3 1/2"

8'-0"