



City of Aurora

Fire Prevention Bureau • 5 E Galena BL #G • Aurora, Illinois 60505-3305 • (630) 256-4130
Fax (630) 256-4139

Jbk Leasing Llc
624 Timber Ridge Ct

Tuesday, March 27, 2018

Eureka, IL 61530

Re: Vermeer Midwest - 2801 Beverly Drive - Final Plan Revision For Lots 1, 14, 15 And 16
Project # 17-00000259

dorlik@watermark-engineering.com

Dear Jbk Leasing Llc

Fire Prevention Bureau - The Fire Prevention Bureau has reviewed the proposal and has the following comments.

- ⇒ **With The Following Condition(s) as prescribed in the 2009 International Fire Code as adopted and/or amended by the City of Aurora:**
- 1. Provide a supply hydrant for any fire department connection located between 50' minimum to 100' maximum from the fire department connection per the International Fire Code, Section 507.5.1.2.***If bollards are used to protect the hydrant, they cannot obstruct any adjacent parking spaces. These spaces must be painted to indicate no parking in these areas.*****
 - 2. Resubmittal is required for the Fire Prevention Bureau.**

If there are any questions regarding this review, please contact Javan Cross at the e-mail address listed below or you may call (630) 256-4130.

Javan Cross

JCross@aurora-il.org