PROJECT MANUAL FOR City of Aurora Project #: 24-113

FINANCE DEPARTMENT INTERIOR RENOVATION 44 E. DOWNER PLACE AURORA, ILLINOIS 60507

OWNER



CITY OF LIGHTS

44 E. DOWNER PLACE AURORA, ILLINOIS 60507

ARCHITECT/ENGINEER

KLUBER ARCHITECTS + ENGINEERS 41 W. BENTON STREET AURORA, ILLINOIS 60506

BIDS DUE WEDNESDAY, NOVEMBER 13, 2024, AT 11:00 A.M. CITY OF AURORA CITY CLERK'S OFFICE 44 E. DOWNER PLACE AURORA, ILLINOIS 60507

DATE: OCTOBER 24, 2024 PROJECT NO. 24-130-1552

SECTION 00 01 01 PROJECT TITLE PAGE

PROJECT MANUAL

FOR

FINANCE DEPARTMENT INTERIOR RENOVATION 44 E. DOWNER PLACE AURORA, ILLINOIS 60507

OWNER

CITY OF AURORA 44 E. DOWNER PLACE AURORA, ILLINOIS 60507

ARCHITECT / ENGINEER

KLUBER ARCHITECTS + ENGINEERS 41 W. BENTON STREET AURORA, ILLINOIS 60506

SECTION 00 01 07 SEALS PAGE

1.01 DESIGN PROFESSIONALS' SEALS

A. ARCHITECT

B. STRUCTURAL ENGINEER

C. ELECTRICAL ENGINEER



D. MECHANICAL ENGINEER







SECTION 00 01 10

	TABLE OF CONTENTS	DACES
		PAGES
	DRY INFORMATION Droiget Title Dage	00 01 01 1 1
00 01 01		00 01 01-1-1
00 01 07	Seals Page	00 01 07-1-1
00 01 10	l able of Contents	00 01 10-1-3
00 01 15	Drawing Index	00 01 15-1-2
BIDDING REC	QUIREMENTS	
00 11 13	Advertisement for Bids (2 Page Attachment)	00 11 13-1-3
00 21 13	Instructions to Bidders (14 Page Attachment)	00 21 13-1-15
00 31 13	Preliminary Schedule	00 31 13-1-1
00 41 13	Bid Form - Stipulated Sum	00 41 13-1-3
00 43 13	Bid Security Form	00 43 13-1-1
00 43 14	Bid Form Supplement - Bidder's Certification (1 Page Attachment)	00 43 14-1-2
00 43 15	Bid Form Supplement - Bidder's Tax Certification (1 Page Attachment)	00 43 15-1-2
00 43 16	Bid Form Supplement - Apprenticeship or Training Prog Certification and Current Signatory Letters (2 Page Attachment)	ram 00 43 16-1-3
00 43 17	Bid Form Supplement - City of Aurora Local Vendor Pre Application (1 Page Attachment)	eference 00 43 17-1-2
CONTRACTIN	IG REQUIREMENTS	
00 52 00	Agreement Form (11 Page Attachment)	00 52 00-1-12
00 60 00	Project Forms	00 60 00-1-1
00 72 00	General Conditions	00 72 00-1-1
00 73 00	Supplementary Conditions	00 73 00-1-15
00 73 40	Labor and Wage Requirements	00 73 40-1-1
SPECIFICATIONS		
DIVISION 01 -	- GENERAL REQUIREMENTS	
01 10 00	Summary	01 10 00-1-2
01 20 00	Price and Payment Procedures	01 20 00-1-4
01 21 00	Allowances	01 21 00-1-1
01 30 00	Administrative Requirements (1 Page Attachment)	01 30 00-1-7
01 40 00	Quality Requirements	01 40 00-1-5
01 41 00	Regulatory Requirements	01 41 00-1-2
01 42 00	References	01 42 00-1-5

01 60 00Product Requirements (1 Page Attach01 61 16Volatile Organic Compound (VOC) Co01 61 16.01Accessory Material VOC Content Cert01 70 00Execution and Closeout Requirements01 77 00Closeout Procedures01 78 00Closeout SubmittalsDIVISION 02 EXISTING CONDITIONS	imment) 01 60 00-1-5 ontent Restrictions 01 61 16-1-2 tification Form 01 61 16.01-1-1 s 01 70 00-1-9 01 77 00-1-2 01 78 00-1-5
01 61 16Volatile Organic Compound (VOC) Co01 61 16.01Accessory Material VOC Content Cert01 70 00Execution and Closeout Requirements01 77 00Closeout Procedures01 78 00Closeout SubmittalsDIVISION 02 EXISTING CONDITIONS	ontent Restrictions 01 61 16-1-2 tification Form 01 61 16.01-1-1 s 01 70 00-1-9 01 77 00-1-2 01 78 00-1-5
01 61 16.01Accessory Material VOC Content Cert01 70 00Execution and Closeout Requirements01 77 00Closeout Procedures01 78 00Closeout SubmittalsDIVISION 02 EXISTING CONDITIONS	tification Form 01 61 16.01-1-1 s 01 70 00-1-9 01 77 00-1-2 01 78 00-1-5
01 70 00Execution and Closeout Requirements01 77 00Closeout Procedures01 78 00Closeout SubmittalsDIVISION 02 EXISTING CONDITIONS	s 01 70 00-1-9 01 77 00-1-2 01 78 00-1-5
01 77 00Closeout Procedures01 78 00Closeout SubmittalsDIVISION 02 EXISTING CONDITIONS	01 77 00-1-2 01 78 00-1-5
01 78 00 Closeout Submittals DIVISION 02 EXISTING CONDITIONS	01 78 00-1-5
DIVISION 02 EXISTING CONDITIONS	
02 41 00 Demolition	02 41 00-1-2
DIVISION 06 WOOD, PLASTICS, AND COMPOSITE	S
06 10 00 Rough Carpentry	06 10 00-1-3
06 41 00 Custom Casework	06 41 00-1-7
DIVISION 07 THERMAL AND MOISTURE PROTECT	ION
07 05 53 Fire and Smoke Assembly Identification	on 07 05 53-1-2
07 21 19.02 Foamed-In-Place Insulation	07 21 19.02-1-3
07 84 00 Firestopping	07 84 00-1-4
07 92 00 Joint Sealants	07 92 00-1-5
DIVISION 08 OPENINGS	
08 12 13 Hollow Metal Frames	38 11 13-1-4
08 14 16 Flush Wood Doors	08 14 16-1-4
08 31 00 Access Doors and Panels	08 31 00-1-2
08 56 53 Security Windows	08 56 53-1-4
08 71 00 Door Hardware	08 71 00-1-11
08 80 00 Glazing	08 80 00-1-5
DIVISION 09 FINISHES	
09 05 61 Common Work Results for Flooring Pr	reparation 09 05 61-1-6
09 21 16 Gypsum Board Assemblies	09 21 16-1-6
09 30 00 Tiling	09 30 00-1-6
09 51 00 Acoustical Ceilings	09 51 00-1-4
09 65 00 Resilient Flooring	09 65 00-1-3
09 90 00 Painting and Coating	09 90 00-1-4
DIVISION 10 SPECIALTIES	
10.26.01 Wall and Corper Guarde	10 26 01-1-2

DIVISION 12 I	FURNISHINGS	
12 24 00	Window Shades - MechoShade Systems	12 24 00-1-4
12 36 00	Countertops	12 36 00-1-4
DIVISION 21 I	FIRE SUPPRESSION	
21 05 00	Common Work Results for Fire Suppression	21 05 00-1-3
21 13 00	Fire Suppression Sprinklers	21 13 00-1-3
DIVISION 22 I	PLUMBING	
22 07 19	Plumbing Piping Insulation	22 07 19-1-3
22 10 05	Plumbing Piping	22 10 05-1-5
22 10 06	Plumbing Piping Specialties	22 10 06-1-2
22 30 00	Plumbing Equipment	22 30 00-1-2
22 40 00	Plumbing Fixtures	22 40 00-1-5
DIVISION 23 I	HEATING, VENTILATING, AND AIR-CONDITIONING (HVAC)	
23 05 93	Testing, Adjusting, and Balancing for HVAC	23 05 93-1-3
23 07 13	Duct Insulation	23 07 13-1-3
23 31 00	HVAC Ducts and Casings	23 31 00-1-4
23 33 00	Air Duct Accessories	23 33 00-1-2
23 37 00	Air Outlets and Inlets	23 37 00-1-2
23 82 00	Convection Heating and Cooling Units	23 82 00-1-2
DIVISION 26 I	ELECTRICAL	
26 05 00	Basic Electrical Requirements	26 05 00-1-6
26 05 05	Selective Demolition for Electrical	26 05 05-1-2
26 05 83	Wiring Connections	26 05 83-1-2
26 24 16	Panelboards	26 24 16-1-6
26 27 26	Wiring Devices	26 27 26-1-7
26 51 00	Interior Luminaries	26 51 00-1-7
DIVISION 28 I	ELECTRONIC SAFETY AND SECURITY	
28 46 00	Fire Detection and Alarm	28 46 00-1-6
	END OF SECTION	

SECTION 00 01 15 DRAWING INDEX

1.01 GENERAL

- G100 COVER SHEET, GENERAL NOTES, SYMBOLS & DRAWING INDEX
- G201 ACCESSIBILITY REQUIREMENTS

1.01 ARCHITECTURAL

- A240 FOURTH FLOOR DEMOLITION FLOOR PLAN
- A240C FOURTH FLOOR REFLECTED CEILING DEMOLITION PLAN
- A340 FOURTH FLOOR PLAN
- A430 THIRD FLOOR CEILING PLAN
- A440 REFLECTED CEILING PLAN
- A800 DOOR, FRAME, & HARDWARE SCHEDULES, INTERIOR ELEVATIONS
- A801 INTERIOR CASEWORK AND PLAN DETAILS
- A940 FOURTH FLOOR FINISH PLAN
- A1100 INTERIOR PARTITION TYPES & DETAILS

1.02 FIRE PROTECTION

F340 FOURTH FLOOR FIRE PROTECTION PLAN

1.03 PLUMBING

P340 FOURTH FLOOR PLUMBING PLAN, SCHEDULES AND DETAILS

1.04 MECHANICAL

- M240 FOURTH FLOOR MECHANICAL DEMOLITION PLAN
- M340 FOURTH FLOOR MECHANICAL PLAN, SCHEDULES AND DETAILS

1.05 ELECTRICAL

- E050 ELECTRICAL SYMBOLS LIST, ABBREVIATIONS, SCHEDULES & DETAILS
- E240 FOURTH FLOOR ELECTRICAL DEMOLITION PLAN

- E340 FOURTH FLOOR ELECTRICAL POWER PLAN
- E430 THIRD FLOOR ELECTRICAL LIGHTING & DEMOLITION PLANS
- E440 FOURTH FLOOR ELECTRICAL LIGHTING PLAN
- E600 ELECTRICAL SCHEDULES

SECTION 00 11 13 ADVERTISEMENT FOR BIDS

1.01 CITY OF AURORA INVITATION TO BID ATTACHED (2 PAGES).

1.02 GENERAL

- A. A **MANDATORY Pre-Bid Meeting** will be held Monday, November 4, 2024 from 2:00 PM to 3:00 PM. All bidders should meet at 44 East Downer Place, Second Floor, City Council Chambers, Aurora, Illinois 60507. **Bidders must be present at the start of the meeting to qualify to bid on the project.**
- B. A second non-mandatory walk through will take place Wednesday, November 6, 2024 at 10:00 AM to 11:00 AM at the City of Aurora, 44 E. Downer Place, Aurora, Illinois 60507. Meet at the first floor lobby on the east of the building adjacent to the space to be renovated.



CITY OF AURORA INVITATION TO BID **24-113** FINANCE DEPARTMENT INTERIOR RENOVATION

Sealed bids will be received at the City Clerk's Office, 44 East Downer Place, Aurora, Illinois 60507 until **11:00 a.m., Wednesday, November 13, 2024**, for the Finance Department Interior Renovation Project (fourth floor). Proposals will be opened and read publicly via a non-mandatory teleconferenced live stream, access details to be provided to all plan holders 24 to 48 hours in advance of the bid opening.

The proposed work consists of demolition of existing ceilings, interior walls, floor coverings, mechanical, plumbing and electrical components as required for the proposed renovations. New work includes open office space, private offices, new ceilings, floor coverings, new lighting system and mechanical system modifications. The common elevator lobby and bathrooms will also be renovated. The work will cover an area of approximately 3,900 square feet.

Specifications, drawings and other pertinent documents will be available on <u>Friday, October 25, 2024</u> and may be obtained online at: <u>https://www.aurora-il.org/bids.aspx</u>

The Bidding Documents may also be examined at the Architect's office, Kluber, Inc., 41 W. Benton Street, Aurora, IL 60506.

A mandatory pre-bid meeting will be held Monday, November 4, 2024 from 2:00 p.m. to 3:00 p.m. All bidders should meet at 44 East Downer Place, Second Floor, City Council Chambers, Aurora, Illinois 60507. Bidders must be present at the <u>start</u> of the meeting to qualify to bid on the project.

All inquiries and/or questions pertaining to the provisions and specifications of this bid package shall be directed to the Director of Purchasing, in writing at <u>PurchasingDL@aurora.il.us</u>. Questions will be accepted until 5:00pm, Wednesday, November 6, 2024. Questions will be answered via addendum and posted to the City's website at <u>https://www.aurora-il.org/bids.aspx</u> by 12:00 pm, Friday, November 8, 2024. <u>NO</u> questions will be accepted or answered verbally. No questions will be accepted or answered after the November 6, 2024 cut-off date/time. It is the responsibility of the interested bidder to check our website and assure they have received addendum, if any issued, and acknowledge such receipt where indicated.

A bid bond or a certified check payable to the City of Aurora in the amount of 10% of the bid price is required with the presented bid. A 100% performance and payment bond will be required from the successful Bidder.

The City of Aurora encourages minority business firms to submit bids and encourages the successful firm to utilize minority businesses as applicable.

Any bidder who owes the City money may be disqualified at the City's discretion.

The City of Aurora has a local preference ordinance that would apply to this contract.

Sufficient proof of liability and workmen's compensation must be furnished to satisfy requirements of the City of Aurora.

When required by State Law, please be advised that all Bids must comply with the Illinois Prevailing Wage Act and the Prevailing Rate of Hourly Wages in the City of Aurora where the Work is to be performed is to be paid to all persons on the project.

The successful respondent shall comply with all codes, ordinances, rules, statutes, laws and regulations of the City of Aurora, State of Illinois as they apply to all Public Works construction projects.

The City of Aurora reserves the right at any time and for any reason to cancel this Invitation to Bid, to accept or reject any or all Bids or portion thereof, or accept an alternate bid. The City reserves the right to waive any immaterial defect in any bid, or technicality, informality or irregularity in the bids received, and to disregard all nonconforming or conditional bids or counter- proposals. Unless otherwise specified by the bidder or the City, the City reserves the right to hold the best bids for ninety (90) days from the opening date set forth above. The City may seek clarification from any bidder at any time and failure to respond promptly is cause for rejection. The City further reserves the right to award the bid to the lowest responsible Bidder whose offer best responds in quality, fitness and capacity to the requirements of the proposed work or usage and therefore is in the best interest of the City.

CITY OF AURORA

Jolene Coulter Director of Purchasing

SECTION 00 21 13 INSTRUCTIONS TO BIDDERS

1.01 FORM OF INSTRUCTIONS TO BIDDERS

A. See attached City of Aurora Instructions to Bidders.

CITY OF AURORA, ILLINOIS INSTRUCTIONS TO BIDDERS

01. **REQUIREMENTS OF BIDDER**

The successful Bidder may be required to (a) enter into a fully signed contract in writing with the City of Aurora covering matters and things as are set forth in the Bid Package; (b) execute a bond necessary for surety acceptable to the City of Aurora in the amount of one hundred percent (100%) of the full contract price and to be conditioned for the faithful fulfillment of the contract for the payment of all labor and materials used in the Work and to include the protection of the City from all liens and damages arising out of the Work; (c) carry insurance acceptable to the City covering public liability, property damage and workers compensation; and (d) pay workers in accordance with the schedule of prevailing wages for Kane County attached hereto.

02. ACCEPTANCE OF BIDS

- a. Bidder must submit an original bid response, marked as "original" and one (1) complete paper copy and one (1) PDF copy on a flash drive, and shall have provided all requested information, and submitted all appropriate forms, certificates, affidavits and addendum acknowledgements <u>in each copy</u> in order to be considered responsive.
- b. Bids must be submitted on the forms provided and all information and certifications called for must be furnished. Bids submitted in any other manner, or which fail to furnish all information or certificates required, may be summarily rejected. Bids may be modified or withdrawn prior to the time specified for the opening of bids. Bids shall be filled out legibly in ink or type-written with all erasures, strikeovers and corrections initialed in ink by the person signing the bid. The bid shall include the legal name of the bidder, the complete mailing address, and be signed in ink by a person or persons legally authorized to bind the bidder to a contract. Name of person signing should be typed or printed below the signature.

Envelopes containing bids must be sealed and addressed to the City of Aurora City Clerk. The name and address of the bidder and the Invitation Number must be shown in the upper left corner of the envelope.

c. The City of Aurora reserves the right at any time and for any reason to accept or reject any or all Bids or portion thereof, or accept an alternate bid. The City reserves the right to waive any immaterial defect in any bid, or technicality, informality or irregularity in the bids received, and to disregard all nonconforming or conditional bids or counter-proposals. Unless otherwise specified by the bidder or the City, the City reserves the right to hold the best bids for ninety (90) days from the opening date. Bidder agrees to accept a notice of award, if selected, based on the terms of this Bid Proposal in the event that a notification of award is received on or before expiration of the 90-day time period. The City reserves the right to cancel the Bid Proposal at any time, without liability for any loss, damage,

cost or expense incurred or suffered by any Bidder as a result of that cancellation. Each Bidder is solely responsible for the risk and cost of preparing and submitting a Bid Proposal.

d. Although price is a consideration, qualifications and experience, capacity to handle the work, and response to the bid, will also be considered. No Bid Proposal will be considered unless the Bidder shall furnish evidence satisfactory to the City that he has the necessary facilities, abilities, experience, equipment, and financial and physical resources available to fulfill the conditions of the contract and execute the Work should the contract be awarded to them. Bid Proposal documents which are not responsive to the requirements herein may not be considered by the City for an award of the contract.

The contract will be awarded to the lowest responsive responsible Bidder. In determining the responsibility of any Bidder, the City may take into account other factors such as past records of its or other entities transactions with the Bidder, experience, ability to work cooperatively with the City and its staff, adequacy of equipment, ability to complete performance within necessary time limits, and other pertinent considerations such as, but not limited to, reliability, reputation, competency, skill, efficiency, facilities and resources.

The Bidder will be awarded in the City's best interests based on these and other legally-allowable considerations. The City and its representatives and agents may make any investigations deemed necessary to determine the ability of the Bidder to perform the Work. The Bidder shall furnish any information and data requested by the City for this purpose.

03. RECEIPT OF BIDS

- a. It is suggested that respondents allow a minimum of four (4) days for delivery through U.S. mail, or Bids may be delivered to the Office of the City Clerk in person. Overnight courier is acceptable provided timely receipt of Bids. The Bidder assumes responsibility for late delivery of the mail. It is the sole responsibility of the Bidder to see that his Bid is received in the proper time.
- b. Any Bid received by the Office of the City Clerk after 11:00 a.m. on Wednesday, November 13, 2024 shall be rejected and returned unopened. There will be no exceptions!

04. WITHDRAWAL OF BIDS

Bidders are cautioned to verify their bids before submission. Negligence on the part of the bidder in preparing the bid confers no right for withdrawal or modification of the bid after it has been opened. Bidders may not withdraw their bid after the opening without the approval of the Director of Purchasing. Requests to withdraw a bid must be in writing and properly signed. Bidders may, however, without prejudice, modify or withdraw its bid by written request, provided that the request is received by the City Clerk prior to the scheduled opening and at the address to which bid proposals were to be submitted. Following withdrawal or modification of its Bid Proposal, Bidder may submit a new Bid Proposal, provided it is received by the City Clerk prior to the bid proposal due date. No bid proposal will be opened which is received after the time and date scheduled for the Bid Proposals to be received.

05. BID DEPOSIT

Each Bidder shall deposit with Bid a Bid guarantee consisting of a bank draft, Bid bond, cashier's check, or certified check drawn on a good and solvent National or State Bank and payable to the order of the City, in an amount not less than ten percent (10%) of the total amount of the Bid submitted, as a guaranty that in case the Bidder's Bid is accepted, the Bidder shall within one day after the date of such acceptance and notification thereof, deliver to the City a contract signed and executed by the Bidder, proper insurance certificates and a Performance and Payment Bond in one hundred percent (100%) of the contract sum furnished by a responsible bonding company acceptable to and written upon forms prepared or approved by the City as security for payment of labor and materials and for the faithful performance of the contract and compliance with the provisions of law relating to the payment of prevailing rate of wages. All Bid deposits will be retained by the City until a Bid award is made, at which time the Bid deposit will be promptly returned to the unsuccessful Bidders. The Bid deposit of the successful Bidder will be retained until the equipment, goods or services have been received or completed and found to be in compliance with the specifications. Performance by the Bidder shall not be considered complete, until final inspection and acceptance by the City of the Bidder's Work. Final inspection shall occur within 30 days after the actual completion of the Work. Execution of the contract is contingent upon receipt of an acceptable Performance and Payment Bond and any required certificates of insurance. Upon failure to meet the requirements of this paragraph, the Bidder shall forfeit the amount deposited as liquidated damages and no mistakes or errors on the part of the Bidder shall excuse the Bidder or entitle him to a return of the aforementioned amount.

06. BOND AND INSURANCE

The Bidder will be required to furnish a Performance and Payment Bond in the amount of one hundred percent (100%) of the full contract price, Public Liability Insurance, and Workers Compensation Insurance; all of which shall be acceptable to the City of Aurora.

The Bidder awarded the project will need to provide performance and payment bonds for one year with a letter attached from the bond company certifying that the bond may be automatically renewed for the second year.

The term Payment Bond shall be understood to mean the bond executed by the Bidder and his surety guaranteeing the payment of all sums of money due for any labor, materials, apparatus, fixtures, or machinery furnished to such principal for the purpose of performing the contract work.

The term Performance Bond shall be understood to mean the bond, executed by the contractor and his surety, guaranteeing complete execution of the contract.

Proof of liability insurance coverage through a reputable, recognized carrier shall be provided at the time of acceptance and signing of the contract and shall remain current for the duration of the contract.

The City of Aurora, by showing and substantiating sufficient proof of incompetence, negligence, poor or substandard workmanship which would cause unwarranted damage

or deterioration of either premises, contents or appendages, reserves the right to terminate said Contractor without recourse from the City by successful Contractor.

07. CITY'S AGENT

The Director of Purchasing, or delegate, shall represent and act for the City in all matters pertaining to the Bid proposal and contract in conjunction thereto.

08. INVESTIGATION

It shall be the responsibility of the Bidders to make any and all investigations necessary to become thoroughly informed of what is required and specified in the Bid. No plea of ignorance by the Bidders of conditions that exist or may hereafter exist as a result of failure or omission on the part of the Bidder to make the necessary examinations and investigations will be accepted as a basis for varying the requirements of the City of the compensation to the Bidder.

Each Bidder submitting a Bid is responsible for examining the complete Bid Package and all Addenda, and is also responsible for informing itself of all conditions that might in any way affect the cost or the performance of any Work. Failure to do so will be at the sole risk of the Bidder, and no relief will be given for errors or omissions by the Bidder. If awarded the contract, the Bidder will not be allowed any extra compensation by reason of any matter or thing concerning which such Bidder should have fully informed himself, because of his failure to have so informed himself prior to the bidding. The submission of a Bid shall be construed as conclusive evidence that the Bidder has made such examination as is required in this section and that the Bidder is conversant with local facilities and difficulties, the requirements of the Bid Package documents, and of pertinent, local, state and federal laws and codes, prevailing local labor and material markets, and has made due allowance in its Bid for all contingencies. Before any award is made of the contract to the Bidder, the Bidder may be required to, upon request of the City, furnish information concerning his performance record in his capacity to complete the Work in an efficient and timely manner.

09. BIDDER CAPABILITY

The City reserves the right to require of the Bidder proof of his/her capability to perform as required by the specifications. However, prequalification of the Bidder shall not be required. The City may, at its option, disqualify a Bidder and reject his proposal for cause. Reasons deemed sufficient for this action shall include, but not be limited to, the following:

- Evidence of collusion among bidders.
- Receipt of more than one bid proposal on any project from an individual, or from a corporation. This restriction does not apply to subcontractors.
- Default on any previous contract.
- Unreasonable failure to complete a previous contract within the specified time or for being in arrears on an existing contract without reasonable cause for being in arrears.

- Inability to perform as revealed by an investigation of the Proposer's financial statement, experience and/or plant and equipment.
- Any proposer who owes the city money may be disqualified at the City's discretion.

10. AWARD OF BID

It is the intent of the City to award a contract to the lowest responsive responsible bidder meeting specifications. The City reserves the right to determine the lowest responsive responsible bidder on the basis of an individual item, groups of items, or in any way determined to be in the best interests of the City. Award will be based on the following factors, but not limited to (where applicable): (a) adherence to all conditions and requirements of the bid specifications; (b) price; (c) qualifications of the bidder, including past performance, financial responsibility, general reputation, experience, service capabilities, and facilities; (d) delivery or completion date; (e) product appearance, workmanship, finish, taste, feel, overall quality, and results of product testing; (f) maintenance costs and warranty provisions; and (g) repurchase or residual value.

However, if the Bidder modifies limits, restricts or subjects his bid proposal to conditions that would change the requirements of the bid, this would be considered a conditional or qualified Bid Proposal and will not be accepted. The City reserves the right to delete any item listed in the bid.

11. **PRICES**

The price quoted for each item is the full purchase price, including delivery to destination and includes all transportation and handling charges, premiums on bonds, material or service costs and all other overhead charges of every kind and nature. Unless otherwise specified, prices shall remain firm for the contract period.

Unit prices shall not include any local, state or federal taxes. In case of mistake in extension of price, unit price shall govern. All prices must be typewritten or written in black ink. (The party signing the Bid Proposal or his/her authorized representative must initial any alteration in ink.)

12. DISCOUNTS

Prices quoted must be net after deducting all trade and quantity discounts. Where cash discounts for prompt payment are offered, the discount period shall begin with the date of receipt of a correct invoice or receipt or final acceptance of goods, whichever is later.

13. PAYMENT

Payment shall be made for services rendered. The City, after inspection and acceptance, and in consideration of the faithful performance by the Bidder, agrees to pay for the completion of the work embraced in this Contract, payment shall be made in accordance with the Illinois Local Government Prompt Payment Act (50 ILCS 505/1, *et. seq.*) upon receipt of the invoice.

Time, in connection with any discount offered, will be computed from the date of delivery to the City or from the date a correct invoice is received by the City of Aurora Purchasing Division, if the latter date is later than the date of delivery.

Prices will be considered NET, if no payment discount is shown.

Invoices MUST contain the Purchase Order Number, as issued by the City.

The successful Bidder shall submit invoices via e-mail to:

PurchasingDL@aurora-il.org

or Mail to the following address:

City of Aurora Attn: Purchasing Division 44 E. Downer Place Aurora, IL 60507

The City of Aurora offers electronic funds transfer (EFT) payment to our vendors. EFT is fast, simple, safe and secure and is *our preferred method of payment!*

14. TAXES

The City of Aurora is exempt, by law, from paying State and City Retailer's Occupation Tax, State Service Occupation Tax, State Use Tax and Federal Excise Tax upon City works and purchases. The City of Aurora's Sales Tax Exemption Number is E9996-0842-07.

15. DEFAULT

Time is of the essence of this contract and if delivery of acceptable items or rendering of services is not completed by the time promised, the City reserves the right, without liability, in addition to its other rights and remedies, to terminate the contract by notice effective when received by Bidder, as to stated items not yet shipped or services not yet rendered The City will procure articles or service from other sources and hold the Bidder responsible for any excess cost incurred as provided for in Article 2 of the Uniform Commercial Code.

16. INTERPRETATION OR CORRECTION OF BIDDING DOCUMENTS

Bidders shall promptly notify the City of any ambiguity, inconsistency of error which they may discover upon examination of the bidding documents. Interpretations, corrections and changes will be made by addendum. Each bidder shall ascertain prior to submitting a bid that all addenda have been received and acknowledged in the bid.

17. INSPECTION

Materials or equipment purchased are subject to inspection and approval at the City's destination. The City reserves the right to reject and refuse acceptance of items which are

not in accordance with the instructions, specifications, drawings or data of Bidder's warranty (express or implied). Rejected materials or equipment shall be removed by, or at the expense of, the Bidder promptly after rejection.

18. WARRANTY

Bidder warrants that all goods and services furnished hereunder will conform in all respects to the terms of the solicitation, including any drawings, specifications or standards incorporated herein, and that they will be free from latent and patent defects in materials, workmanship and title, and will be free from such defects in design. In addition, Bidder warrants that said goods and services are suitable for, and will perform in accordance with, the purposes for which they are purchased, fabricated, manufactured and designed or for such other purposes as are expressly specified in this solicitation. The City may return any nonconforming or defective items to the Bidder or require correction or replacement of the item at the time the defect is discovered, all at the Bidder's risk and expense. Acceptance shall not relieve the Bidder of its responsibility.

Contractor and/or Bidder (as case may be) expressly warrants that all goods and services (real property and all structures thereon) will conform to the drawings, materials, performance and any other specifications, samples or other description furnished by the City, and will be fit and sufficient for the purpose intended, merchantable, of good material and workmanship. Contractor and/or Bidder (as case may be) agrees that these warranties shall run to the City of Aurora, its successor, assigns, customers and users of the products or services and that these warranties shall survive acceptance of the goods or performance of the services.

19. CANCELLATION

The City reserves the right to cancel the whole or any part of the contract if the Bidder fails to perform any of the provisions in the contract or fails to make delivery within the time stated. The Bidder will not be liable to perform if situations arise by reason of strikes, acts of God or public enemy, acts of the City, fires or floods.

20. SIGNATURES

Bid proposals must be signed by the Bidder with his/her usual signature. Bids by partnerships must be signed with the partnership name by all members of the partnership, or an authorized representative, followed by the signature and title of the person signing. Bids by corporations must be signed with the name of the corporation, followed by the signature and title of the person authorized to bind it in the matter. All signatures must be in ink.

When a corporation submits a Bid, its agent must present legal evidence that he has lawful authority to sign said Bid and that the corporation has a legal existence. In the event that any corporation organized and doing business under the laws of any foreign state is the successful Bidder, such corporation must present evidence before any contract is executed that it is authorized to do business in the State of Illinois. Bids by corporations must be executed in the corporate name by the President or a Vice President (or other corporate officer accompanied by evidence of authority to sign), and the signature must be attested by the Secretary or an Assistant Secretary, and the corporate seal must be affixed. The corporate address and state of incorporation must be shown below the signature. Bids by partnerships must be executed in the partnership name and signed by a partner whose title must appear under the signature, and the official address of the partnership must be shown below the signature. Any corrections to entries made on the Bid forms shall be initialed by the person signing the Bid. When requested by the City, satisfactory evidence of the authority of any signature on behalf of the Bidder shall be furnished.

21. SPECIAL CONDITIONS

Wherever special conditions are written into the Special Conditions and Specifications which are in conflict with conditions stated in these Instructions to Bidders, the conditions stated in Special Conditions and Specifications shall take precedence.

22. PERMITS AND LICENSES

The successful Bidder shall obtain, at its own expense, all permits and licenses which may be required to complete the contract.

23. **REGULATORY COMPLIANCE**

Bidder represents and warrants that the goods or services furnished hereunder (including all labels, packages and container for said good) comply with all applicable standards, rules and regulations in effect under the requirements of all Federal, State and local laws, rules and regulations as applicable, including the Occupational Safety and Health Act as amended, with respect to design, construction, manufacture or use for their intended purpose of said goods or services. Bidder shall furnish "Material Safety Data Sheet" in compliance with the Illinois Toxic Substances Disclosure to Employees Act.

24. ROYALTIES AND PATENTS

Bidder shall pay all royalties and license fees. Bidder shall defend all suits or claims for infringement of any patent or trademark rights and shall hold the City harmless from loss on account thereof.

25. REFERENCES

Sufficient references of all like public and/or private agencies must be presented on a separate sheet and attached to this Bid. Listing must include company name, contact person, telephone number and date purchased. All Bidders, as a condition of and prior to entry into a contract, agree that a complete background investigation of the principals of the Bidder and all employees who will work on the project may be made. Bidders agree to cooperate with the appropriate City of Aurora personnel to supply all information necessary to complete these investigations. The City of Aurora in its complete discretion may disqualify any Bidder, including low Bidder, and may void any contract previously entered into based on its background investigation.

26. ELIGIBILITY

By signing this bid, the bidder hereby certifies that they are not barred from bidding on this contract as a result of a violation of Article 33E, Public Contracts of the Illinois Criminal Code of 1961, as amended (Illinois Compiled Statutes, 720 ILCS 5/33E-1).

27. COMPLIANCE WITH LAWS AND REGULATIONS

The Bidder shall at all times observe and comply with all Federal, State, Municipal and other local laws, ordinances, regulations, and requirements which in any manner affect the conduct of the Work, and with all Federal, State and local laws and policies of nondiscrimination, sexual harassment, prevailing wages and others applicable thereto; and all such orders or decrees as exist at the present and which may be enacted later, of bodies or tribunals having jurisdiction or authority over the Work, and no plea of misunderstanding or ignorance thereof will be considered. He shall indemnify and save harmless the City and all its officers, agents, employees and servants against any requirement, claim or liability arising from or based on the violation of any such law, ordinance, regulation, order or decree, whether by himself or his employees.

28. PATENTED DEVICES, MATERIALS, AND PROCESSES

It is mutually understood and agreed that without exception contract prices are to include all royalties and costs arising in the Work. It is the intent that whenever the Bidder is required or desires to use any design, device, material, or process covered by letters or patent or copyright, the right of such use shall be provided for by suitable legal agreement with the patent owner. The Bidder in all cases shall indemnify and save harmless the City from any and all claims for infringement by reason of the use of any such patent design, device, materials, or process, to be performed or used under the contract, and shall indemnify and save harmless the said City for any costs, expenses, attorney's fees, and damages which it may be obligated to pay, by reason of any such infringement at any time during the prosecution or after the completion of the Work.

29. PROTECTION AND RESTORATION OF PROPERTY

It is understood that in the execution of the Work herein provided for there may be interference with and/or damage to trees, shrubbery, crops, fences, railroad tracks, overhead structures such as poles, wires, cables, underground structures such as sewers, gas mains, telephone conduits and cables, water mains, drains, service connections, wires, pipes, conduits, located along, adjacent to, and/or crossing the locations of the Work, and that it may be necessary to relocate or reconstruct certain of such structures, improvements, and installations and/or to make repairs to the same by reasons of doing the Work herein provided for, and it is therefore particularly and specifically agreed that the Bidder except as otherwise herein provided, shall do the Work necessary for such relocation, reconstruction, and repair and shall bear and pay all of the cost and expense of such relocation, reconstruction, and/or repair of, and all damage done to any and all such pipe line and other structures, improvements, and installations, including service connections, if any, to adjacent property, existing at the date of the execution of the contract and/or existing, during the period of the Work to be done under the contract, which may be interfered with, damaged, and/or necessarily relocated, reconstructed, or repaired in the performance of the Work herein provided for, including the restoration and resurfacing of unpaved portions of public streets and alleys, rights-of-way, easements, and private property damaged or disturbed by the Work, the same to be restored to as good condition as the same existed at the time of the commencement of any such Work or relocation.

It is further agreed that the owners of any structures, improvements, installations, referred to in the preceding paragraph shall have the right to do the Work or any part thereof necessary for the relocation, reconstruction, replacement, repair, and other Work required by reason of any interference with and/or damage to such structures, improvements, installations, due to the prosecution of the Work and upon completion of such Work by them done, said owners may render bills to the Bidder for the cost and expenses thereof which bills shall be paid by the Bidder without extra compensation therefore from the City, upon demand by said owners, or upon demand made by the City upon the Bidder for the payment thereof.

30. INSURANCE AND HOLD HARMLESS PROVISION

At the Bidder's expense, the Bidder shall secure and maintain in effect throughout the duration of this contract, insurance of the following kinds and limits to cover all locations of the Bidder's operations. The Bidder shall furnish Certificates of Insurance to the City before starting or within ten (10) days after the execution of the contract, whichever date is reached first. All insurance policies shall be written with insurance companies approved by the City of Aurora and licensed to do business in the State of Illinois and having a rating of not less than A IX, according to the latest edition of the A.M. Best Company; and shall include a provision preventing cancellation of the insurance policy unless thirty (30) days prior written notice is given to the City. This provision shall also be stated on each Certificate of Insurance as: "Should any of the above-described policies be canceled before the expiration date thereof, the issuing company will endeavor to mail 10 days written notice to the certificate holder named to the left".

If requested, the awardee of this proposal will give the City a copy of the insurance policies. The policies must be delivered to the City within two weeks of the request.

The limits of liability for the insurance required shall provide coverage for not less than the following amount, or greater where required by law:

- (1) Worker's Compensation Insurance Statutory amount.
- (2) General Liability Insurance:
 - (a) \$1,000,000 per occurrence and \$2,000,000 general aggregate
 - (b) \$500,000 per occurrence for Property Damage
 - (c) \$1,000,000 per occurrence for Personal Injury
- (3) Auto Liability Insurance:
 - (a) Bodily injury with limits not less than \$1,000,000
 - (b) Property damage with limits not less than \$500,000
- (4) Umbrella excess liability of \$1,000,000 per occurrence, \$2,000,000 aggregate

The Bidder shall include the City as a primary, non-contributory additional named insured on both General and Auto Liability Insurance policies and indicate said status on any Certificates of Insurance provided to the City pursuant to this project. All insurance premiums shall be paid without cost to the City.

The Bidder agrees to indemnify and save harmless the City of Aurora, their agents and employees from and against all loss and expenses (including costs and attorneys' fees) by reason of liability imposed by law or claims made upon the City of Aurora for damages because of bodily injury, including death at any time resulting therefrom sustained by any person or persons or on account of damage to property, including loss of use thereof, arising out of or in consequence of the performance of this project work, whether such claims or injuries to persons or damage to property be due to the negligence of the Bidder or his Subcontractors. The Bidder shall assume total risk and shall be responsible for any and all damages or losses caused by or in any way resulting from the work and provide all insurance necessary to protect and save harmless the City of Aurora and its employees.

31. LOCAL BIDDER PREFERENCE

O20-029 approved April 28, 2020 defines "Local business" to mean a vendor or contractor who has a valid, verifiable physical business address located within the corporate boundaries of the City of Aurora at least twelve months prior to a bid or proposal opening date, from which the vendor, contractor or consultant operates or performs business on a daily basis, including manufacturing production or distribution. The business must disclose the percentage of workforce in the City of Aurora; be registered with the City of Aurora, if applicable; be subject to City of Aurora taxes (inclusive of sales taxes); be current with property tax payments and sales tax payments; not have any outside cited code violations; not have any outstanding debts to the City of Aurora; have adequately qualified and trained staff to service the bid of interest.

32. MINORITY PARTICIPATION

The City of Aurora encourages minority business firms to submit proposers and encourages the successful contract bidder to utilize minority businesses as subcontractors for supplies, equipment, services and construction.

33. WORKERS COMPENSATION ACT

The Bidder further agrees to insure his employees and their beneficiaries and to the employees and the beneficiaries of any subcontractor employed from time to time by him on said Work, the necessary first-aid, medical, surgical, and hospital services and any compensation provided for in the Workers Compensation Act of the State of Illinois that is or may be in force in the State.

Such insurance shall be placed by said Bidder in a company or association (to be approved by the City and to be accepted by the Council thereof) authorized under the laws of the State of Illinois to insure the liability above specified.

Said Bidder hereby further agrees to indemnify, keep and save harmless said City from all action, proceedings, claims, judgments, awards, and costs, loss, damages, expenses,

and attorney's fees which may in any way come against said City by reason of any accidental injuries or death suffered by any of his employees or the employees of any subcontractor employed by him in and about the performance of the Work provided for in the contract, and any and all liability resulting thereupon; and said Bidder, in case of any suit, action, or proceeding on account of any or all of the foregoing shall defend the same for and on behalf of said City and indemnify the City therefore, and pay the amount of any and all awards and final judgments and orders rendered and entered therein, together with all loss, costs, damages, attorney's fees, and expenses incurred therein. Said Bidder shall be the sole employer of its employees and workers, and in no way so shall the City be considered a joint employer of same under any circumstance.

34. RESPONSIBLE BIDDER

Section 2-331(5) of the Aurora City Code requires that bidders for city contracts in excess of \$25,000 must participate in active apprenticeship and training programs approved and registered with the United States Department of Labor's Bureau of Apprenticeship and Training to be considered a responsible bidder. A bidder must affirm such participation in the Bidder's Certification submitted with any bid. Furthermore, the bidder must submit a copy of each applicable program registration certificate with his/her bid.

35. SUBLETTING OR ASSIGNMENT OF WORK

If the Bidder sublets the whole or any part of the Work to be done under the contract, with or without the written consent of the City, he shall not, under any circumstances, be relieved of his liabilities and obligations. All transactions of the City shall be with the Bidder; subcontractors shall be recognized only in the capacity of employees or workmen and shall be subject to the same requirements as to character and competence. In case any party or parties, to whom any work under the contract shall have been sublet, shall disregard the directions of the City or his duly authorized representatives, or shall furnish any unsatisfactory Work or shall fail or refuse in any way to conform to any of the City, the Bidder shall require said party or parties in default to discontinue Work under the contract. Said Work shall be corrected or made good and shall be continued and completed by the said Bidder or by such other party or parties as are approved by the City, in the manner and subject to all of the requirements specified in the contract.

36. PROSECUTION OF WORK

The Bidder shall begin the Work to be performed under the contract no later than ten (10) days after the execution and acceptance of the contract, unless otherwise provided. The Work shall be conducted in such a manner and with sufficient materials, equipment and labor as is considered necessary to insure its completion within the time specified in the contract. The Bidder shall solely be fully responsible for complying with State and local prevailing wage requirements in accordance with the Bidders Certification, and for all wage rate and hour regulations and applications.

37. GUARANTEE AND MAINTENANCE OF WORK

The Bidder shall guarantee the Work to be free from defects of any nature for a period of one year from and after the final acceptance and payment for the Work by the City, and the Bidder shall maintain said Work and shall make all needed repairs and/or replacements during this one year period which in the judgment of the Council, may be necessary to insure the delivery of the Work to the City in first-class condition and in full conformity with the plans and specifications therefore, at the expiration of the guarantee period.

38. CONTRACT

The successful Bidder will be required to execute a contract in the form attached hereto (as may be modified and amended by the City) within five (5) days after notice of award and receipt of the contract from the City and sign and deliver to the City all required copies of the contract. Failure on the part of the Bidder to execute the contract within five (5) days and provide the required evidence of insurance at, or before the execution of the contract, will be considered just cause for the annulment of the award of the Bid.

39. INSURANCE CERTIFICATES

At, or prior to, delivery of the signed contract, the successful Bidder shall deliver to the City the policies of insurance or insurance certificates as required by the contract Documents. All policies or certificates of insurance shall be approved by the City before the successful Bidder may proceed with the Work. Execution of the contract by the City is contingent upon receipt of the insurance policies or certificates. Failure to provide the evidence of insurance in the time provided for will result in disqualification and the Bid will be awarded to the next lowest Bidder or in the creation of a new Bid.

40. PERSONNEL AND EQUIPMENT

The Bidder shall provide an adequate number of competently trained personnel with sufficient supervision to provide the services required, and the Bidder shall provide identification of its personnel if requested by the City.

Any Bidder's employee whose employment is reasonably detrimental or objectionable to the City shall be immediately transferred from the premises upon the City's request. The exercise of the option shall not be construed as placing the City in charge of the Work or making the City responsible for safety.

All on the road vehicles or equipment shall be identified by the Bidder's name for purpose of identification.

All tools or equipment required to carry out the operations within the scope of the contract shall be provided by the Bidder, and shall meet the standards of the Federal Occupational Safety and Health Act and State of Illinois safety codes as may be required by law. The City reserves the right to inspect the equipment that will be used prior to award of Bid.

41. TIME

Bidder shall schedule its Work and that of its subcontractors to meet the requirement of the City. Bidder shall perform the Work expeditiously in cooperation with the City's agents, employees, contractors and subcontractors. Bidder shall make no claim against City and no claim shall be allowed for any damages which may arise out of any delay caused by City, its agents, employees, contractor or subcontractors. Bidder's sole remedy for delay shall be an extension in the contract time.

42. **QUESTIONS**

Inquiries and/or questions pertaining to the provisions and specifications of this bid package shall be directed to the Director of Purchasing, in writing at <u>PurchasingDL@aurora.il.us</u>. Questions will be accepted until 5:00 pm, November 6, 2024. Questions will be answered via addendum and posted to the City's website at <u>https://www.aurora-il.org/bids.aspx</u> by 12:00 pm, November 8, 2024. NO questions will be accepted or answered verbally. **No questions will be accepted or answered after November 6, 2024 5:00 pm cut-off date/time.**

It is the responsibility of the interested bidder to assure they have received addendum, if any issued, and acknowledge such receipt where indicated.

SECTION 00 31 13 PRELIMINARY SCHEDULE

1.01 GENERAL

A. The following represents the preliminary construction schedule for the Work. This schedule is the current estimate of the Owner to be used for purposes of bidding. All bidders shall include the costs of all overtime, double-shift, or so-called "premium" time that may be necessary to meet this milestone.

1.02 PRELIMINARY SCHEDULE

- A. Award of Contract: Anticipated December 11, 2024
- B. Commencement of Construction: December 16, 2024
- C. Substantial Completion: May 30, 2025

END OF SECTION

SECTION 00 41 13 BID FORM - STIPULATED SUM

SING	LE CONTRACT				
	PROJECT:	FINANCE DEPARTMENT INTERIOR RENOVATION			
		44 E. DOWNER PLACE			
		AURORA, ILLINOIS 60507			
	BID TO:	CITY OF AURORA			
		44 E. DOWNER PLACE			
		AURORA, ILLINOIS 60507			
	BID FROM:	CORPORATE NAME:			
		ADDRESS:			
		CITY, STATE, ZIP:			
		TELEPHONE NO.:			
		EMAIL ADDRESS:			
		CONTACT PERSON:			

ACCEPTANCE

THE UNDERSIGNED BIDDER AGREES, IF THIS BID IS ACCEPTED, TO ENTER INTO AN AGREEMENT WITH THE OWNER, IN THE FORM INCLUDED IN THE BIDDING DOCUMENTS, TO PERFORM AND FURNISH THE WORK AS INDICATED IN THE BIDDING DOCUMENTS FOR THE BID PRICE AND WITHIN THE BID TIMES INDICATED IN THIS BID AND IN ACCORDANCE WITH THE TERMS AND CONDITIONS OF THE CONTRACT DOCUMENTS.

1.01 ACKNOWLEDGMENTS

IN SUBMITTING THIS BID, THE BIDDER REPRESENTS THAT:

- A. This Bid will remain open for acceptance for a period of 90 days from the Bid opening date;
- B. The Owner has the right to reject this Bid;
- C. The Bidder accepts the provisions of the Instructions and Supplementary Instructions to Bidders regarding the disposition of the Bid;
- D. The Bidder agrees to sign and submit the Agreement and other documents required by the Bidding Requirements within 5 days after the Owner's Notice of Award;
- E. The Bidder has examined the complete set of Bidding Documents;
- F. The Bidder has visited the site and become familiar with the general, local, and site conditions;

- G. The Bidder is familiar with Federal, State and Local Laws and Regulations;
- H. The Bidder has correlated the information known to the Bidder; information and observations obtained from visits to the site, reports and drawings identified in the Bidding Documents and additional examinations, investigations, explorations, tests, studies, and data with the Bidding Documents;
- I. This Bid is genuine and not made in the interest of or on behalf of an undisclosed person, firm, or corporation and is not submitted in conformity with an Agreement or rules or group, association, organization, or corporation;
- J. The Bidder has not directly or indirectly induced or solicited another Bidder to submit a false or sham Bid; sought by collusion to obtain for itself an advantage over another Bidder or over the Owner;
- K. The Bidder has received the following Addenda, receipt of which is hereby acknowledged:
 - 1. Addendum No. _____Date _____
 - 2. Addendum No. _____Date _____
 - 3. Addendum No. _____Date _____

THE BIDDER UNDERSTANDS THAT, IN SUBMITTING THIS BID, HE WAIVES ALL RIGHT TO PLEAD ANY MISUNDERSTANDINGS REGARDING THE FOREGOING.

1.02 SINGLE CONTRACT - BASE BID PRICE:

- A. Refer to Section 01 10 00 Summary.
- B. The Bidder will complete the Work of the Project in accordance with the Contract Documents for the following price:
 - 1. Stipulated Sum Bid Price:
 - 2. _____

(Use Numerals)

3. _____

(Use Words)

1.03 BID BOND

A. The Bidder has attached the required bid security in the form described by Document 00 43 13- Bid Security Form with this Bid.

1.04 ALLOWANCES

A. The Bidder has included in the Bid the appropriate allowances as specified in Section 01 21 00 - Allowances.

1.05 CONTRACT TIME

A. The Bidder agrees to begin and complete Work as indicated in Document 00 31 13 - Preliminary Schedule.

1.06 OTHER BID FORM SUPPLEMENTS

- A. The following additional Documents are attached to and made a condition of this Bid:
 - 1. Document 00 43 14 Bid Form Supplement Bidder's Certification.
 - 2. Document 00 43 15 Bid Form Supplement Bidder's Tax Certification.
 - 3. Document 00 43 16 Bid Form Supplement Apprenticeship or Training Program Certification and Current Signatory Letters.
 - 4. Document 00 43 17 Bid Form Supplement City of Aurora Local Vendor Preference Application.

1.07 SIGNATURES

- A. Respectfully submitted this _____ day of _____, 2024.
- B. Type of Firm: (check one)

_____ Individual

_____ Partnership

_____ Corporation

- _____ Joint Venture
- C. Corporate Seal:(SEAL)
- D. Full name of firm: _____
- F. Authorized Signing Officer: _____

Title: _____

SECTION 00 43 13 BID SECURITY FORM

1.01 FORM OF BID BOND

- A. AIA Document A310 (2010 Edition) Bid Bond Form.
- B. The above document may be examined at the Architect/Engineer's office or purchased at the American Institute of Architects, http://www.aia.org/docs.

SECTION 00 43 14 BID FORM SUPPLEMENT - BIDDER'S CERTIFICATION

1.01 CITY OF AURORA BIDDER'S CERTIFICATION ATTACHED (1 PAGE). END OF DOCUMENT

BIDDER'S CERTIFICATION

I/We hereby certify that:

- A. A complete set of bid papers, as intended, has been received, and that I/We will abide by the contents and/or information received and/or contained herein.
- B. I/We have not entered into any collusion or other unethical practices with any person, firm, or employee of the City which would in any way be construed as unethical business practice.
- C. I/We have adopted a written sexual harassment policy which is in accordance with the requirements of Federal, State and local laws, regulations and policies and further certify that I/We are also in compliance with all other equal employment requirements contained in Public Act 87-1257 (effective July 1, 1993) 775 ILCS 5/2-105 (A).
- D. I/We are in compliance with the most current "Prevailing Rate" of wages for laborers, mechanics and other workers as required by the State of Illinois Department of Labor.
- E I/We operate a drug free environment and drugs are not allowed in the workplace or satellite locations as well as City of Aurora sites in accordance with the Drug Free Workplace Act of January, 1992.
- F. The Bidder is not barred from bidding on the Project, or entering into this contract as a result of a violation of either Section 33E-3 or 33E-4 of the Illinois Criminal Code, or any similar offense of "bid rigging" or "bid rotating" of any state or the United States.
- G. I/We will submit, for all contracts in excess of \$25,000.00, a certificate indicating participation in apprenticeship and training programs approved and registered with the United States Department of Labor. Contractor shall check the box indicating that a copy of applicable program certification is attached.

Contractor shall check the box indicating that a copy of applicable program certification is attached.

H. I/We will abide by all other Federal, State and local codes, rules, regulations, ordinances and statutes.

COMPANY NAME	
ADDRESS	
CITY/STATE/ZIP CODE	
NAME OF CORPORATE/COMPANY OFFICIAL	PLEASE TYPE OR PRINT CLEARLY
AUTHORIZED OFFICIAL SIGNATURE	
DATE	Subscribed and Sworn to
TELEDUONE ()	Before me this day
	✓

Notary Public

SECTION 00 43 15 BID FORM SUPPLEMENT - BIDDER'S TAX CERTIFICATION

1.01 CITY OF AURORA BIDDER'S TAX CERTIFICATION ATTACHED (1 PAGE). END OF SECTION

STATE OF ILLINOIS

SS.

))

)

County of Kane

BIDDER'S TAX CERTIFICATION

(BIDDER'S EXECUTING OFFICER), being first duly sworn on oath, deposes and states that all statements made herein are made on behalf of the Bidder, that this despondent is authorized to make them and that the statements contained herein are true and correct.

Bidder deposes, states and certifies that Bidder is not barred from contracting with any unit of local government in the State of Illinois as result of a delinquency in payment of any tax administered by the Illinois Department of Revenue unless Bidder is contesting, in accordance with the procedures established by the appropriate statute, its liability for the tax or the amount of the tax, all as provided for in accordance with 65 ILCS 5/11-42.1-1.

DATED this _____ day of _____, 2024.

By _______ (Signature of Bidder's Executing Officer)

(Print name of Bidder's Executing Officer)

(Title)

ATTEST/WITNESS:

By_____

Title _____

Subscribed and sworn to before me this _____ day of _____, 2024.

Notary Public

(SEAL)

SECTION 00 43 16 BID FORM SUPPLEMENT - APPRENTICESHIP OR TRAINING PROGRAM CERTIFICATION AND CURRENT SIGNATORY LETTERS

1.01 CITY OF AURORA APPRENTICESHIP OR TRAINING PROGRAM CERTIFICATION ATTACHED (2 PAGES).

END OF SECTION
Apprenticeship or Training Program Certification

Return with Bid

All contractors are required to complete the following certification:

□ For this contract proposal or for all groups in this deliver and install proposal.

□ For the following deliver and install groups in this material proposal:

The City of Aurora policy, adopted in accordance with the provisions of the Illinois Highway Code, requires this contract to be awarded to the lowest responsive and responsible bidder. In addition to all other responsibility factors, this contract or deliver and install proposal requires all bidders and all bidders' subcontractors to disclose participation in apprenticeship or training programs that are approved by and registered with the United States Department of Labor's Bureau of Apprenticeship and Training, and applicable to the work of the above indicated proposals or groups. Therefore, all bidders are required to complete the following certification:

- I. Except as provided in paragraph IV below, the undersigned bidder certifies that it is a participant, either as an individual or as part of a group program, in an approved apprenticeship or training program applicable to each type of work or craft that the bidder will perform with its own employees.
- II. The undersigned bidder further certifies for work to be performed by subcontract that each of its subcontractors submitted for approval is, at the time of such bid, participating in an approved, applicable apprenticeship or training program applicable to the work of the subcontract.
- III. The undersigned bidder, by inclusion in the list in the space below, certifies the official name of each program sponsor holding the Certificate of Registration for all of the types of work or crafts in which the bidder is a participant and that will be performed with the bidder's employees. Types of work or craft that will be subcontracted shall be included and listed as subcontract work. The list shall also indicate any type of work or craft job category for which there is no applicable apprenticeship or training program available.

IV. Except for any work identified above, any bidder or subcontractor that shall perform all or part of the work of the contract or deliver and install proposal solely by individual owners, partners or members and not by employees to whom the payment of prevailing rates of wages would be required, check the following box, and identify the owner/operator workforce and positions of ownership. □

The requirements of this certification and disclosure are a material part of the contract, and the contractor shall require this certification provision to be included in all approved subcontracts. The bidder is responsible for making a complete report and shall make certain that each type of work or craft job category that will be utilized on the project is accounted for and listed. The City of Aurora requires a copy of each applicable Certificate of Registration issued by the United States Department of Labor evidencing such participation by the contractor and any or all of its subcontractors be included with the bid in order to qualify to bid on the project.

The Bidder must also submit a signed and current dated letter(s) from the <u>certificate holder(s)</u> indicating that the Bidder may use the certificate to meet the above listed requirements for this specific project.

Bidder:	By:
	(Signature)
Address:	Title

SECTION 00 43 17 BID FORM SUPPLEMENT - CITY OF AURORA LOCAL VENDOR PREFERENCE APPLICATION

1.01 CITY OF AURORA, IL. - LOCAL VENDOR APPLICATION ATTACHED (1 PAGE). END OF SECTION



The business identified below is requesting to be placed on the City of Aurora, Illinois Local Vendor Preference list, in accordance with ordinance O20-029 approved April 28, 2020.

1)	Date Submitted:
2)	Name of Business:
3)	Address of Local Office:
4)	City, State, Zip:
5)	Company's Web Address:
6)	Phone: Fax:
7)	County your Local Business is Located In:
	Submitted By (Signature):
	Print Name and Title:
	Email Address:

Sec. 2-410.-Prequalification; local bidder.

- (a) If an interested business would like to prequalify as a "local business", such a business shall complete and submit the prequalification application along with supporting documentation, as listed below, and the applicable fee as set by the City Council, to the Finance Department:
 - a. Evidence that the business has established and maintained a physical presence in the City of Aurora, by virtue of the ownership or lease of all or a portion of a building for a period of not less than twelve (12) consecutive months prior to the submission of the prequalification application; and
 - b. Evidence demonstrating that the business is legally authorized to conduct business within the State of Illinois and the City of Aurora, and has a business registered to operate in the City if required; and
 - c. Evidence that the business is not a debtor to the City of Aurora. For purposes of this subparagraph, a debtor is defined as having outstanding fees, water bills, sales tax or_restaurant/bar tax payments that are thirty (30) days or more past due, or has outstanding weed or nuisance abatements or liens, has failure to comply tickets or parking tickets that are not in dispute as to their validity and are not being challenged in court or other administrative processes.

Back up documentation for (a) a. and (a) b. must accompany this submittal or application will be rejected. Please note for (a) c. above the City of Aurora will verify internally that your company does not have any outstanding fees. Your company should make sure that to the best of its knowledge all bills are current.

Return completed application, with all required backup documentation to: City of Aurora, Attn: Purchasing Division, 44 E. Downer Place, Aurora, IL 60507 Or email to: <u>PurchasingDL@aurora.il.us</u>

Do not write below this line: For City of Aurora use ONLY

(;	1)	a.
~		

(a) b.

(a) c.

Date: ____

Approved: _	
Letter Sent:	

Denied:	
Initials:	

SECTION 00 52 00 AGREEMENT FORM

1.01 FORM OF AGREEMENT

- A. AIA Document A101, Owner-Contractor Agreement Form Stipulated Sum (2017 Edition), forms the basis of Contract between the Owner and Contractor.
- B. The above document may be examined at the Architect's office or purchased at the American Institute of Architects, http://www.aia.org/contractdocs/index.htm.

1.02 RELATED REQUIREMENTS

- A. Document 00 72 00- General Conditions.
- B. Document 00 73 00 Supplementary Conditions.

PART 2 PRODUCTS (NOT USED)

PART 3 EXECUTION (NOT USED)

END OF DOCUMENT

AIA Document A101° – 2017

Standard Form of Agreement Between Owner and Contractor where the basis of payment is a Stipulated Sum

AGREEMENT made as of the 11th day of December in the year 2024 (In words, indicate day, month and year.)

BETWEEN the Owner: (Name, legal status, address and other information)

City of Aurora 44 East Downer Place Aurora, Illinois 60506

and the Contractor: (Name, legal status, address and other information)

for the following Project: (Name, location and detailed description)

1552 - Finance Department Interior Renovation 44 East Downer Place Aurora, Illinois 60506

The Architect: (Name, legal status, address and other information)

Kluber, Inc. 41 W. Benton Street Aurora, Illinois 60506

The Owner and Contractor agree as follows.

ADDITIONS AND DELETIONS:

The author of this document has added information needed for its completion. The author may also have revised the text of the original AIA standard form. An Additions and Deletions Report that notes added information as well as revisions to the standard form text is available from the author and should be reviewed. A vertical line in the left margin of this document indicates where the author has added necessary information and where the author has added to or deleted from the original AIA text.

This document has important legal consequences. Consultation with an attorney is encouraged with respect to its completion or modification.

The parties should complete A101®-2017, Exhibit A, Insurance and Bonds, contemporaneously with this Agreement. AIA Document A201®-2017, General Conditions of the Contract for Construction, is adopted in this document by reference. Do not use with other general conditions unless this document is modified.

AlA Document A101 - 2017. Copyright © 1915, 1918, 1925, 1937, 1951, 1958, 1961, 1963, 1967, 1974, 1977, 1987, 1991, 1997, 2007 and 2017. All rights reserved. "The American Institute of Architects," "American Institute of Architects," "AIA," the AIA Logo, and "AIA Contract Documents" are trademarks of The 1 American Institute of Architects. This document was produced at 16:55:25 ET on 10/03/2024 under Order No.4104245145 which expires on 12/08/2024, is not for resale, is licensed for one-time use only, and may only be used in accordance with the AIA Contract Documents® Terms of Service. To report copyright violations, e-mail docinfo@aiacontracts.com. **User Notes:**

TABLE OF ARTICLES

- 1 THE CONTRACT DOCUMENTS
- 2 THE WORK OF THIS CONTRACT
- DATE OF COMMENCEMENT AND SUBSTANTIAL COMPLETION 3
- Δ CONTRACT SUM
- 5 PAYMENTS
- **DISPUTE RESOLUTION** 6
- 7 **TERMINATION OR SUSPENSION**
- **MISCELLANEOUS PROVISIONS** 8
- ENUMERATION OF CONTRACT DOCUMENTS 9

EXHIBIT A INSURANCE AND BONDS

THE CONTRACT DOCUMENTS ARTICLE 1

The Contract Documents consist of this Agreement, Conditions of the Contract (General, Supplementary, and other Conditions), Drawings, Specifications, Addenda issued prior to execution of this Agreement, other documents listed in this Agreement, and Modifications issued after execution of this Agreement, all of which form the Contract, and are as fully a part of the Contract as if attached to this Agreement or repeated herein. The Contract represents the entire and integrated agreement between the parties hereto and supersedes prior negotiations, representations, or agreements, either written or oral. An enumeration of the Contract Documents, other than a Modification, appears in Article 9.

THE WORK OF THIS CONTRACT ARTICLE 2

The Contractor shall fully execute the Work described in the Contract Documents, except as specifically indicated in the Contract Documents to be the responsibility of others.

DATE OF COMMENCEMENT AND SUBSTANTIAL COMPLETION **ARTICLE 3**

§ 3.1 The date of commencement of the Work shall be: (Check one of the following boxes.)

- [] The date of this Agreement.
- [] A date set forth in a notice to proceed issued by the Owner.
- [X] Established as follows:

(Insert a date or a means to determine the date of commencement of the Work.)

December 16, 2024

If a date of commencement of the Work is not selected, then the date of commencement shall be the date of this Agreement.

§ 3.2 The Contract Time shall be measured from the date of commencement of the Work.

§ 3.3 Substantial Completion

§ 3.3.1 Subject to adjustments of the Contract Time as provided in the Contract Documents, the Contractor shall achieve Substantial Completion of the entire Work: (Check one of the following boxes and complete the necessary information.)

Init. 1

AIA Document A101 - 2017. Copyright © 1915, 1918, 1925, 1937, 1951, 1958, 1961, 1963, 1967, 1974, 1977, 1987, 1991, 1997, 2007 and 2017. All rights reserved. "The American Institute of Architects," "American Institute of Architects," "AIA," the AIA Logo, and "AIA Contract Documents" are trademarks of The 2 American Institute of Architects. This document was produced at 16:55:25 ET on 10/03/2024 under Order No.4104245145 which expires on 12/08/2024, is not for resale, is licensed for one-time use only, and may only be used in accordance with the AIA Contract Documents® Terms of Service. To report copyright violations, e-mail docinfo@aiacontracts.com. **User Notes:**

[] Not later than () calendar days from the date of commencement of the Work.

[X] By the following date: May 30, 2025

§ 3.3.2 Subject to adjustments of the Contract Time as provided in the Contract Documents, if portions of the Work are to be completed prior to Substantial Completion of the entire Work, the Contractor shall achieve Substantial Completion of such portions by the following dates:

Portion of Work Substantial Completion Date

§ 3.3.3 If the Contractor fails to achieve Substantial Completion as provided in this Section 3.3, liquidated damages, if any, shall be assessed as set forth in Section 4.5.

ARTICLE 4 CONTRACT SUM

§ 4.1 The Owner shall pay the Contractor the Contract Sum in current funds for the Contractor's performance of the Contract. The Contract Sum shall be (\$), subject to additions and deductions as provided in the Contract Documents.

§ 4.2 Alternates

§ 4.2.1 Alternates, if any, included in the Contract Sum:

Item

Price

§ 4.2.2 Subject to the conditions noted below, the following alternates may be accepted by the Owner following execution of this Agreement. Upon acceptance, the Owner shall issue a Modification to this Agreement. (Insert below each alternate and the conditions that must be met for the Owner to accept the alternate.)

Item Price **Conditions for Acceptance** § 4.3 Allowances, if any, included in the Contract Sum: (Identify each allowance.) Item Price Section 01 21 00 - Contingency \$30,000.00 § 4.4 Unit prices, if any: (Identify the item and state the unit price and quantity limitations, if any, to which the unit price will be applicable.) **Units and Limitations** Price per Unit (\$0.00) Item N/A

§ 4.5 Liquidated damages, if any: (Insert terms and conditions for liquidated damages, if any.)

None

§ 4.6 Other:

(Insert provisions for bonus or other incentives, if any, that might result in a change to the Contract Sum.)

Init. 1

AIA Document A101 - 2017. Copyright © 1915, 1918, 1925, 1937, 1951, 1958, 1961, 1963, 1967, 1974, 1977, 1987, 1991, 1997, 2007 and 2017. All rights reserved. "The American Institute of Architects," "American Institute of Architects," "AIA," the AIA Logo, and "AIA Contract Documents" are trademarks of The 3 American Institute of Architects. This document was produced at 16:55:25 ET on 10/03/2024 under Order No.4104245145 which expires on 12/08/2024, is not for resale, is licensed for one-time use only, and may only be used in accordance with the AIA Contract Documents® Terms of Service. To report copyright violations, e-mail docinfo@aiacontracts.com. **User Notes:**

ARTICLE 5 PAYMENTS

§ 5.1 Progress Payments

§ 5.1.1 Based upon Applications for Payment submitted to the Architect by the Contractor and Certificates for Payment issued by the Architect, the Owner shall make progress payments on account of the Contract Sum to the Contractor as provided below and elsewhere in the Contract Documents.

§ 5.1.2 The period covered by each Application for Payment shall be one calendar month ending on the last day of the month, or as follows:

See attached 2025 Payment Deadline Schedule - Exhibit F

§ 5.1.3 Provided that an Application for Payment is received by the Architect not later than two weeks prior to payment deadline, the Owner shall make payment of the amount certified to the Contractor not later than the 30th day of the following month. If an Application for Payment is received by the Architect after the application date fixed above, payment of the amount certified shall be made by the Owner not later than the next day listed on the attached schedule. The provisions of the Illinois Local Government Prompt Payment Act, 50ILCS 505/1 shall apply to this contract. Contractor shall submit certified payroll and partial/final waivers of lien with every payment request. (Federal, state or local laws may require payment within a certain period of time.)

§ 5.1.4 Each Application for Payment shall be based on the most recent schedule of values submitted by the Contractor in accordance with the Contract Documents. The schedule of values shall allocate the entire Contract Sum among the various portions of the Work. The schedule of values shall be prepared in such form, and supported by such data to substantiate its accuracy, as the Architect may require. This schedule of values shall be used as a basis for reviewing the Contractor's Applications for Payment.

§ 5.1.5 Applications for Payment shall show the percentage of completion of each portion of the Work as of the end of the period covered by the Application for Payment.

§ 5.1.6 In accordance with AIA Document A201TM–2017, General Conditions of the Contract for Construction, and subject to other provisions of the Contract Documents, the amount of each progress payment shall be computed as follows:

- § 5.1.6.1 The amount of each progress payment shall first include:
 - That portion of the Contract Sum properly allocable to completed Work; .1
 - .2 That portion of the Contract Sum properly allocable to materials and equipment delivered and suitably stored at the site for subsequent incorporation in the completed construction, or, if approved in advance by the Owner, suitably stored off the site at a location agreed upon in writing; and
 - .3 That portion of Construction Change Directives that the Architect determines, in the Architect's professional judgment, to be reasonably justified.

§ 5.1.6.2 The amount of each progress payment shall then be reduced by:

- The aggregate of any amounts previously paid by the Owner; .1
- .2 The amount, if any, for Work that remains uncorrected and for which the Architect has previously withheld a Certificate for Payment as provided in Article 9 of AIA Document A201–2017;
- .3 Any amount for which the Contractor does not intend to pay a Subcontractor or material supplier, unless the Work has been performed by others the Contractor intends to pay;
- .4 For Work performed or defects discovered since the last payment application, any amount for which the Architect may withhold payment, or nullify a Certificate of Payment in whole or in part, as provided in Article 9 of AIA Document A201-2017; and
- .5 Retainage withheld pursuant to Section 5.1.7.

§ 5.1.7 Retainage

§ 5.1.7.1 For each progress payment made prior to Substantial Completion of the Work, the Owner may withhold the following amount, as retainage, from the payment otherwise due:

(Insert a percentage or amount to be withheld as retainage from each Application for Payment. The amount of retainage may be limited by governing law.)

Init. 1

AIA Document A101 - 2017. Copyright © 1915, 1918, 1925, 1937, 1951, 1958, 1961, 1963, 1967, 1974, 1977, 1987, 1991, 1997, 2007 and 2017. All rights reserved. "The American Institute of Architects," "American Institute of Architects," "AIA," the AIA Logo, and "AIA Contract Documents" are trademarks of The American Institute of Architects. This document was produced at 16:55:25 ET on 10/03/2024 under Order No.4104245145 which expires on 12/08/2024, is not for resale, is licensed for one-time use only, and may only be used in accordance with the AIA Contract Documents® Terms of Service. To report copyright violations, e-mail docinfo@aiacontracts.com. User Notes:

Ten Percent (10%)

§ 5.1.7.1.1 The following items are not subject to retainage: (Insert any items not subject to the withholding of retainage, such as general conditions, insurance, etc.)

Bonds and Insurance.

§ 5.1.7.2 Reduction or limitation of retainage, if any, shall be as follows:

(If the retainage established in Section 5.1.7.1 is to be modified prior to Substantial Completion of the entire Work, including modifications for Substantial Completion of portions of the Work as provided in Section 3.3.2, insert provisions for such modifications.)

§ 5.1.7.3 Except as set forth in this Section 5.1.7.3, upon Substantial Completion of the Work, the Contractor may submit an Application for Payment that includes the retainage withheld from prior Applications for Payment pursuant to this Section 5.1.7. The Application for Payment submitted at Substantial Completion shall not include retainage as follows:

(Insert any other conditions for release of retainage upon Substantial Completion.)

§ 5.1.8 If final completion of the Work is materially delayed through no fault of the Contractor, the Owner shall pay the Contractor any additional amounts in accordance with Article 9 of AIA Document A201–2017.

§ 5.1.9 Except with the Owner's prior approval, the Contractor shall not make advance payments to suppliers for materials or equipment which have not been delivered and stored at the site.

§ 5.2 Final Payment

§ 5.2.1 Final payment, constituting the entire unpaid balance of the Contract Sum, shall be made by the Owner to the Contractor when

- .1 the Contractor has fully performed the Contract except for the Contractor's responsibility to correct Work as provided in Article 12 of AIA Document A201–2017, and to satisfy other requirements, if any, which extend beyond final payment; and
- .2 a final Certificate for Payment has been issued by the Architect.

§ 5.2.2 The Owner's final payment to the Contractor shall be made no later than 30 days after the issuance of the Architect's final Certificate for Payment, or as follows:

(Paragraphs deleted) ARTICLE 6 DISPUTE RESOLUTION § 6.1 Initial Decision Maker

The Architect will serve as the Initial Decision Maker pursuant to Article 15 of AIA Document A201–2017, unless the parties appoint below another individual, not a party to this Agreement, to serve as the Initial Decision Maker. (If the parties mutually agree, insert the name, address and other contact information of the Initial Decision Maker, if other than the Architect.)

AlA Document A101 - 2017. Copyright © 1915, 1918, 1925, 1937, 1951, 1958, 1961, 1963, 1967, 1974, 1977, 1987, 1991, 1997, 2007 and 2017. All rights reserved. "The American Institute of Architects," "American Institute of Architects," "AIA," the AIA Logo, and "AIA Contract Documents" are trademarks of The American Institute of Architects. This document was produced at 16:55:25 ET on 10/03/2024 under Order No.4104245145 which expires on 12/08/2024, is not for 5 resale, is licensed for one-time use only, and may only be used in accordance with the AIA Contract Documents® Terms of Service. To report copyright violations, e-mail docinfo@aiacontracts.com **User Notes:**

§ 6.2 Binding Dispute Resolution

For any Claim subject to, but not resolved by, mediation pursuant to Article 15 of AIA Document A201-2017, the method of binding dispute resolution shall be as follows: (Check the appropriate box.)

- Arbitration pursuant to Section 15.4 of AIA Document A201-2017 []
- [X] Litigation in a court of competent jurisdiction
- [] Other (Specify)

If the Owner and Contractor do not select a method of binding dispute resolution, or do not subsequently agree in writing to a binding dispute resolution method other than litigation, Claims will be resolved by litigation in a court of competent jurisdiction.

TERMINATION OR SUSPENSION ARTICLE 7

§ 7.1 The Contract may be terminated by the Owner or the Contractor as provided in Article 14 of AIA Document A201-2017.

§ 7.1.1 If the Contract is terminated for the Owner's convenience in accordance with Article 14 of AIA Document A201–2017, then the Owner shall pay the Contractor a termination fee as follows: (Insert the amount of, or method for determining, the fee, if any, payable to the Contractor following a termination for the Owner's convenience.)

§ 7.2 The Work may be suspended by the Owner as provided in Article 14 of AIA Document A201–2017.

ARTICLE 8 MISCELLANEOUS PROVISIONS

§ 8.1 Where reference is made in this Agreement to a provision of AIA Document A201–2017 or another Contract Document, the reference refers to that provision as amended or supplemented by other provisions of the Contract Documents.

§ 8.2 The Owner's representative: (Name, address, email address, and other information)

Jim Birchall City of Aurora 44 East Downer Place Aurora, Illinois 60506

§ 8.3 The Contractor's representative: (Name, address, email address, and other information)

§ 8.4 Neither the Owner's nor the Contractor's representative shall be changed without ten days' prior notice to the other party.

6

AIA Document A101 – 2017. Copyright © 1915, 1918, 1925, 1937, 1951, 1958, 1961, 1963, 1967, 1974, 1977, 1987, 1991, 1997, 2007 and 2017. All rights reserved. "The American Institute of Architects," "American Institute of Architects," "AIA," the AIA Logo, and "AIA Contract Documents" are trademarks of The Init. American Institute of Architects. This document was produced at 16:55:25 ET on 10/03/2024 under Order No.4104245145 which expires on 12/08/2024, is not for resale, is licensed for one-time use only, and may only be used in accordance with the AIA Contract Documents® Terms of Service. To report copyright violations, e-mail docinfo@aiacontracts.com. User Notes:

§ 8.5 Insurance and Bonds

§ 8.5.1 The Owner and the Contractor shall purchase and maintain insurance as set forth in AIA Document A101[™]–2017, Standard Form of Agreement Between Owner and Contractor where the basis of payment is a Stipulated Sum, Exhibit A, Insurance and Bonds, and elsewhere in the Contract Documents.

§ 8.5.2 The Contractor shall provide bonds as set forth in AIA Document A101TM-2017 Exhibit A, and elsewhere in the Contract Documents.

(Paragraphs deleted) § 8.7 Other provisions:

ARTICLE 9 ENUMERATION OF CONTRACT DOCUMENTS

§ 9.1 This Agreement is comprised of the following documents:

- AIA Document A101TM–2017, Standard Form of Agreement Between Owner and Contractor .1
- .2 , Exhibit A, Insurance and Bonds
- .3 AIA Document A201TM–2017, General Conditions of the Contract for Construction (Insert the date of the E203-2013 incorporated into this Agreement.)

N/A

.5 Drawings

Number	Title	Date
00 01 15	Drawing Index Exhibit D	October 24, 2024

.6 Specifications

Section	Title	Date	Pages
00 10 00	Table of Contents Exhibit C	October 24, 2024	

.7 Addenda, if any:

Number	Date	Pages
00 91 01 – Addendum Number 1 –	TBD	TBD
Exhibit E		

Portions of Addenda relating to bidding or proposal requirements are not part of the Contract Documents unless the bidding or proposal requirements are also enumerated in this Article 9.

.8 Other Exhibits:

> (Check all boxes that apply and include appropriate information identifying the exhibit where required.)

[] AIA Document E204TM_2017, Sustainable Projects Exhibit, dated as indicated below: (Insert the date of the E204-2017 incorporated into this Agreement.)

[] The Sustainability Plan:

Init.

AIA Document A101 - 2017. Copyright © 1915, 1918, 1925, 1937, 1951, 1958, 1961, 1963, 1967, 1974, 1977, 1987, 1991, 1997, 2007 and 2017. All rights reserved. "The American Institute of Architects," "AIA," the AIA Logo, and "AIA Contract Documents" are trademarks of The American Institute of Architects," "AIA," the AIA Logo, and "AIA Contract Documents" are trademarks of The American Institute of Architects. This document was produced at 16:55:25 ET on 10/03/2024 under Order No.4104245145 which expires on 12/08/2024, is not for 7 resale, is licensed for one-time use only, and may only be used in accordance with the AIA Contract Documents® Terms of Service. To report copyright violations, e-mail docinfo@aiacontracts.com. **User Notes:**

Title	Date	Pages

Supplementary and other Conditions of the Contract: (Exhibit G) [X]

Document	Title	Date	Pages
00 73 00	Supplementary	October 24,	15
	Conditions	2024	

.9 Other documents, if any, listed below:

(List here any additional documents that are intended to form part of the Contract Documents. AIA Document A201TM–2017 provides that the advertisement or invitation to bid, Instructions to Bidders, sample forms, the Contractor's bid or proposal, portions of Addenda relating to bidding or proposal requirements, and other information furnished by the Owner in anticipation of receiving bids or proposals, are not part of the Contract Documents unless enumerated in this Agreement. Any such documents should be listed here only if intended to be part of the Contract Documents.)

00 11 13	Advertisement for Bids
00 21 13	Instructions to Bidders
00 31 13	Preliminary Schedule
00 41 13	Bid Form – Stipulated Sum submitted by, Exhibit B
00 43 13	Bid Security Form, Exhibit B
00 43 14	Bid Form – Bidder's Certification submitted by, Exhibit B
00 43 15	Bid Form – Bidder's Tax Certification submitted by, Exhibit B
00 43 16	Bid Form – Apprenticeship or Training Program Cert. and Current Signatory
	Letters submitted by, Exhibit B

This Agreement entered into as of the day and year first written above.

OWNER (Signature)

CONTRACTOR (Signature)

Jolene Coulter, Director of Purchasing (Printed name and title)

(Printed name and title)

AIA Document A101 - 2017. Copyright © 1915, 1918, 1925, 1937, 1951, 1958, 1961, 1963, 1967, 1974, 1977, 1987, 1991, 1997, 2007 and 2017. All rights reserved. "The American Institute of Architects," "American Institute of Architects," "AIA," the AIA Logo, and "AIA Contract Documents" are trademarks of The American Institute of Architects. This document was produced at 16:55:25 ET on 10/03/2024 under Order No.4104245145 which expires on 12/08/2024, is not for resale, is licensed for one-time use only, and may only be used in accordance with the AIA Contract Documents® Terms of Service. To report copyright violations, e-mail docinfo@aiacontracts.com. **User Notes:**

8

Additions and Deletions Report for

AIA[®] Document A101[®] – 2017

This Additions and Deletions Report, as defined on page 1 of the associated document, reproduces below all text the author has added to the standard form AIA document in order to complete it, as well as any text the author may have added to or deleted from the original AIA text. Added text is shown underlined. Deleted text is indicated with a horizontal line through the original AIA text.

Note: This Additions and Deletions Report is provided for information purposes only and is not incorporated into or constitute any part of the associated AIA document. This Additions and Deletions Report and its associated document were generated simultaneously by AIA software at 16:55:25 ET on 10/03/2024.

PAGE 1

AGREEMENT made as of the <u>11th</u> day of <u>December</u> in the year <u>2024</u>

...

City of Aurora 44 East Downer Place Aurora, Illinois 60506

...

1552 - Finance Department Interior Renovation 44 East Downer Place Aurora, Illinois 60506

...

Kluber, Inc. 41 W. Benton Street Aurora, Illinois 60506 PAGE 2

> [X] Established as follows:

...

December 16, 2024

PAGE 3

[X] By the following date: May 30, 2025

...

...

...

Section 01 21 00 - Contingency

\$30,000.00

N/A

None PAGE 4

Additions and Deletions Report for AIA Document A101 – 2017. Copyright © 1915, 1918, 1925, 1937, 1951, 1958, 1961, 1963, 1967, 1974, 1977, 1987, 1991, 1997, 2007 and 2017. All rights reserved. "The American Institute of Architects," "American Institute of Architects," "AIA," the AIA Logo, and "AIA Contract Documents" are 1 trademarks of The American Institute of Architects. This document was produced at 16:55:25 ET on 10/03/2024 under Order No.4104245145 which expires on 12/08/2024, is not for resale, is licensed for one-time use only, and may only be used in accordance with the AIA Contract Documents® Terms of Service. To report copyright violations, e-mail docinfo@aiacontracts.com. **User Notes:**

(1634692469)

See attached 2025 Payment Deadline Schedule - Exhibit F

§ 5.1.3 Provided that an Application for Payment is received by the Architect not later than the day of a month, the two weeks prior to payment deadline, the Owner shall make payment of the amount certified to the Contractor not later than the <u>30th</u> day of the <u>following</u> month. If an Application for Payment is received by the Architect after the application date fixed above, payment of the amount certified shall be made by the Owner not later than () days after the Architect receives the Application for Payment. the next day listed on the attached schedule. The provisions of the Illinois Local Government Prompt Payment Act, 50ILCS 505/1 shall apply to this contract. Contractor shall submit certified payroll and partial/final waivers of lien with every payment request. PAGE 5

Ten Percent (10%)

...

Bonds and Insurance.

...

§ 5.3 Interest

Payments due and unpaid under the Contract shall bear interest from the date payment is due at the rate stated below, or in the absence thereof, at the legal rate prevailing from time to time at the place where the Project is located. (Insert rate of interest agreed upon, if any.)

-%

PAGE 6

[X] Litigation in a court of competent jurisdiction

...

Jim Birchall City of Aurora 44 East Downer Place Aurora, Illinois 60506 PAGE 7

§ 8.6 Notice in electronic format, pursuant to Article 1 of AIA Document A201 2017, may be given in accordance with a building information modeling exhibit, if completed, or as otherwise set forth below: (If other than in accordance with a building information modeling exhibit, insert requirements for delivering notice in electronic format such as name, title, and email address of the recipient and whether and how the system will be required to generate a read receipt for the transmission.)

...

- AIA Document A101[™] 2017, Exhibit A, Insurance and Bonds .2
- AIA Document A201TM–2017, General Conditions of the Contract for Construction .3
- Building information modeling exhibit, dated as indicated below:

(Insert the date of the building information modeling exhibit E203-2013 incorporated into this Agreement.)

2

Additions and Deletions Report for AIA Document A101 - 2017. Copyright @ 1915, 1918, 1925, 1937, 1951, 1958, 1961, 1963, 1967, 1974, 1977, 1987, 1991, 1997, 2007 and 2017. All rights reserved. "The American Institute of Architects," "American Institute of Architects," "AIA," the AIA Logo, and "AIA Contract Documents" are trademarks of The American Institute of Architects. This document was produced at 16:55:25 ET on 10/03/2024 under Order No.4104245145 which expires on 12/08/2024, is not for resale, is licensed for one-time use only, and may only be used in accordance with the AIA Contract Documents® Terms of Service. To report copyright violations, e-mail docinfo@aiacontracts.com. User Notes:

	<u>N/A</u>		
	<u>00 01 15</u>	Drawing Index Exhibit D	<u>October 24, 2024</u>
	00 10 00	<u>Table of Contents Exhibit</u> <u>C</u>	<u>October 24,</u> 2024
 PAGE 8	<u>00 91 01 – Addendum Number 1 –</u> <u>Exhibit E</u>	TBD	TBD
	[X] Supplementary and other Co	onditions of the Contract: (Ex	<u>hibit G)</u>

<u>00 73 00</u>	<u>Supplementary</u>	October 24,	15
	Conditions	2024	

...

...

<u>00 11 13</u>	Advertisement for Bids
<u>00 21 13</u>	Instructions to Bidders
<u>00 31 13</u>	Preliminary Schedule
<u>00 41 13</u>	Bid Form – Stipulated Sum submitted by , Exhibit B
<u>00 43 13</u>	Bid Security Form, Exhibit B
<u>00 43 14</u>	Bid Form – Bidder's Certification submitted by, Exhibit B
<u>00 43 15</u>	Bid Form – Bidder's Tax Certification submitted by, Exhibit B
00 43 16	Bid Form – Apprenticeship or Training Program Cert. and Current Signatory
	Letters submitted by, Exhibit B

...

Jolene Coulter, Director of Purchasing

Additions and Deletions Report for AIA Document A101 – 2017. Copyright © 1915, 1918, 1925, 1937, 1951, 1958, 1961, 1963, 1967, 1974, 1977, 1987, 1991, 1997, 2007 and 2017. All rights reserved. "The American Institute of Architects," "American Institute of Architects," "AIA," the AIA Logo, and "AIA Contract Documents" are trademarks of The American Institute of Architects. This document was produced at 16:55:25 ET on 10/03/2024 under Order No.4104245145 which expires on 12/08/2024, is not for resale, is licensed for one-time use only, and may only be used in accordance with the AIA Contract Documents® Terms of Service. To report converted wideltions, a mail document for a converted wideltions. 3 copyright violations, e-mail docinfo@aiacontracts.com. User Notes:

SECTION 00 60 00 PROJECT FORMS

1.01 FORMS OF BONDS AND CERTIFICATES

- A. Performance and Payment Bonds: AIA Document A312 Performance Bond and Payment Bond.
- B. Consents of Surety:
 - 1. AIA Document G707A Consent of Surety to Final Reduction in or Partial Release of Retainage.
 - 2. AIA Document G707 Consent of Surety to Final Payment.
- C. The above documents may be examined at the Architect's office or purchased at the American Institute of Architects.

END OF DOCUMENT

SECTION 00 72 00 GENERAL CONDITIONS

1.01 FORM OF GENERAL CONDITIONS

- A. The General Conditions applicable to this contract is attached following this page.
- B. AIA Document A201 2017 "General Conditions of the Contract for Construction" is the General Conditions between the Owner and Contractor.
- C. The above document may be examined at the Architect's office or purchased at the American Institute of Architects.

1.02 RELATED REQUIREMENTS

A. SECTION 00 73 00 - Supplementary Conditions.

1.03 SUPPLEMENTARY CONDITIONS

A. Refer to Document 00 73 00 for amendments to these General Conditions.

END OF DOCUMENT

SECTION 00 73 00 SUPPLEMENTARY CONDITIONS

1.01 GENERAL

1.02 ARTICLE 1 GENERAL PROVISIONS

A. § 1.1 Basic Definitions

1. **1.1.1** The Contract Documents

- a. After the text "other documents listed in the Agreement, ", insert the text "Advertisement for Bids, Instructions to Bidders, Supplementary Instructions to Bidders, the Contractor's Bid, including all supplementary forms and certifications included with the Contractor's Bid, ".
- b. Delete the last sentence.

B. § 1.2 Correlation and Intent of the Contract Documents

- 1. At the end of the last sentence of Section 1.2.1, replace the words "indicated results." with the following: "intended results. In the event the Contract Documents conflict, the Contractor shall comply with the more stringent of the requirements."
- Add new Section 1.2.2.1 as follows:
 "§ 1.2.2.1 Sections of Division 1 General Requirements govern the execution of the Work of all Sections of the specifications."

C. § 1.5 Ownership and Use of Drawings, Specifications and Other Instruments of Service

1. After the first sentence of Section 1.5.1, insert the following:

"These Instruments of Service are the tangible rendering of professional opinions and service for the Owner and are not, therefore, a commodity, product or good. No warranties, express or implied, are made by the Architect to the Contractor concerning those Instruments of Service."

1.03 ARTICLE 2 OWNER

A. § 2.1 General

1. Add new Section 2.1.3 as follows:

"§ 2.1.3 The Owner's rights under this Article 2 for Contractor's deficiencies in the Work are not the Owner's sole remedies, but are cumulative and may be exercised along with any other rights of the Owner as permitted by law."

B. § 2.2 Evidence of the Owner's Financial Arrangements

1. Delete the second and third sentences of Section 2.2.1.

C. § 2.3 Information and Services Required of the Owner

- Delete the last sentence of Section 2.3.4 and replace with the following:
 "The furnishing of survey(s) by the Owner is not a guarantee of the accuracy of the information contained therein and shall not relieve the Contractor of its duties under the Contract Documents in general. The submission of a bid for the Work implies that the Contractor has examined the site, taking into consideration all such conditions that may affect the Work, regardless of the information contained in the survey(s)."
- 2. Delete Section 2.3.6 in its entirety and replace with the following:

"§ 2.3.6 The Owner shall furnish to the Contractor one (1) PDF copy of the Contract Documents for the purposes of making reproductions pursuant to Section 1.5.2."

3. Add new Section 2.3.7 as follows:

"§ 2.3.7 Any information furnished by the Owner shall not constitute a representation by the Owner or Architect concerning site conditions."

D. § 2.5 Owner's Right to Carry Out the Work

1. Delete the text of Section 2.5 in its entirety and replace with the following:

"If the Contractor defaults or neglects to carry out or is otherwise deficient in carrying out the Work in accordance with the Contract Documents and fails within a seven-day period after receipt of notice from the Owner to commence and/or continue correction of such default, neglect or other deficiency with diligence and promptness, the Owner may, without prejudice to other remedies the Owner may have, correct such default or neglect. Such action by the Owner and amounts charged to the Contractor, including Owner's expenses and compensation for the Architect's additional services made necessary by such default, neglect or other failure, are subject to prior evaluation by the Architect, and the Architect may, pursuant to Section 9.5.1, withhold or nullify a Certificate for Payment in whole or in part, to the extent reasonably necessary to reimburse the Owner for the actual cost of correcting such deficiencies. If current and future payments are not sufficient to cover such amounts, the Contractor shall pay the difference to the Owner. If the Contractor disagrees with the actions of the Owner or the Architect, the Contractor may file a Claim pursuant to Article 15."

1.04 ARTICLE 3 CONTRACTOR

A. § 3.2 Review of Contract Documents and Field Conditions by Contractor

1. Delete Section 3.2.1 in its entirety and replace with the following:

"§ 3.2.1 Execution of the Contract by the Contractor is a representation by the Contractor that, prior to the submission of its bid, the Contractor has (1) thoroughly examined the Contract Documents and determined them to be full, complete and sufficient to enable the Contractor to construct the Work outlined therein, in accordance with applicable laws and regulations, for an amount not in excess of the Contract Sum on or before the date(s) of Substantial Completion established in the Agreement; (2) visited and examined the Project site and is familiar with all of the conditions thereon; (3) examined the nature, location and character of the general area in which the Project is located, including, without limitation, its climactic conditions, available labor supply, labor costs and available equipment supply and costs; and (4) examined the quality and quantity of materials, supplies, tools, equipment, labor and professional services necessary to complete the Work in the manner and within the cost and time frame required by the Contract Documents."

- 2. Delete Section 3.2.3.
- 3. Add new Section 3.2.5 as follows:

"§ 3.2.5 Prior to any excavation, the Contractor shall determine the locations of all existing water, gas, sewer, electric, telephone, telegraph, television, irrigation, petroleum pipelines, and other underground utilities and structures. Where the locations of existing underground and surface utilities and structures are indicated, these locations are generally approximate, and all items that may be encountered during the work are not necessarily indicated. The Contractor shall determine the exact locations of all items indicated, and the existence and locations of all items not indicated."

B. § 3.3 Supervision and Construction Procedures

1. Add new Sections 3.3.4 through 3.3.7 as follows:

"§ 3.3.4 The Contractor has the responsibility to ensure that all material suppliers and Subcontractors, their agents, and employees adhere to the Contract Documents, and that they order materials on time, taking into account the current market and delivery conditions and that they provide materials on time. The Contractor shall coordinate its Work, including without limitation, deliveries, storage, installations, and construction utilities with that of all others on the Project. The Contractor shall be responsible for the space requirements, locations, and routing of its equipment. In areas and locations where the proper and most effective space requirements, locations and routing cannot be made as indicated, the Contractor shall meet with all others involved, before installation, to plan the most effective method of overall installation.

§ 3.3.5 All manufactured articles, material and equipment shall be applied, installed, connected, erected, used, cleaned, and conditioned as directed by the manufacturer, unless herein specified to the contrary.

§ 3.3.6 After commencing the work, the Contractor shall use every precaution to avoid interferences with existing underground and surface utilities and structures, and protect them from damage. The Contractor shall repair or pay for all damage caused by his operations to all existing utility lines, public property, and private property, whether it is below ground or above ground, and he shall settle in total cost of all damage suits which may arise as a result of his operations at no additional costs to the Owner. To avoid unnecessary interferences or delays, the Contractor shall coordinate all utility removals, replacements and construction with the appropriate utility company. The cost of temporarily relocating utilities for convenience of the Contractor, shall be paid by Contractor.

§ 3.3.7 The Contractor shall establish and maintain benchmarks and all other grades, lines, and levels necessary for the Work, report errors or inconsistencies to the Owner and Architect before commencing Work, and review the placement of the building and permanent facilities on the site with the Owner and Architect after all lines are staked out and before foundation Work is started."

C. § 3.4 Labor and Materials

1. Delete Section 3.4.2 in its entirety and replace with the following:

"§ 3.4.2 After the Contract has been executed, the Owner and the Architect will consider a formal request for the substitution of products in place of those specified only under the conditions set forth in Section 01 60 00 - Product Requirements."

2. Add new Sections 3.4.4, 3.4.5 and 3.4.6 as follows:

"§ 3.4.4 The Contractor shall maintain harmonious labor relations on the job site. If a labor problem arises or any person(s) employed by the Contractor on the Work appear to the Owner to be Incompetent or conduct himself in a disorderly or improper manner, such person(s) shall be removed from the Work immediately on the request of the Owner. Said removal shall not create any additional cost to Owner and shall not extend the time for completion of the Work.

§ 3.4.5 To the extent that the Prevailing Wage Act applies, the Contractor shall comply therewith and pay, and require every Subcontractor to pay, the prevailing rates of wages as established by the Illinois Department of Labor for each craft or type of work needed to execute the contract in accordance with 820 ILCS 130/.01 et seq. The Contractor shall prominently post the current schedule of prevailing wages at the Contract site and shall notify immediately in writing all of its Subcontractors, of all changes in the schedule of prevailing wages. Any increases in costs to Contractor due to changes in the prevailing rate

of wage during the terms of any contract shall be at the expense of Contractor and not at the expense of the Owner. Change orders shall, however, be computed using the prevailing wage rates applicable at the time the change order work is scheduled to be performed. The Contractor shall be solely responsible to maintain accurate records as required by the prevailing wage statute and to obtain and furnish all such certified records to Owner as required by Statute including certified payroll or, in lieu thereof, a certified letter stating that the Contractor is exempt from the application of the Act. Contractor shall be solely liable for paying the difference between prevailing wages and any wages actually received by laborers, workmen and/or mechanics engaged in the Work and in every way defend and indemnify Owner against any claims arising under or related to the payment of wages in accordance with the Prevailing Wage Act. The Owner agrees to notify the Contractor or Subcontractor of the pendency of any such claim, demand, lien or suit. § 3.4.6 In the event of a labor dispute resulting in a slow-down or in the cessation or suspension of work, the Contractor shall not be relieved of its obligations to provide labor or for timely progress and completion of the work. In such event, the notice provisions contained in Section 2.4 shall not apply. Instead, the Contractor shall be automatically deemed to be in default and to have committed a breach of contract unless said work stoppage or slow-down is remedied to the Owner's satisfaction in accordance with this Section. In the event of a work stoppage due to a labor dispute, the Contractor shall provide replacement labor within 24 hours of the commencement of the work stoppage. In the event of a slow-down of work due to a labor dispute, the Contractor shall provide as much supplemental labor as may be necessary to resume normal and customary progress and deadlines on the project in accordance with the time schedules established for the work. In the alternative, the Owner shall have the option to replace or supplement labor, and shall be entitled to reduce the contract sum by an amount equal to the Owner's cost of replacing or supplementing labor. If the balance of the contract sum is not sufficient to cover such amounts, the contractor shall pay the difference to the Owner. The Owner may also pursue any other remedies it may have, including, but not limited to, remedies under the performance bond and payment bond. If any labor dispute necessitates legal action or legal intervention by the Owner, or in the event that the Owner otherwise takes legal action to enforce the terms of this section, the Contractor shall be responsible for the Owner's attorney's fees and court costs, without prejudice to any other remedies that the Owner may have."

D. § 3.6 Taxes

 Delete the text of Section 3.6 in its entirety and replace with the following: "The Owner is exempt from the Illinois Use Tax Act and the Retailer's Occupation Tax. Any taxes for which the Owner is not exempt shall be paid by the Contractor."

E. § 3.7 Permits, Fees, Notices and Compliance with Laws

- 1. Delete Section 3.7.3 in its entirety and replace with the following:
 - "§ 3.7.3 If the Contractor performs Work contrary to applicable laws, statutes, ordinances, codes, rules and regulations, or lawful orders of public authorities, the Contractor shall assume appropriate responsibility for such Work and shall bear the costs attributable to correction."
- 2. In the first sentence of Section 3.7.4, delete "14 days" and replace with "7 days". At the end of Section 3.7.4 append the following: "The Contractor accepts these procedures and therefore voluntarily waives any and all other rights it may have by operation of statute including but not

limited to any statutory right to stop the work pending resolution of any claim for additional time or additional compensation or equitable adjustments for allegedly changed conditions that Contractor may otherwise enjoy by operation of the Illinois Public Construction Contract Act.

F. § 3.9 Superintendent

- 1. After the last sentence in Section 3.9.1, add the following:
 - "The Superintendent shall have knowledge of, and control over, the entirety of the Work, and upon request of the Owner or Architect, the Superintendent shall communicate directly to the Owner."

G. § 3.10 Contractor's Construction and Submittal Schedules

1. Delete Section 3.10.1 in its entirety and replace with the following:

\$ 3.10.1 The Contractor, promptly after being awarded the Contract, shall prepare and submit for the Owner's and Architect's information a Contractor's construction schedule for the Work. The schedule shall indicate the proposed completion dates for the various subdivisions of the Work, as well as the totality of the Work. The schedule shall be updated every thirty (30) days and submitted to the Architect with Contractor's Application for Payment. Each schedule shall contain a comparison of actual progress with the estimated progress for such point in time stated in the original schedule. If any schedule submitted sets forth a date for Completion for the Work or any phase of the Work beyond the date(s) of Completion established in the Contract (as the same may be extended as provided in the Contract Documents), then Contractor shall submit to Architect and Owner for their review and approval a narrative description of the means and methods which Contractor intends to employ to expedite the progress of the Work to ensure timely completion of the various phases of the Work as well as the totality of the Work. To ensure such timely completion, Contractor shall take all necessary action including, without limitation, increasing the number of personnel and labor on the Project and implementing overtime and double shifts. In that event, Contractor shall not be entitled to an adjustment in the Contract Sum or the schedule. The Owner may, at its discretion, choose to withhold any payment due the Contractor until an updated schedule is submitted. The Owner's or Architect's failure to object to a submitted schedule that exceeds the time limits current under the Contract Documents shall not relieve the Contractor of its obligations to meet the time limits in the Contract Documents, nor shall it make the Owner or Architect liable for any of the Contractor's damages incurred as a result of increased construction time or not meeting the time limits in the Contract Documents. Similarly, the Owner's or Architect's failure to object to a Contractor's schedule showing completion in advance of the time limits in the Contract Documents shall not create or infer any rights in favor of the Contractor for acceleration of the Work.

H. § 3.18 Indemnification

1. Delete Section 3.18.1 and replace with the following:

"§ 3.18.1 To the fullest extent permitted by law, the Contractor shall waive any right of contribution against the Owner and shall indemnify and hold harmless the Owner and the Architect and their officers, officials, employees, volunteers and agents from and against all claims, damages losses and expenses, including, but not limited to, legal fees (attorney's and paralegal's fees, expert fees and court costs), arising out of or resulting from the performance of the Contractor's work provided that any such claim, damage, loss or expense is attributable to bodily injury, sickness, disease or death, or injury to or destruction of property, other than the work itself, including the loss of use resulting therefrom to the

extent it is caused in whole or in part by any wrongful or negligent act or omission of the Contractor, any Subcontractor, anyone directly or indirectly employed by any of them or anyone for whose acts any of them may be liable. Such obligation shall not be construed to negate, abridge or otherwise reduce any other right to indemnity which the Owner would otherwise have. The Contractor shall similarly, protect, indemnify and hold and save harmless, the Owner, its officers, officials, employee, volunteers and agents against and from any and all claims, costs, causes, actions and expenses, including, but not limited to, legal fees, incurred by reason of Contractor's breach of any of its obligations under, or Contractor's default of any provisions of the Contract. The indemnification obligations under this paragraph shall not be limited in any way by any limitation on the amount or type of damages, compensation, or benefits payable by or for the Contractor or any subcontractor under Workers' Compensation or Disability Benefit Acts or Employee Benefit Act."

2. Add new Section 3.18.1.1 as follows:

"§ 3.18.1.1 The words "claim", "damage", "loss" and "expense" as used in this Contract shall be construed to include, but be not limited to (1) injury or damage consequent upon the failure of or use or misuse by Contractor, its Subcontractors, agents, servants or employees, of any hoist, rigging, blocking, scaffolding, or any and all other kinds of items of equipment, including those covered in the Illinois Structural Work Act whether or not the same be owned, furnished or loaned by Owner; (2) all attorneys' fees and costs incurred in bringing an action to enforce the provisions of this indemnity or any other indemnity contained herein; (3) time expended by the party being indemnified and their employees, at their usual rates plus costs of travel, long distance telephone and reproduction of documents; and (4) error or omission or defect in any submission made to Architect / Engineer for its approval or review. The Contractor and every subcontractor expressly waive all so-called Kotecki rights under the Illinois workers' compensation statutes even though the Owner has retained all such rights."

1.05 ARTICLE 7 CHANGES IN THE WORK

A. § 7.1 General

1. Add new Section 7.1.4 as follows:

"§ 7.1.4 For adjustments to the Contract Sum based on other than the unit price method, overhead, profit and general conditions combined shall be calculated at the following percentages of the cost attributable to the change in the work:

- 1) For the Contractor, for any Work performed by the Contractor's own forces: 10 percent of the cost.
- 2) For the Contractor, for Work performed by his Subcontractor: 5 percent of the amount due to the Subcontractor.
- 3) For each Subcontractor or Sub-subcontractor involved, for any Work performed by the Subcontractor's own forces: 10 percent of the cost.
- 4) For each Subcontractor, for Work performed by his Sub-subcontractors: 5 percent of the amount due the Sub-subcontractor.
- 5) All proposals, except those less than \$200.00, shall be accompanied by a complete itemization of costs including labor, materials and subcontracts. Labor and materials shall be itemized in the manner prescribed above. Where major cost items are subcontracts, they shall be itemized also. In no case will a change involving over \$200.00 be approved without such itemization."

B. § 7.3 Construction Change Directives

 In the first sentence of Section 7.3.7, delete the words: "as set forth in the Agreement, or if no such amount is set forth in the Agreement, a reasonable amount." and replace with the words: "in accordance with Section 7.1.4".

1.06 ARTICLE 8 TIME

A. 8.3 Delays and Extensions of Time

1. Add new Section 8.3.1.1 as follows:

"§ 8.3.1.1 The Contractor shall not participate in any secondary boycotts or honor any informational picket lines and shall not receive credit for days or costs associated with any such labor action.

1.07 ARTICLE 9 PAYMENTS AND COMPLETION

A. § 9.3 Applications for Payment

1. Add new Section 9.3.1.3 as follows:

"§ 9.3.1.3 Until substantial completion, the Owner shall pay 90 percent of the amount due the Contractor on account of progress payments."

2. Add new Section 9.3.2.1 as follows:

"§ 9.3.2.1 In accordance with Section 9.3.2, the Contractor shall be permitted to make written petition to the Owner requesting payment for 75% of the cost of materials and equipment suitably stored off the site at a location agreed upon in writing between the Owner and the Contractor. In order to receive such payment, title to the materials and/or equipment must pass to the Owner; the materials and/or equipment must be stored in a protected, insured facility agreed to by the Owner, with the Owner named as an additional insured; and all storage costs and costs associated with handling and transporting the materials and/or equipment to the Project site must be paid for by the Contractor."

3. Add new Section 9.3.2.2 as follows:

"§ 9.3.2.2 Owner at it's sole discretion may allow the contractor to request payment for more than 75% of the cost of the materials and equipment."

B. § 9.8 Substantial Completion

- Delete the last sentence of Section 9.8.4 and replace with the following: "Warranties required by the Contract Documents shall commence on the date of Substantial Completion of the Work or designated portion thereof unless otherwise provided in the Contract Documents or the Certificate of Substantial Completion."
- 2. Delete the last sentence of Section 9.8.5 and replace with the following: "The payment shall be sufficient to increase the total payments to 95 percent of the Contract sum, less such amounts as the Architect shall determine for incomplete Work and unsettled claims."

C. § 9.10 Final Completion and Final Payment

1. Delete Section 9.10.4 in its entirety.

1.08 ARTICLE 11 INSURANCE AND BONDS

A. § 11.1 Contractor's Insurance and Bonds

1. Delete Section 11.1 in its entirety and replace with the following:

"§ 11.1 Contractor's Insurance

§ 11.1.1 The Contractor shall procure and maintain for the duration of the contract, insurance against claims for death, injuries to persons, or damages to property which may arise from or in connection with the performance of work hereunder by the

Contractor, its agents, representatives, employees or subcontractors of the types and in the amounts listed below.

§ 11.1.1.2 The additional insureds on the insurance policies shall be: City of Aurora 44 E. Downer Place, Aurora, IL 60507 and Kluber, Inc. 41 W. Benton Street, Aurora, IL 60506 **§ 11.1.2 Commercial General Liability And Umbrella Liability Insurance**

§ 11.1.2.1 The Contractor shall maintain commercial general liability (CGL) with limits of not less than \$1,000,000 each occurrence and \$2,000,000 aggregate and a commercial umbrella insurance with a limit of not less than \$2,000,000 each occurrence. If such CGL insurance contains a general aggregate limit, it shall apply separately to this project/location. CGL insurance shall cover liability arising from premises, operations, independent contractors, products-completed operations, personal injury and advertising injury, and liability assumed under an insured contract (including the tort liability of another assumed in a business contract). Additional insured Form CG2010 4-13 to include a waiver of subrogation in favor of the Owner. The Owner and Architect shall be included as an additional insured under the CGL. This insurance or self-insurance afforded to the Owner and Architect. There shall be no endorsement or modification of the CGL limiting the scope of coverage for liability arising from pollution, explosion, collapse, or underground property damage. Umbrella should be follow form to the required forms for CGL.

§ 11.1.2.2 The Contractor shall also maintain by endorsement or separate policy Contractors' Pollution Legal Liability and/or Asbestos Legal Liability and/or Errors and Omissions (if project involves environmental hazards) with limits no less than

\$1,000,000 each occurrence or claim, and \$2,000,000 policy aggregate.

§ 11.1.3 Continuing Completed Operations Liability Insurance

The Contractor shall maintain commercial general liability (CGL) with limits of not less than \$1,000,000 each occurrence and \$2,000,000 aggregate and a commercial umbrella insurance with a limit of not less than \$2,000,000 each occurrence for at least three years following substantial completion of the work. Continuing CGL insurance shall, at minimum, cover liability arising from products-completed operations and liability assumed under an insured contract. Continuing CGL insurance shall have a products-completed operations aggregate of at least two times its each occurrence limit. Continuing commercial umbrella coverage shall include liability coverage for damage to the insured's completed work. Additional insured Form CG2037 to include a waiver of subrogation in favor of the Owner. The Owner and Architect shall be included as an additional insured under the CGL. This insurance shall apply as primary and noncontributory insurance with respect to any other insurance or self-insurance afforded to the Owner and Architect. There shall be no endorsement or modification of the CGL limiting the scope of coverage for liability arising from pollution, explosion, collapse, or underground property damage. Umbrella should be follow form to the required forms for CGL.

§ 11.1.4 Business Auto Liability and Umbrella Liability Insurance

The Contractor shall maintain business auto liability with a limit of not less than \$1,000,000 CSL each accident and a commercial umbrella liability insurance with a limit of not less than \$2,000,000 each occurrence. Owner and Architect shall be included as

additional Insured on a primary and noncontributory basis with waiver of subrogation in favor of the Owner. Such insurance shall cover liability arising out of any auto including owned, hired and non-owned autos. Umbrella should be follow form to the required forms for Auto.

§ 11.1.5 Workers' Compensation Insurance

The Contractor shall maintain workers' compensation as required by statute and employers liability insurance. The commercial umbrella and/or employers liability limits shall not be less than \$1,000,000 each accident for bodily injury by accident or \$1,000,000 each employee for bodily injury by disease. If the Owner has not been included as an insured under the Commercial General and Umbrella Liability Insurance required in this Contract, the Contractor waives all rights against the Owner and its officers, officials, employees, volunteers and agents for recovery of damages arising out of or incident to the Contractor's work.

§ 11.1.6 Contractor's Obligation to Insure for Bodily Injury Claims

In addition to the above, all Contractors will purchase insurance to cover claims and expenses asserted against the Architect, its employees and consultants for bodily injury, sickness, disease, or death cause by any negligent act or omission of the Contractor, any Subcontractor, anyone directly or indirectly employed by them or anyone for whose acts any of them may be liable.

§ 11.1.7 General Insurance Provisions

§ 11.1.7.1 Evidence of Insurance

Prior to beginning work, the Contractor shall furnish the Owner with a certificate(s) of insurance and applicable policy endorsement(s), executed by a duly authorized representative of each insurer, showing compliance with the insurance requirements set forth above. All certificates shall provide for 30 days written notice to the Owner prior to the cancellation or material change of any insurance referred to therein. Written notice to the Owner shall be by certified mail, return receipt requested. Failure of the Owner to demand such certificate, endorsement or other evidence of full compliance with these insurance requirements or failure of the Owner to identify a deficiency from evidence that is provided shall not be construed as a waiver of the Contractor's obligation to maintain such insurance. The Owner shall have the right, but not the obligation, of prohibiting the Contractor or any Subcontractor from entering the Project site until such certificates or other evidence that insurance has been placed in complete compliance with these requirements is received and approved by the Owner. Failure to maintain the required insurance may result in termination of this Contract at the Owner's option. With respect to insurance maintained after final payment in compliance with a requirement above, an additional certificate(s) evidencing such coverage shall be promptly provided to the Owner whenever requested. The Contractor shall provide certified copies of all insurance policies required above within 10 days of the Owner's written request for said copies.

§ 11.1.7.2 Acceptability of Insurers

Insurers must be licensed in the State of Illinois and approved for the relevant line of coverage. and approved for the relevant line of coverage. All insurers must have an AM Best A rating or better.

§ 11.1.7.3 Cross-Liability Coverage

If the Contractor's liability policies do not contain the standard ISO separation of insureds provision, or a substantially similar clause, they shall be endorsed to provide

cross-liability coverage.

§ 11.1.7.4 Deductibles and Self-Insured Retentions

Any deductibles or self insured retentions must be declared to the Owner. At the option of the Owner, the Contractor may be asked to eliminate such deductibles or self insured retentions as respects the Owner, its officers, officials, employees, volunteers and agents or required to procure a bond guaranteeing payment of losses and other related costs including but not limited to investigations, claim administration and defense expenses.

§ 11.1.7.5 Subcontractors

The Contractor shall require each Subcontractor and Sub-subcontractor employed by the Contractor to purchase and maintain insurance of the types specified above. When requested by the Owner, the Contractor shall furnish copies of certificates of insurance evidencing coverage for each Subcontractor and Sub-subcontractor."

§ 11.1.8 Contractor's Performance and Payment Bonds

§ 11.1.8.1 Where the Contract Sum is equal to or greater than \$50,000.00, the Contractor, before commencing the Work, shall furnish a Performance Bond and a Labor and Material Bond. The Performance Bond shall be in an amount equal to 100% of the full amount of the Contract Sum as security for the faithful performance of the obligation of the Contract Documents, and the Labor and Material Payment Bond shall be in an amount equal to 100% of the full amount of the Contract Sum as security for the payment of all persons performing labor and furnishing materials in connection with the Contract Documents. Such bonds shall be on standard AIA Documents, issued by the American Institute of Architects, shall be issued by a surety authorized by the Illinois Department of Insurance to issue surety bonds in Illinois and otherwise satisfactory to the Owner, and shall name the Owner as a primary coobligee. The cost of the bonds is to be included in the Bid Proposal. The Performance Bond and Labor and Material Payment Bond will become a part of the Contract. Each Bidder shall list the name of the surety company that will be furnishing the Bonds on its Bid Proposal. The failure of a Bidder to list the name of its surety company on its Bid Proposal shall be a non-responsive bid. The failure of the successful Bidder to enter into a Contract and supply the required Bonds within ten (10) days after the Notice of Award or within such extended period as the Owner may grant if the forms do not meet its approval shall constitute a default, and the Owner may either award the Contract to the next responsible, responsive Bidder or readvertise for bids. A charge against the defaulting Bidder may be made for the difference between the amount of the bid and the amount for which a contract for the work is subsequently executed, irrespective of whether the amount thus due exceeds the amount of the bid guarantee.

§ 11.1.8.1.1 The Contractor shall deliver the required bonds to the Owner not later than three days following the date the Agreement is entered into, or if the Work is to be commenced prior thereto in response to a letter of intent, the Contractor shall, prior to the commencement of the Work, submit evidence satisfactory to the Owner that such bonds will be furnished.

§ 11.1.8.1.2 The contractor shall require the attorney-in-fact who executed the required bonds on behalf of the Surety to affix thereto a certified and current copy of the power of attorney.

§ 11.1.8.2 Whenever the Contractor shall be and is declared by Owner to be in default under the Contract, the Surety and the Contractor are each responsible to make full payment to the Owner or any and all extra Work incurred by the Architect as a result of the Contractor's default, and to pay to Owner all attorney's fees and court costs incurred by Owner as a result of the Contractor's default, and in protecting Owner's rights under the Agreement to remedy Contractor's default.

§ 11.1.8.3 The Contractor shall (i) furnish all Surety Company's bonds through Surety Company's local agents approved by and/or as directed by Owner; (ii) fully covered and guarantee with said bond the faithful performance and completion of the entire Contract, including without limitation, the faithful performance of prevailing wage requirements; and (iii) guarantee with said bond payment in all cases by the Contractor or by the Surety Company for all labor performed, material and supplies furnished with the entire Work in the Contract. Said Bond shall remain in full force and effect during the entire period of all general guarantees given by the Contractor with the Contract as called for in the Specifications and Contract, except in cases where other bonds are specifically called for in the specifications and Contract in connection with special guarantees.

§ 11.1.8.4 The Contractor and all Subcontractors shall name the Owner as an obligee on all bonds."

B. § 11.2 Owner's Insurance

1. Delete Section 11.2 in its entirety and replace with the following:

"§ 11.2 Owner's Insurance

§ 11.2.1 The Owner shall be responsible for purchasing and maintaining the Owner's usual liability insurance.

§ 11.2.2 Unless otherwise provided, the Owner shall maintain property insurance in the amount of the initial Contract Sum as well as subsequent modifications thereto for the entire Work at the site on a replacement cost basis. Such property insurance shall be maintained, unless otherwise provided in the Contract Documents or otherwise agreed in writing by all persons and entities who are beneficiaries of such insurance, until final payment has been made as provided in Section 9.10 or until no person or other entity other than the Owner has an insurable interest in the property required by this Section 11.2 to be covered, whichever is later. This insurance shall include the interests of the Owner, the Contractor, Subcontractors and Sub-Subcontractors on the Project. The Owner's insurance obligations under this paragraph may be satisfied by membership in programs of self-insurance or membership in an insurance pool.

§ 11.2.2.1 Property insurance shall be on "all risk" or equivalent policy form and shall include, without limitation, insurance against the perils of fire (with extended coverage) and physical loss or damage including, without duplication of coverage, theft, vandalism, malicious mischief, collapse, earthquake, flood, windstorm, falsework, testing and startup, temporary buildings and debris removal including demolition occasioned by enforcement of any applicable legal requirements and shall cover reasonable compensation for Architect's and Contractor's services for such insured loss.

§ 11.2.2.2 If the Owner does not intend to purchase such property insurance required by the Contract and with all of the coverages in the amount described above, the Owner shall so inform the Contractor in writing prior to commencement of the Work. The Contractor may then effect insurance that will protect the interests of the

Contractor, Subcontractors, and Sub-Subcontractors in the Work, and by appropriate Change Order the cost thereof shall be charged to the Owner. If the Contractor is damaged by the failure or neglect of the Owner to purchase or maintain insurance as described above, without so notifying the Contractor in writing, then the Owner shall bear all reasonable costs properly attributable thereto.

§ 11.2.2.3 If deductibles are not identified in the Contract Documents, the Contractor shall pay costs not covered because of deductibles.

§ 11.2.2.4 Partial occupancy or use in accordance with Section 9.9 shall not commence until the insurance company or companies providing property insurance have consented to such partial occupancy or use by endorsement or otherwise. The Owner and the Contractor shall take reasonable steps to obtain consent of the insurance company or companies and shall, without mutual written consent, take no action with respect to partial occupancy or use that would cause cancellation, lapse, or reduction of insurance.

§ 11.2.3 Boiler and Machinery Insurance

The Owner shall purchase and maintain boiler and machinery insurance required by the Contract Documents or by law, which shall specifically cover such insured objects during installation and until final acceptance by the Owner; this insurance shall include interest of the Owner, Contractor, Subcontractors, and Sub-Subcontractors in the Work, and the Owner and Contractor shall be named insureds.

§ 11.2.4 If the Contractor requests in writing that insurance for risks other and those described herein or other special causes of loss be included in the property insurance policy, the Owner shall, if possible, include such insurance, and the cost thereof shall be charged to the Contractor by appropriate Change Order.

§ 11.2.5 A loss insured under the Owner's property insurance shall be adjusted by the Owner as fiduciary and made payable to the Owner as fiduciary for the insureds, as their interests may appear, subject to requirements of any applicable mortgagee clause and of Section 11.3.10. The Contractor shall pay Subcontractors their just shares of insurance proceeds received by the Contractor, and by appropriate agreements, written where legally required for validity, shall require Subcontractors to make payments to their Subsubcontractors in similar manner.

§ 11.2.6 If required in writing by a party in interest, the Owner as fiduciary shall, upon occurrence of an insured loss, give bond for proper performance of the Owner's duties. The cost of required bonds shall be charged against proceeds received as fiduciary. The Owner shall deposit in a separate account proceeds so received, which the Owner shall distribute in accordance with such agreement as the parties in interest may reach, or as determined in accordance with the method of binding dispute resolution selected in the Agreement between the Owner and Contractor. If after such loss no other special agreement is made and unless the Owner terminates the Contract for convenience, replacement of damaged property shall be performed by the Contractor after notification of a Change in the Work in accordance with Article 7.

§ 11.2.7 The Owner as fiduciary shall have power to adjust and settle a loss with insurers unless one of the parties in interest shall object in writing within five days after occurrence of loss to the Owner's exercise of this power; if such objection is made, the dispute shall be resolved in the manner selected by the Owner and Contractor as the method of binding dispute resolution in the Agreement. If the Owner and Contractor have selected arbitration as the method of binding dispute resolution, the Owner as fiduciary

shall make settlement with insurers or, in the case of a dispute over distribution of insurance proceeds, in accordance with the directions of the arbitrators.

§ 11.2.8 Notwithstanding any provision contained in Section 11.2, the Owner's obligation to purchase insurance shall herein be deemed satisfied by the Owner's membership in a self-insured risk management agency or pool. The Contractor agrees that any obligation the Owner has to purchase property insurance shall be satisfied by the Owner's membership in a self-insured risk management agency or pool. The Contractor further agrees that it will only have rights allowable to it under any coverage provided through the Owner's membership in a self-insured risk management agency or pool."

C. § 11.4 Loss of Use, Business Interruption, and Delay in Completion Insurance

1. Delete Section 11.4 in its entirety.

1.09 ARTICLE 12 UNCOVERING AND CORRECTION OF WORK

A. 12.2.2 After Substantial Completion

 Delete Sections 12.2.2.1, 12.2.2.2 and 12.2.2.3 in their entireties and replace with the following: "§ 12.2.2.1 In addition to the Contractor's obligations under Section 3.5, if, within two years after the date of Substantial Completion of the Work or designated portion thereof or after the date for commencement of warranties established under Section 9.9.1, or by terms of an applicable special warranty required by the Contract Documents, any of the Work is found to be not in accordance with the requirements of the Contract Documents, the Contractor shall correct it promptly after receipt of written notice from the Owner to do so unless the Owner has previously given the Contractor a written acceptance of such condition. The Owner shall give such notice promptly after discovery of the condition. During the two-year period for correction of Work, if the Owner fails to notify the Contractor and give the Contractor an opportunity to make the correction, the Owner waives the rights to require correction by the Contractor and to make a claim for breach of warranty. If the Contractor fails to correct nonconforming Work within a reasonable time during that period after receipt of notice from the Owner or Architect, the Owner may correct it in accordance with Section 2.5. § 12.2.2. The two-year period for correction of Work shall be extended with respect to

portions of Work first performed after Substantial Completion by the period of time between Substantial Completion and the actual completion of that portion of the Work.

§ 12.2.2.3 The two-year period for correction of Work shall not be extended by corrective Work performed by the Contractor pursuant to this Section 12.2."

2. Delete Section 12.2.2.5 in its entirety and replace with the following:

"§ 12.2.2.5 Nothing contained in this Section 12.2 shall be construed to establish a period of limitation with respect to other obligations the Contractor has under the Contract Documents. Establishment of the two-year period for correction of Work as described in Section 12.2 relates only to the specific obligation of the Contractor to correct the Work, and has no relationship to the time within which the obligation to comply with the Contract Documents may be sought to be enforced nor the time within which proceedings may be commenced to establish the Contractor's liability with respect to the Contractor's obligations other than specifically to correct the Work."

1.10 ARTICLE 13 MISCELLANEOUS PROVISIONS

A. 13.4 Tests and Inspections

1. Add new Section 13.4.7 as follows:

"§ 13.4.7 The cost of any requested retest will be borne by the party requesting the retest, unless the retest shows that the original test or the Work being tested was in error or defective, and in such event, the cost of the retest shall be borne by the other party."

B. 13.5 Interest

1. Delete Section 13.5 in its entirety. All references to interest payments throughout the Contract Documents are hereby voided. Payment is governed by the Illinois Local Government Prompt Payment Act.

C. Add Section 13.6 as follows:

"§ 13.6 Regulations

§ 13.6.1 The Contractor or Subcontractor warrants that he is familiar with and he shall comply with Federal, State and local laws, statutes, ordinances, rules and regulations and the orders and decrees of any courts or administrative bodies or tribunals in any manner affecting the performance of the Contract including without limitation Workmen's Compensation Laws, minimum salary and wage statutes and regulations, laws with respect to permits and licenses and fees in connection therewith, laws regarding maximum working hours. No plea of misunderstanding or ignorance thereof will be considered.

§ 13.6.2 Whenever required, the Contractor or Subcontractor shall furnish the Architect and Owner with satisfactory proof of compliance with said Federal, State and local laws, statutes, ordinances, rules, regulations, orders, and decrees.

§ 13.6.3 Each bidder shall carefully examine the Occupational Safety and health Act as issued by the Federal Register (OSHA), and the specific regulations governing procedures, techniques, safety precautions, equipment design, and the configuration of the same as required under this Act and each bidder agrees as evidenced by his submission of a bid to comply with all terms of the Act and to perform and complete in a workmanlike manner all work required in full compliance with said Act.

§ 13.6.5 At all times Contractor shall remain in compliance with the Illinois Public Works Employment Discrimination Act (775 ILCS 10/1, et seq.,) and the Illinois Human Rights Act (775 ILCS 5/2-101, et seq.,) and in addition shall at all times comply with Section 2-105 of the Illinois Human Rights Act.

§ 13.6.6 By execution of this Contract, the Contractor understands, represents and warrants to the Owner that the Contractor and its Subcontractors (for which the Subcontractor takes responsibility to insure that they comply with the above-mentioned Acts) are in compliance with all requirements provided by the Acts set forth in Article 13 and that they will remain in compliance for the entirety of the Work. A violation of any of the Acts set forth in this Article is cause for the immediate cancellation of the Contract. However, any forbearance or delay by the Owner in canceling this Contract shall not be considered as, and does not constitute, Owner's consent to such violation and a waiver of any rights the Owner may have, including without limitation, cancellation of this Contract."

D. Add Section 13.7 as follows:

"§ 13.7 Record Keeping

§ 13.7.1 The Contractor and every Subcontractor shall keep and maintain accurate books of record and account, in accordance with sound accounting principles, of all expenditures made and all costs, liabilities and obligations incurred under this Contract, and all papers, files, accounts, reports, cost proposals with backup data and all other material relating to work under this Contract and shall make all such materials available at the office of the Owner at any reasonable time during the term of this contract and for the length of time established by law or

five (5) years, whichever is longer, from the date of final payment to Contractor or termination of this Contract for audit, inspection and copying upon Owner's request. The Contractor agrees to maintain all records and documents for projects of the Owner in compliance with the Freedom of Information Act, 5 ILCS 140/1 et seq. In addition, the Contractor shall produce records which are responsive to a request received by the Owner under the Freedom of Information Act so that the Owner may provide records to those requesting them within the time frames required. If additional time is necessary to compile records in response to a request, then the Contractor shall so notify the Owner and, if possible, the Owner shall request an extension so as to comply with the Act. In the event that the Owner is found to have not complied with the Freedom of Information Act due to the Contractor's failure to produce documents or otherwise appropriately respond to a request under the Act, then the Contractor shall indemnify and hold the Owner harmless, and pay all amounts determined to be due including but not limited to fines, costs, attorneys' fees and penalties."

E. Add Section 13.8 as follows:

"§ 13.8 PREVAILING WAGES

§ 13.8.1 The Contractor and all Subcontractors shall pay prevailing wages as established by the Illinois Department of Labor for each craft or type of work needed to execute the contract in accordance with the Prevailing Wage Act (820 ILCS 130/0.01 et seq.). The Contractor shall prominently post the current schedule of prevailing wages at the Contract site and shall notify immediately in writing all of its Subcontractors, of all changes in the schedule of prevailing wages. Any increases in costs to the Contractor due to changes in the prevailing rate of wage during the terms of any contract shall be at the expense of the Contractor and not at the expense of the Owner. The change order shall be computed using the prevailing wage rates applicable at the time the change order work is scheduled to be performed. The Contractor shall be solely responsible for maintain accurate records as required by the prevailing wage satute and shall be solely liable for paying the difference between prevailing wages and any wages actually received by laborers, workmen and/or mechanics engaged in the Work. § 13.8.2 The Contractor shall provide certified payroll records in accordance with the requirements established by the Prevailing Wage Act(820 ILCS 130/5) as amended 8/10/2005 by Illinois Public Act 94-0515."

1.11 ARTICLE 15 CLAIMS AND DISPUTES

A. § 15.1.7 Waiver of Claims for Consequential Damages

1. Delete Section 15.1.7 in its entirety.

B. § 15.2 INITIAL DECISION

1. Delete Section 15.2.1 in its entirety and replace with the following:

"§ 15.2.1 Claims, excluding those arising under Sections 10.3, 10.4 and 11.5, may be referred to the Initial Decision Maker for action. A decision by the Initial Decision Maker shall not be binding and shall not be required as a condition precedent to litigation."

END OF DOCUMENT

SECTION 00 73 40 LABOR AND WAGE REQUIREMENTS

1.01 LABOR AND WAGE REQUIREMENTS

- A. In the employment and use of labor, the Contractor and his subcontractors shall conform to the Illinois Statutory requirements regarding labor and wages.
- B. Wage Guidelines:
 - Prevailing Rate of Wages: All Contracts for the work herein are subject to the provisions of the Illinois Prevailing Wages Act (820 ILCS 130/et seq.) providing for the payment of prevailing rate of wages to all Laborers, Workmen, and Mechanics engaged on the work, which such provisions shall be applicable to all subcontractors and material men as well as the Contractor. The Owner may at any time inquire of the Contractor as to rates of wages being paid employees of the Contractor, any subcontractor or material men, whereupon such information shall be promptly provided to the Owner.
 - a. The terms "generally prevailing rate of hourly wages," "generally prevailing rate of wages," or "prevailing rate of wages," mean the hourly cash wage plus fringe benefits for health and welfare, insurance, vacations, and pensions paid generally, in the locality in which the work is being performed, to employees engaged in work of a similar character on public works.
 - 2. The Contractor shall not pay less than the rates of wages prevailing the District as determined by the Illinois Department of Labor to all Laborers, Mechanics and Workers performing any work under this Contract.
 - a. Only such laborers, workers and mechanics as are directly employed by the Contractor or Subcontractors in actual construction work on the site of the Project, and laborers, workers and mechanics engaged in the transportation of materials and equipment to or from the site, but not including the transportation by sellers and suppliers or the manufacture or processing of materials or equipment, in the execution of the Work shall be deemed to be employed on the Project for purposes of compliance with the Illinois Statutory requirements.
 - 3. The Contractor shall require all of its Subcontractors to comply with the requirements of the preceding paragraphs, which shall be incorporated in each and every subcontract for all or any portion of the Work.
 - 4. The Contractor will cooperate and coordinate his work with any subcontractors that the Owner has working on the Project at the same time.
 - 5. Future increases to wage rates and material cost over the course of the contract time will not be born by the Owner. Contractor to include in his Base Bid.
- C. Certified Payroll Requirements: For all of the Contractor's, its Subcontractors and Subsubcontractors' laborers, mechanics and other workers employed on the Project, the Contractor shall submit monthly, and with each Application For Payment, certified payroll records in accordance with State of Illinois, Department of Labor, 8/10/2005 Prevailing Wage Act Changes; "Certified Payroll Requirements" (Public Act 94-0515).

1.02 WAGE DETERMINATION SCHEDULE

A. Contact the Illinois Department of Labor for the most recent revisions to the Prevailing Rate of Wages.

END OF DOCUMENT

SECTION 01 10 00 SUMMARY

PART 1 GENERAL

1.01 PROJECT

- A. Project Name: FINANCE DEPARTMENT INTERIOR RENOVATION.
- B. Owner's Name: City of Aurora.
- C. Architect/Engineer's Name: Kluber Architects + Engineers.
- D. The Project consists of the interior renovation of the existing Fourth Floor office space.

1.02 CONTRACT DESCRIPTION

A. Contract Type: A single prime contract based on a Stipulated Price as described in Document 00 52 00 - Agreement Form.

1.03 DESCRIPTION OF ALTERATIONS WORK

- A. Scope of demolition and removal work is shown on drawings and specified in Section 02 41 00.
- B. Scope of alterations work is shown on drawings.
- C. HVAC: Alter existing system and add new construction, keeping existing in operation.
- D. Electrical Power and Lighting: Alter existing system and add new construction, keeping existing in operation.
- E. Fire Suppression Sprinklers: Alter existing system and add new construction, keeping existing in operation.
- F. Fire Alarm: Alter existing system and add new construction, keeping existing in operation.

1.04 WORK BY OWNER

- A. Items noted NIC (Not in Contract) will be supplied and installed by Owner before Substantial Completion.
 - 1. Furniture

1.05 OWNER OCCUPANCY

- A. Owner intends to continue to occupy adjacent portions of the existing building during the entire construction period.
- B. Owner intends to occupy the Project upon Substantial Completion.
- C. Cooperate with Owner to minimize conflict and to facilitate Owner's operations.
- D. Schedule the Work to accommodate Owner occupancy.

1.06 CONTRACTOR USE OF SITE AND PREMISES

- A. Arrange use of site and premises to allow:
 - 1. Owner occupancy.
 - 2. Work by Others.

- 3. Work by Owner.
- 4. Use of site and premises by the public.
- B. Provide access to and from site as required by law and by Owner:
 - 1. Emergency Building Exits During Construction: Keep all exits required by code open during construction period; provide temporary exit signs if exit routes are temporarily altered.
 - 2. Do not obstruct roadways, sidewalks, or other public ways without permit.
- C. Time Restrictions:
 - 1. Limit conduct of especially noisy work to the hours of 6:00 am to 8:00 am.

1.07 WORK SEQUENCE

- A. Coordinate construction schedule and operations with Owner.
- PART 2 PRODUCTS NOT USED

PART 3 EXECUTION - NOT USED

END OF SECTION
SECTION 01 20 00 PRICE AND PAYMENT PROCEDURES

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Procedures for preparation and submittal of applications for progress payments.
- B. Documentation of changes in Contract Sum and Contract Time.
- C. Change procedures.
- D. Correlation of Contractor submittals based on changes.
- E. Procedures for preparation and submittal of application for final payment.

1.02 RELATED REQUIREMENTS

- A. Section 00 52 00 Agreement Form: Contract Sum, retainages, payment period.
- B. Section 00 72 00 General Conditions: Additional requirements for progress payments, final payment, changes in the Work.
- C. Section 00 73 00 Supplementary Conditions: Percentage allowances for Contractor's overhead and profit.

1.03 SCHEDULE OF VALUES

- A. Use Schedule of Values Form: AIA G703, edition stipulated in the Agreement.
- B. Electronic media printout including equivalent information will be considered in lieu of standard form specified; submit draft to Architect/Engineer for approval.
- C. Forms filled out by hand will not be accepted.
- D. Submit Schedule of Values to the Architect/Engineer at earliest possible date, but no later than 14 days prior to first Pay Request Meeting.
 - 1. After review by the Architect/Engineer, revise and resubmit Schedule as directed.
- E. Format: Utilize the Table of Contents of this Project Manual as a format for the listing of the Work.
- F. Identify as separate line items on the Schedule the costs for the following items: Bonds, Insurance, Site Mobilization, each Allowance scheduled in Section 01 21 00, Construction Submittals, General Conditions, Overhead And Profit, Demonstration And Training, and Closeout Submittals
 - 1. Bonds and Insurance.
 - 2. General Conditions.
 - 3. Allowances (list each Allowance on a separate line; See Section 01 21 00).
 - 4. Contractor's overhead and profit.
- G. Submit Schedule of Values in sufficient detail for the Architect/Engineer to use in evaluation of Applications for Payment.
 - 1. Itemize the cost of the work of:
 - a. Contractor's materials.
 - b. Contractor's own labor.
 - c. Subcontractors' materials.

- d. Subcontractors' labor.
- H. Revise Schedule of Values to list approved Change Orders, with each Application For Payment.

1.04 APPLICATIONS FOR PROGRESS PAYMENTS

- A. Payment Period: Submit at intervals stipulated in the Agreement.
- B. Use Form AIA G702 and Form AIA G703, edition stipulated in the Agreement.
- C. Electronic media printout including equivalent information will be considered in lieu of standard form specified; submit sample to Architect/Engineer for approval.
- D. Forms filled out by hand will not be accepted.
- E. For each item, provide a column for listing each of the following:
 - 1. Item Number.
 - 2. Description of work.
 - 3. Scheduled Values.
 - 4. Previous Applications.
 - 5. Work in Place and Stored Materials under this Application.
 - 6. Authorized Change Orders.
 - 7. Total Completed and Stored to Date of Application.
 - 8. Percentage of Completion.
 - 9. Balance to Finish.
 - 10.Retainage.
- F. Execute certification by signature of authorized officer.
- G. Use data from approved Schedule of Values. Provide dollar value in each column for each line item for portion of work performed and for stored products.
- H. List each authorized Change Order as a separate line item, listing Change Order number and dollar amount as for an original item of work.
- I. Submit one pencil/draft copy of each Application for Payment to the Architect/Engineer at least 7 days prior to the due date for the submission of the Application.
- J. Contractor or Architect/Engineer may schedule a Pay Request Meeting to review the pencil/draft copy of the Application for agreement with the progress of the Work.
- K. After receipt of Architect/Engineer's review comments, submit three final copies, signed and notarized, of each Application for Payment.
- L. Include the following with the application:
 - 1. Transmittal letter as specified for submittals in Section 01 30 00.
 - 2. Construction progress schedule, revised and current as specified in Section 01 30 00.
 - Contractor's partial waiver of lien in the amount of the Application for Payment as well as trailing partial waivers of lien for subcontractors and suppliers who were included in the previous Application for Payment, to the extent of that payment.
 - a. When an Application shows completion of a subcontractor or supplier item, submit a final or full waiver for that item.
 - b. Waivers of lien shall be submitted on forms and executed in a manner acceptable to the Owner.

- 4. Certified payroll records for the Contractor and for all Subcontractors and Sub-subcontractors employed on the Project who performed work on the Project during the Payment Period.
 - a. Contractor shall assemble his and all subcontractor and sub-subcontractor records prior to submitting each Application for Payment.
 - b. Applications for Payment submitted without certified payroll records or with incomplete certified payroll records will result in payment being delayed until the Contractor complies fully with the requirements set forth in the preceding paragraphs.
- 5. Affidavits attesting to products or equipment suitably stored off-site in a bonded warehouse. Payments for materials stored off-site shall be conditioned upon submission of bills of sale, applicable insurance, and any other documentation or procedures satisfactory to the Owner to establish the Owner's title to such materials, or otherwise protect the Owner's interest.
- M. When Architect/Engineer requires substantiating information, submit data justifying dollar amounts in question. Provide one copy of data with cover letter for each copy of submittal. Show application number and date, and line item by number and description.

1.05 MODIFICATION PROCEDURES

- A. Submit name of the individual authorized to receive change documents and who will be responsible for informing others in Contractor's employ or subcontractors of changes to Contract Documents.
- B. For minor changes not involving an adjustment to the Contract Sum or Contract Time, Architect/Engineer will issue instructions directly to Contractor.
- C. For other required changes, Architect/Engineer will issue a document signed by Owner instructing Contractor to proceed with the change, for subsequent inclusion in a Change Order.
 - 1. The document will describe the required changes and will designate method of determining any change in Contract Sum or Contract Time.
 - 2. Promptly execute the change.
- D. For changes for which advance pricing is desired, Architect/Engineer will issue a document that includes a detailed description of a proposed change with supplementary or revised drawings and specifications, a change in Contract Time for executing the change with a stipulation of any overtime work required and the period of time during which the requested price will be considered valid. Contractor shall prepare and submit a fixed price quotation within ten (10) days.
- E. Contractor may propose a change by submitting a request for change to Architect/Engineer, describing the proposed change and its full effect on the work, with a statement describing the reason for the change, and the effect on the Contract Sum and Contract Time with full documentation and a statement describing the effect on work by separate or other contractors. Document any requested substitutions in accordance with Section 01 60 00.
- F. Computation of Change in Contract Amount: As specified in the Agreement and Conditions of the Contract.
 - 1. For change requested by Architect/Engineer for work falling under a fixed price contract, the amount will be based on Contractor's price quotation.
 - 2. For change requested by Contractor, the amount will be based on the Contractor's request for a Change Order as approved by Architect/Engineer.
 - 3. For pre-determined unit prices and quantities, the amount will be based on the fixed unit prices.

- For change ordered by Architect/Engineer without a quotation from Contractor, the amount will be determined by Architect/Engineer based on the Contractor's substantiation of costs as specified for Time and Material work.
- G. Substantiation of Costs: Provide full information required for evaluation.
 - 1. On request, provide the following data:
 - a. Quantities of products, labor, and equipment.
 - b. Taxes, insurance, and bonds.
 - c. Overhead and profit.
 - d. Justification for any change in Contract Time.
 - e. Credit for deletions from Contract, similarly documented.
 - 2. Support each claim for additional costs with additional information:
 - a. Origin and date of claim.
 - b. Dates and times work was performed, and by whom.
 - c. Time records and wage rates paid.
 - d. Invoices and receipts for products, equipment, and subcontracts, similarly documented.
 - 3. For Time and Material work, submit itemized account and supporting data after completion of change, within time limits indicated in the Conditions of the Contract.
- H. Execution of Change Orders: Architect/Engineer will issue Change Orders for signatures of parties as provided in the Conditions of the Contract.
- I. After execution of Change Order, promptly revise Schedule of Values and Application for Payment forms to record each authorized Change Order as a separate line item and adjust the Contract Sum.
- J. Promptly revise progress schedules to reflect any change in Contract Time, revise sub-schedules to adjust times for other items of work affected by the change, and resubmit.
- K. Promptly enter changes in Project Record Documents.

1.06 APPLICATION FOR FINAL PAYMENT

- A. Prepare Application for Final Payment as specified for progress payments, identifying total adjusted Contract Sum, previous payments, and sum remaining due.
- B. Application for Final Payment will not be considered until the following have been accomplished:
 - 1. All closeout procedures specified in Section 01 70 00.
 - 2. Procedures outlined in Article 9 of the General Conditions as amended.
 - 3. Additional closeout procedures specified in Section 01 77 00.
- C. The submittal of Final Waiver of Lien and the acceptance of the final payment by the Contractor shall be held to be a waiver of any and all claims against the Owner arising from, out of, or in any connection with the Contract.

PART 2 PRODUCTS - NOT USED

PART 3 EXECUTION - NOT USED

SECTION 01 21 00 ALLOWANCES

PART 1 GENERAL

1.01 SECTION INCLUDES

A. Contingency allowance.

1.02 RELATED REQUIREMENTS

A. Section 01 20 00 - Price and Payment Procedures: Additional payment and modification procedures.

1.03 CONTINGENCY ALLOWANCE

- A. Contractor's costs for products, delivery, installation, labor, payroll, taxes and equipment rental will be included in Change Orders authorizing expenditure of funds from this Contingency Allowance.
- B. Funds will be drawn from the Contingency Allowance only by Change Order.
- C. Bond, insurance, overhead and profit fees on Change Orders paid out of Contingency Allowances will not be permitted. The Contractor must carry in its Base Bid OH&P costs on Contingency Allowance funds expenditures.
- D. At closeout of Contract, funds remaining in Contingency Allowance will be credited to Owner by Change Order.

1.04 ALLOWANCES SCHEDULE

- A. Contingency Allowance: Include in the Base Bid the stipulated sum of \$30,000.00 for use upon Owner's instructions.
- PART 2 PRODUCTS NOT USED
- PART 3 EXECUTION NOT USED

SECTION 01 30 00 ADMINISTRATIVE REQUIREMENTS

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. General administrative requirements.
- B. Preconstruction meeting.
- C. Progress meetings.
- D. Construction progress schedule.
- E. Submittals for review, information, and project closeout.
- F. Architect/Engineer-provided CAD files.
- G. Number of copies of submittals.
- H. Submittal procedures.

1.02 RELATED REQUIREMENTS

- A. Section 00 72 00 General Conditions: Dates for applications for payment.
- B. Section 01 70 00 Execution and Closeout Requirements: Additional coordination requirements.
- C. Section 01 78 00 Closeout Submittals: Project record documents; operation and maintenance data; warranties and bonds.

1.03 GENERAL ADMINISTRATIVE REQUIREMENTS

A. Comply with requirements of Section 01 70 00 - Execution and Closeout Requirements for coordination of execution of administrative tasks with timing of construction activities.

PART 2 PRODUCTS - NOT USED

PART 3 EXECUTION

3.01 PRECONSTRUCTION MEETING

- A. Architect
- B. Attendance Required:
 - 1. Owner.
 - 2. Architect/Engineer.
 - 3. Contractor.

C. Agenda:

- 1. Architect will prepare agenda for this meeting.
- 2. Submission of executed bonds and insurance certificates.
- 3. Distribution of Contract Documents.
- 4. Submission of list of subcontractors, list of products, schedule of values, and progress schedule.

- 5. Procedures and processing of field decisions, submittals, substitutions, applications for payments, proposal request, Change Orders, and Contract closeout procedures.
- 6. Scheduling.
- D. Architect will record minutes and distribute copies to participants.

3.02 PROGRESS MEETINGS

- A. Make arrangements for meetings, prepare agenda with copies for participants, preside at meetings.
- B. General Contractor will make arrangements for meetings, prepare agenda with copies for participants, preside at meetings.
- C. Attendance Required:
 - 1. Contractor.
 - 2. Owner.
 - 3. Architect/Engineer.
 - 4. Contractor's superintendent.
- D. Agenda:
 - 1. Review minutes of previous meetings.
 - 2. Review of Work progress.
 - 3. Field observations, problems, and decisions.
 - 4. Identification of problems that impede, or will impede, planned progress.
 - 5. Review of submittals schedule and status of submittals.
 - 6. Review of RFIs log and status of responses.
 - 7. Review of off-site fabrication and delivery schedules.
 - 8. Maintenance of progress schedule.
 - 9. Corrective measures to regain projected schedules.
 - 10. Planned progress during succeeding work period.
 - 11. Maintenance of quality and work standards.
 - 12. Effect of proposed changes on progress schedule and coordination.
 - 13. Other business relating to Work.
- E. Record minutes and distribute copies within two days after meeting to participants, with copies to Architect/Engineer, Owner, participants, and those affected by decisions made.

3.03 CONSTRUCTION PROGRESS SCHEDULE

- A. Within 10 days after date of the Agreement, submit preliminary schedule defining planned operations for the first 60 days of work, with a general outline for remainder of work.
- B. If preliminary schedule requires revision after review, submit revised schedule within 7 days.
- C. Submit updated schedule with each Application for Payment.

3.04 SUBMITTALS FOR REVIEW

- A. When the following are specified in individual sections, submit them for review:
 - 1. Product data.
 - 2. Shop drawings.
 - 3. Samples for selection.

- 4. Samples for verification.
- B. Submit to Architect/Engineer for review for the limited purpose of checking for compliance with information given and the design concept expressed in Contract Documents.
- C. Samples will be reviewed for aesthetic, color, or finish selection.
- D. After review, provide copies and distribute in accordance with SUBMITTAL PROCEDURES article below and for record documents purposes described in Section 01 78 00 Closeout Submittals.

3.05 SUBMITTALS FOR INFORMATION

- A. When the following are specified in individual sections, submit them for information:
 - 1. Design data.
 - 2. Certificates.
 - 3. Test reports.
 - 4. Inspection reports.
 - 5. Manufacturer's instructions.
 - 6. Manufacturer's field reports.
 - 7. Other types indicated.
- B. Submit for Architect/Engineer's knowledge as contract administrator or for Owner.

3.06 SUBMITTALS FOR PROJECT CLOSEOUT

- A. Submit Correction Punch List for Substantial Completion.
- B. Submit Final Correction Punch List for Substantial Completion.
- C. When the following are specified in individual sections, submit them at project closeout in compliance with requirements of Section 01 78 00 Closeout Submittals:
 - 1. Project record documents.
 - 2. Operation and maintenance data.
 - 3. Warranties.
 - 4. Bonds.
 - 5. Other types as indicated.
- D. Submit for Owner's benefit during and after project completion.

3.07 ARCHITECT/ENGINEER-PROVIDED CAD FILES

- A. After the execution of the Contract, Architect/Engineer will provide, free of charge, upon receipt of a properly completed and signed request utilizing "Electronic Data Transfer Consent Form" at the end of this Specification Section, CAD files depicting graphic information for the project as follows:
 - 1. Architectural Floor Plans: Column grid, walls, floors, stairs, doors, windows, room numbers, ceiling grid, mechanical diffusers, plumbing fixtures, sprinkler heads (if depicted in Bid Documents) and lights.
- B. Contractor acknowledges and accepts that the Architectural Floor Plans do not contain structural, mechanical, electrical, plumbing, fire protection and other building systems information depicted in the Bidding Documents. Examples of information not contained in these files include, but are not limited to, title blocks, keynotes, schedules, mechanical ductwork and equipment, electrical device symbols, circuit numbers and home runs, plumbing equipment, piping runs and riser diagrams, and

architectural/engineering text or details. No other CAD files, data or information will be provided.

- C. Only requests from Prime Contractors will be honored. Subcontractors must obtain the files from their respective Prime Contractors.
- D. In submitting a request, Contractor acknowledges that:
 - 1. Architect/Engineer bears no responsibility for the data or its transmission,
 - 2. Use of the data by the Contractor or his subcontractors in no way relieves the Contractor of his obligations under the Contract,
 - 3. Contractor is solely liable for any and all claims arising from any and all products generated by the Contractor or its Subcontractors employing the data,
 - 4. Contractor and its Subcontractors have a limited, non-exclusive license to use the data solely in connection with the Work of the Project.
 - 5. Architect/Engineer retains all rights, including copyright, to the data.

3.08 NUMBER OF COPIES OF SUBMITTALS

- A. Documents for Review:
 - 1. Small Size Sheets: Not Larger Than 11 x 17 inches. Submit two (2) paper copies, one of which will be retained by Architect/Engineer. Contractor shall make his own copies from the original returned by the Architect.
 - a. Contractor's Option: In lieu of paper copies indicated above, submit in Adobe PDF electronic file format via email. Architect will return a reviewed copy in Adobe PDF electronic file format via email. Create PDFs at native size and right-side up; illegible files will be rejected.
 - Large Size Sheets: Larger Than 11 x17 inches; 36 x 48 inches maximum. Submit two (2) paper copies, one of which will be retained by Architect/Engineer. Electronic file format (PDF or other) is NOT acceptable. Contractor shall make his own copies from the original returned by the Architect.
- B. Documents for Information: Submit one copy.
- C. Samples: Submit the number specified in individual specification sections; one of which will be retained by Architect/Engineer.
 - 1. After review, produce duplicates.
 - 2. Retained samples will not be returned to Contractor unless specifically so stated.

3.09 SUBMITTAL PROCEDURES

- A. Shop Drawing Procedures:
 - 1. Prepare accurate, drawn-to-scale, original shop drawing documentation by interpreting the Contract Documents and coordinating related Work.
 - 2. Generic, non-project specific information submitted as shop drawings do not meet the requirements for shop drawings.
- B. Transmit each submittal with a copy of approved submittal form.
- C. Transmit each submittal with AIA Form G810.

- D. Sequentially number the transmittal form. Revise submittals with original number and a sequential alphabetic suffix.
- E. Identify Project, Contractor, Subcontractor or supplier; pertinent drawing and detail number, and specification section number, as appropriate on each copy.
- F. Apply Contractor's stamp, signed or initialed certifying that review, approval, verification of Products required, field dimensions, adjacent construction Work, and coordination of information is in accordance with the requirements of the Work and Contract Documents.
- G. Deliver submittals to Architect/Engineer at business address.
- H. Schedule submittals to expedite the Project, and coordinate submission of related items.
- I. For each submittal for review, allow 20 days excluding delivery time to and from the Contractor.
- J. Clearly identify variations from the Contract Documents. Regardless of the type of variation, Contractor is solely responsible for errors in the field that arise from submittal variations from the requirements of the Contract Documents if those variations were not expressly noted to specifically identify for and describe to the reviewer the nature of the variation from the Contract Documents.
- K. Identify variations from Contract Documents and Product or system limitations that may be detrimental to successful performance of the completed Work.
- L. Correlate submitted items with specified products; clearly indicate the specified product that corresponds to each submitted item.
- M. When options or optional features available for a Product are indicated in a submittal, and selections for those options/features are indicated in the Contract Documents, identify on the submittal the selection indicated in the Contract Documents.
- N. Provide space for Contractor and Architect/Engineer review stamps.
- O. When revised for resubmission, using clouds, highlights or other means acceptable to the Architect, identify all changes made since previous submission. Resubmittals that do not clearly identify all changes may be delayed and/or returned to the Contractor unreviewed.
- P. The Contractor is entitled to one (1) resubmittal of any Shop Drawing, Product Data, or Closeout Submittal item rejected by the Architect or returned by the Architect for further action. Thereafter, the Contractor shall pay the cost of all further Architect's reviews of Shop Drawing, Product Data or Closeout Submittal, at a rate of \$200.00/hour. Cost of such further reviews will be deducted from the Contract Sum by Change Order.
- Q. Distribute reviewed submittals as appropriate. Instruct parties to promptly report any inability to comply with requirements.
- R. Submittals not requested will not be recognized or processed.
- S. Submittal reviews may be delayed and/or submittals may be returned unreviewed for any of the following reasons:
 - 1. Submittals submitted outside the scheduled dates of the Submittal Schedule.
 - 2. Submittals are incomplete or are missing information.

3. Submittals are not submitted in accordance with procedures outlined in this Section (i.e. spec Section number not indicated, missing Contractor's review stamp, submitted items not correlated with specified products).



ELECTRONIC DATA TRANSFER CONSENT FORM

Project Name: FINANCE DEPARTMENT INTERIOR RENOVATION AURORA, ILLINOIS 60507

Project No.: 24-130-1552

Owner: CITY OF AURORA

Your Work: ______

KLUBER, INC. (hereinafter referred to as "Kluber") an Illinois corporation, is providing electronic data to you solely at your request and for your convenience. By accepting and opening any of the electronic data files, you agree that Kluber bears no liability for the data or its transmission to you and that you are solely liable for any and all claims referring or relating to any and all products you, or your Subcontractors, may generate with the data.

You acknowledge that you have a limited non-exclusive license to use the information solely in connection with your work on the project captioned above, and that Kluber retains all rights, including copyright, to the data.

Acknowledged by:				
5,	(Printed Name)		(Signature)	
Company:				
Date:		Email:		

Architectural Floor Plans are transmitted for the contractors' use as backgrounds for shop drawings and as-built drawings, and, as such, contain graphic information for column grid, walls, floors, stairs, doors, windows, room numbers, ceiling grid, lights, diffusers and sprinkler heads where indicated on Bid Documents. Plans <u>do not</u> contain title blocks, keynotes, schedules, mechanical ductwork and equipment, electrical device symbols, circuit numbers and home runs, plumbing equipment, piping runs and riser diagrams, and architectural/engineering text and details. Plans depict <u>entire</u> floors and are not formatted, partial plans as depicted in the Bidding Documents. Files are provided in R2013 .DWG format.)

Bloomington Office 2401 East Washington Street Bloomington, Illinois 61704 309.430.6460 Aurora Office 41 W. Benton Street Aurora, Illinois 60506 630.406.1213

SECTION 01 40 00 QUALITY REQUIREMENTS

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Submittals.
- B. Quality assurance.
- C. Testing and inspection agencies and services.
- D. Contractor's design-related professional design services.
- E. Control of installation.
- F. Tolerances.
- G. Manufacturers' field services.
- H. Defect Assessment.

1.02 RELATED REQUIREMENTS

- A. Section 01 41 00 Regulatory Requirements.
- B. Section 01 42 00 References.

1.03 REFERENCE STANDARDS

- A. ASTM C1021 Standard Practice for Laboratories Engaged in Testing of Building Sealants; 2008 (Reapproved 2023).
- B. ASTM E329 Standard Specification for Agencies Engaged in Construction Inspection, Testing, or Special Inspection; 2021.
- C. ASTM E543 Standard Specification for Agencies Performing Nondestructive Testing; 2021.
- D. ASTM E699 Standard Specification for Agencies Involved in Testing, Quality Assurance, and Evaluating of Manufactured Building Components; 2016.
- E. IAS AC89 Accreditation Criteria for Testing Laboratories; 2021.

1.04 CONTRACTOR'S DESIGN-RELATED PROFESSIONAL DESIGN SERVICES

- A. Coordination: Contractor's professional design services are subject to requirements of project's Conditions for Construction Contract.
- B. Base design on performance and/or design criteria indicated in individual specification sections.
- C. Scope of Contractor's Professional Design Services: Provide for the following items of work:
 - 1. Fire Suppression: As described in Sections 21 05 00 & 21 13 00.
 - 2. Fire Detection and Alarm: As described in Section 28 46 00.

1.05 SUBMITTALS

A. See Section 01 30 00 - Submittals

- B. Designer's Qualification Statement: Submit for Architect/Engineer's knowledge as contract administrator, or for Owner's information.
 - 1. Include information for each individual professional responsible for producing, or supervising production of, design-related professional services provided by Contractor.
 - a. Full name.
 - b. Professional licensure information.
 - c. Statement addressing extent and depth of experience specifically relevant to design of items assigned to Contractor.
- C. Design Data: Submit for Architect/Engineer's knowledge as contract administrator for the limited purpose of assessing compliance with information given and the design concept expressed in the Contract Documents, or for Owner's information.
 - 1. Include calculations that have been used to demonstrate compliance to performance and regulatory criteria provided, and to determine design solutions.
 - 2. Include required product data and shop drawings.
 - 3. Include a statement or certification attesting that design data complies with criteria indicated, such as building codes, loads, functional, and similar engineering requirements.
 - 4. Include signature and seal of design professional responsible for allocated design services on calculations and drawings.
- D. Test Reports: After each test/inspection, promptly submit two copies of report to Architect/Engineer and to Contractor.
 - 1. Include:
 - a. Date issued.
 - b. Project title and number.
 - c. Name of inspector.
 - d. Date and time of sampling or inspection.
 - e. Identification of product and specifications section.
 - f. Location in the Project.
 - g. Type of test/inspection.
 - h. Date of test/inspection.
 - i. Results of test/inspection.
 - j. Compliance with Contract Documents.
 - k. When requested by Architect/Engineer, provide interpretation of results.
- E. Certificates: When specified in individual specification sections, submit certification by the manufacturer and Contractor or installation/application subcontractor to Architect/Engineer, in quantities specified for Product Data.
 - 1. Indicate material or product complies with or exceeds specified requirements. Submit supporting reference data, affidavits, and certifications as appropriate.
 - 2. Certificates may be recent or previous test results on material or product, but must be acceptable to Architect/Engineer.
- F. Manufacturer's Instructions: When specified in individual specification sections, submit printed instructions for delivery, storage, assembly, installation, start-up, adjusting, and finishing, for the Owner's information. Indicate special procedures, perimeter conditions requiring special attention, and special environmental criteria required for application or installation.

1.06 QUALITY ASSURANCE

- A. Testing Agency Qualifications:
 - 1. Prior to start of work, submit agency name, address, and telephone number, and names of full time registered Engineer and responsible officer.
 - Submit copy of report of laboratory facilities inspection made by NIST Construction Materials Reference Laboratory during most recent inspection, with memorandum of remedies of any deficiencies reported by the inspection.
- B. Designer Qualifications: Where professional engineering design services and design data submittals are specifically required of Contractor by Contract Documents, provide services of a Professional Engineer experienced in design of this type of work and licensed in the State in which the Project is located.

1.07 REGULATORY REQUIREMENTS - SEE SECTION 01 41 00

1.08 REFERENCES AND STANDARDS - SEE SECTION 01 42 00

1.09 TESTING AND INSPECTION AGENCIES AND SERVICES

- A. Contractor Employed Agency:
 - 1. Inspection agency: Comply with requirements of ASTM D3740 and ASTM E329.

PART 2 PRODUCTS - NOT USED

PART 3 EXECUTION

3.01 CONTROL OF INSTALLATION

- A. Monitor quality control over suppliers, manufacturers, products, services, site conditions, and workmanship, to produce work of specified quality.
- B. Comply with manufacturers' instructions, including each step in sequence.
- C. Should manufacturers' instructions conflict with Contract Documents, request clarification from Architect/Engineer before proceeding.
- D. Comply with specified standards as minimum quality for the work except where more stringent tolerances, codes, or specified requirements indicate higher standards or more precise workmanship.
- E. Have work performed by persons qualified to produce required and specified quality.
- F. Verify that field measurements are as indicated on shop drawings or as instructed by the manufacturer.
- G. Secure products in place with positive anchorage devices designed and sized to withstand stresses, vibration, physical distortion, and disfigurement.

3.02 TOLERANCES

A. Monitor fabrication and installation tolerance control of products to produce acceptable Work. Do not permit tolerances to accumulate.

- B. Comply with manufacturers' tolerances. Should manufacturers' tolerances conflict with Contract Documents, request clarification from Architect/Engineer before proceeding.
- C. Adjust products to appropriate dimensions; position before securing products in place.

3.03 TESTING AND INSPECTION

- A. See individual specification sections for testing required.
- B. Testing Agency Duties:
 - 1. Provide qualified personnel at site. Cooperate with Architect/Engineer and Contractor in performance of services.
 - 2. Perform specified sampling and testing of products in accordance with specified standards.
 - 3. Ascertain compliance of materials and mixes with requirements of Contract Documents.
 - 4. Promptly notify Architect/Engineer and Contractor of observed irregularities or non-compliance of Work or products.
 - 5. Perform additional tests and inspections required by Architect/Engineer.
 - 6. Submit reports of all tests/inspections specified.
- C. Limits on Testing/Inspection Agency Authority:
 - 1. Agency may not release, revoke, alter, or enlarge on requirements of Contract Documents.
 - 2. Agency may not approve or accept any portion of the Work.
 - 3. Agency may not assume any duties of Contractor.
 - 4. Agency has no authority to stop the Work.
- D. Contractor Responsibilities:
 - 1. Deliver to agency at designated location, adequate samples of materials proposed to be used that require testing, along with proposed mix designs.
 - 2. Cooperate with laboratory personnel, and provide access to the Work and to manufacturers' facilities.
 - 3. Provide incidental labor and facilities:
 - a. To provide access to Work to be tested/inspected.
 - b. To obtain and handle samples at the site or at source of Products to be tested/inspected.
 - c. To facilitate tests/inspections.
 - d. To provide storage and curing of test samples.
 - 4. Notify Architect/Engineer and laboratory 24 hours prior to expected time for operations requiring testing/inspection services.
 - 5. Employ services of an independent qualified testing laboratory and pay for additional samples, tests, and inspections required by Contractor beyond specified requirements.
 - 6. Arrange with Owner's agency and pay for additional samples, tests, and inspections required by Contractor beyond specified requirements.
- E. Re-testing required because of non-compliance with specified requirements shall be performed by the same agency on instructions by Architect/Engineer.
- F. Re-testing required because of non-compliance with specified requirements shall be paid for by Contractor.

3.04 MANUFACTURERS' FIELD SERVICES

- A. When specified in individual specification sections, require material or product suppliers or manufacturers to provide qualified staff personnel to observe site conditions, conditions of surfaces and installation, quality of workmanship as applicable, and to initiate instructions when necessary.
- B. Report observations and site decisions or instructions given to applicators or installers that are supplemental or contrary to manufacturers' written instructions.

3.05 DEFECT ASSESSMENT

- A. Replace Work or portions of the Work not complying with specified requirements.
- B. If, in the opinion of Architect/Engineer, it is not practical to remove and replace the work, Architect/Engineer will direct an appropriate remedy or adjust payment.

SECTION 01 41 00 REGULATORY REQUIREMENTS

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. General.
- B. Definitions.
- C. Quality Assurance.
- D. Regulatory Requirements.

1.02 RELATED SECTIONS

A. Section 01 42 00 - References.

1.03 GENERAL

- A. Comply with all applicable laws, rules, regulations, codes and ordinances.
- B. If the Contractor observes that the Contract Documents may be at variance with specified codes, notify the Architect/Engineer immediately. Architect/Engineer shall issue all changes in accordance with the General Conditions.
- C. It shall not be the Contractor's primary responsibility to make certain that the Contract Documents are in accordance with all applicable laws, rules and regulations, however, when the Contractor performs work knowing or having reason to know that the work in question is contrary to applicable laws, rules, and regulations, and fails to notify the Architect/Engineer, the Contractor shall pay all costs arising therefrom.

1.04 DEFINITIONS

- A. Definitions:
 - 1. Codes: Codes are statutory requirements, rules or regulations of governmental entities.
 - 2. Standards: Standards are requirements that have been established as accepted criteria, set general consent.

1.05 QUALITY ASSURANCE

- A. The Architect/Engineer has designed the project to applicable code requirements and has copies of said codes available for the Contractor's inspection.
- B. The Contractor shall:
 - 1. Ensure that copies of codes and standards referenced herein or specified in individual specifications sections are available to Contractor's personnel, agents, and Sub-Contractors.
 - 2. Ensure that Contractor's personnel, agents, and Sub-Contractors are familiar with the workmanship and requirements of applicable codes and standards.

1.06 REGULATORY REQUIREMENTS

- A. Source and Requirements: Verify amendments with local code officials.
 - 1. Local code requirements:
 - a. ICC International Building Code, 2015 Edition.

- b. ICC International Mechanical Code, 2015 Edition.
- c. ICC International Fire Code, 2015 Edition.
- d. ICC International Fuel and Gas Code, 2015 Edition.
- e. ICC International Existing Building Code, 2015 Edition.
- f. National Electrical Code, 2014 Edition. (NFPA 70)
- 2. State code requirements:
 - a. Capital Development Board (CDB):
 - 1) ICC A117.1 and its references to the 2018 Illinois Accessibility Code.
 - 2) Illinois Energy Conservation Code (ICC) International Energy Conservation Code, 2021 Edition, with State of Illinois modifications.
 - b. Illinois Department of Labor (IDOL): Safety Glazing Materials Act Illinois Revised Statutes, chap. 111 1/2, paragraph 3101, et seq.
 - c. Illinois Department of Public Health (IDPH):
 - 1) Illinois Plumbing Code (Illinois Administrative Code, Title 77, Chapter I, Subchapter r, Part 890) Latest edition.
 - d. Illinois Environmental Protection Agency (IEPA):
 - 1) Air-Pollution Standards.
 - 2) Noise Pollution Standards.
 - 3) Water Pollution Standards.
 - 4) Public Water Supplies
 - 5) Solid Waste Standards.
 - 6) Illinois Recommended Standards for Sewage Works (Illinois Administrative Code, Title 35, Subtitle C, Chapter II, Part 370).
 - e. Illinois State Fire Marshal (OSFM):
 - 1) Boiler & Pressure Vessel Safety Code (Illinois Administrative Code, Title 44, Chapter I, Part 120).
 - 2) Illinois Rules & Regulations for Fire Prevention & Safety (as amended).
 - 3) Gasoline and Volatile Oils (Illinois Revised Statutes, chap. 17 1/2, paragraph 31, et seq.).
- 3. Information and Requirements for Utility Services: Local utility companies.

PART 2 PRODUCTS - NOT USED

PART 3 EXECUTION - NOT USED

SECTION 01 42 00 REFERENCES

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Drawing symbols, abbreviations and acronyms.
- B. Definitions of terms used throughout the Contract Documents.
- C. Explanation of specification format and content.
- D. Requirements relating to referenced standards.
- E. Applicability of referenced standards.
- F. List of industry organizations and certain of their respective documents.

1.02 DRAWING SYMBOLS AND CONVENTIONS

- A. Abbreviations and graphic symbols are defined on the General Notes, Symbols & Abbreviations sheet of the drawings.
- B. Generally, symbols used on the mechanical and electrical drawings conform to those recommended by ASHRAE, though, where appropriate, these symbols are supplemented by more specific symbols as recommended by ASME, ASPE, or the IEEE.

1.03 DEFINITIONS

- A. Where the terms "indicated", "noted", "scheduled", "shown", or "specified" are used it is to help locate the reference; no limitation on location is intended except as specifically noted.
- B. Where the terms "directed", "requested", "authorized", "approved", are used as in "directed by the Architect/Engineer", no implied meaning shall be construed to extend the Architect/Engineer's responsibilities into the Contractor's purview of construction supervision.
- C. Where the term "approved" is used in conjunction with the Architect/Engineer's action on submittals, requests or applications it is limited to the duties of the Architect/Engineer as described in the Agreement, and the General and Supplemental Conditions of the Contract. Such use of the term "approval" shall not limit or release the Contractor from his responsibility to fulfill Contract requirements.
- D. Where the term "regulations" is used it means all applicable statutes, laws, ordinances, and orders issued by authorities having jurisdiction, as well as construction industry standards, rules, or conventions that address performance of the Work.
- E. Where the term "furnish" is used it means supply, deliver, and unload to the construction site ready for assembly and incorporation into the Work.
- F. Where the term "install" is used it is meant to describe operations at the job site to include unloading, assembling, placing, anchoring, finishing, protecting, cleaning and all other similar operations required to fully incorporate an item into the Work.
- G. Where the term "provide" is used it means "furnish and install" as defined above.

H. The "Project Site" is the space available to the Contractor for performance of construction activities. The Project Site may be for the exclusive use of the Contractor and his activities or may be used in conjunction with others with others performing other construction or related activities on the Project. The Extent of the Project Site is indicated on the drawings.

1.04 SPECIFICATION FORMAT AND CONTENT

- A. These Specifications are based on the Construction Specification Institute's 49 Division format and numbering system.
- B. Language used in the Specifications and other Contract Documents is an abbreviated type. Implied words and meanings will appropriately interpreted.
- C. Requirements expressed in imperative and streamlined language are to be performed by the Contractor. At certain locations in the text, subjective language may be used to describe responsibilities that must be fulfilled indirectly by the Contractor or others.
 - 1. Whenever a colon (:) is used within a sentence or phrase, it shall be construed to mean the words "shall be".
- D. Use of certain terms such as "carpentry" is not intended to imply that certain activities must be performed by accredited or unionized individuals of a corresponding generic name. The Specifications do, however, require that certain construction activities shall be performed by specialists who are recognized experts in the operations to be performed. Specialists shall be used for said activities, however the final responsibility for fulfilling the requirements of the Contract remains the Contractor's.

1.05 QUALITY ASSURANCE

- A. For products or workmanship specified by reference to a document or documents not included in the Project Manual, also referred to as reference standards, comply with requirements of the standard, except when more rigid requirements are specified or are required by applicable codes.
- B. Conform to reference standard of date of issue specified in this section, except where a specific date is established by applicable code.
- C. Obtain copies of standards when required by the Contract Documents.
- D. Maintain copy at project site during submittals, planning, and progress of the specific work, until Substantial Completion.
- E. Should specified reference standards conflict with Contract Documents, request clarification from the Architect/Engineer before proceeding.
- F. Neither the contractual relationships, duties, or responsibilities of the parties in Contract nor those of the Architect/Engineer shall be altered by the Contract Documents by mention or inference otherwise in any reference document.

1.06 APPLICABILITY OF INDUSTRY STANDARDS

A. Construction industry standards shall have the same force and effect as if bound or copied directly in the Contract Documents, except where more stringent requirements are specified. All such applicable standards are made a part of the Contract Documents by reference.

- 1. Where compliance with two or more standards are referenced and conflicting requirements for quality or quantities occur, comply with the more stringent requirements. Refer questions regarding apparently conflicting standards to the Architect for a decision before proceeding.
- 2. The standard of quality or quantity levels specified, shown, or referenced shall be the minimum to be provided or performed. Refer questions regarding standards of minimum quality or quantity to the Architect before proceeding.

1.07 CONSTRUCTION INDUSTRY ORGANIZATIONS AND DOCUMENTS

- A. AABC -- ASSOCIATED AIR BALANCE COUNCIL
- B. AAMA -- AMERICAN ARCHITECTURAL MANUFACTURERS ASSOCIATION
- C. ACI -- AMERICAN CONCRETE INSTITUTE INTERNATIONAL
- D. ADC -- AIR DIFFUSION COUNCIL
- E. AGA -- AMERICAN GAS ASSOCIATION
- F. ANSI -- AMERICAN NATIONAL STANDARDS INSTITUTE
- G. APA -- APA THE ENGINEERED WOOD ASSOCIATION
- H. ASCA -- ARCHITECTURAL SPRAY COATERS ASSOCIATION
- I. ASHRAE -- AMERICAN SOCIETY OF HEATING, REFRIGERATING AND AIR-CONDITIONING ENGINEERS, INC.
- J. ASME -- THE AMERICAN SOCIETY OF MECHANICAL ENGINEERS 1. ASME A17.1 - Safety Code for Elevators and Escalators; 2004.
- K. ASTM -- AMERICAN SOCIETY FOR TESTING AND MATERIALS
- L. AWI -- ARCHITECTURAL WOODWORK INSTITUTE
- M. AWPA -- AMERICAN WOOD-PRESERVERS' ASSOCIATION
- N. BHMA -- BUILDERS HARDWARE MANUFACTURERS ASSOCIATION
- O. CISCA -- CEILINGS & INTERIOR SYSTEMS CONSTRUCTION ASSOCIATION
- P. CPSC -- CONSUMER PRODUCTS SAFETY COMMISSION
- Q. CRI -- CARPET AND RUG INSTITUTE
- R. CTI -- COOLING TECHNOLOGY INSTITUTE
- S. DHI -- DOOR AND HARDWARE INSTITUTE
- T. ESD -- ELECTROSTATIC DISCHARGE ASSOCIATION
- U. FM -- FACTORY MUTUAL RESEARCH CORPORATION
- V. GA -- GYPSUM ASSOCIATION
- W. GANA -- GLASS ASSOCIATION OF NORTH AMERICA
- X. GREENSEAL -- GREEN SEAL

- Y. ICC -- INTERNATIONAL CODE COUNCIL, INC.
- Z. IEEE -- INSTITUTE OF ELECTRICAL AND ELECTRONIC ENGINEERS
- AA. ISO -- INTERNATIONAL STANDARDS ORGANIZATION
- BB. MPI -- MASTER PAINTERS INSTITUTE (MASTER PAINTERS AND DECORATORS ASSOCIATION)
- CC. NAAMM -- THE NATIONAL ASSOCIATION OF ARCHITECTURAL METAL MANUFACTURERS
- DD. NCMA -- NATIONAL CONCRETE MASONRY ASSOCIATION
- EE. NEBB -- NATIONAL ENVIRONMENTAL BALANCING BUREAU
- FF. NECA -- NATIONAL ELECTRICAL CONTRACTORS ASSOCIATION
- GG. NELMA -- NORTHEASTERN LUMBER MANUFACTURERS ASSOCIATION, INC.
- HH. NEMA -- NATIONAL ELECTRICAL MANUFACTURERS ASSOCIATION
- II. NFPA -- NATIONAL FIRE PROTECTION ASSOCIATION
- JJ. NGA -- NATIONAL GAS ASSOCIATION
- KK. NPCA -- NATIONAL PAINT AND COATINGS ASSOCIATION
- LL.NRCA -- NATIONAL ROOFING CONTRACTORS ASSOCIATION
- MM. PCA -- PORTLAND CEMENT ASSOCIATION
- NN. PIMA -- POLYISOCYANURATE INSULATION MANUFACTURERS ASSOCIATION
- 00. SDI -- STEEL DOOR INSTITUTE
- PP. SGCC -- SAFETY GLAZING CERTIFICATION COUNCIL
- QQ. SIGMA SEALED INSULATING GLASS MANUFACTURERS ASSOCIATION (See IGMA)
- RR. SMACNA -- SHEET METAL AND AIR CONDITIONING CONTRACTORS' NATIONAL ASSOCIATION, INC.
- SS. SSPC -- THE SOCIETY FOR PROTECTIVE COATINGS
- TT. SWRI -- SEALANT, WATERPROOFING AND RESTORATION INSTITUTE
- UU. UL -- UNDERWRITERS LABORATORIES INC.
- VV. USG -- UNITED STATES GYPSUM
 - 1. USG (HB) Gypsum Construction Handbook; Seventh Edition.
- WW. USGBC -- U. S. GREEN BUILDING COUNCIL
- XX. WWPA -- WESTERN WOOD PRODUCTS ASSOCIATION

1.08 UNITED STATES GOVERNMENT AND RELATED AGENCIES/DOCUMENTS

A. CFR -- CODE OF FEDERAL REGULATIONS

- B. CPSC -- CONSUMER PRODUCTS SAFETY COMMISSION
- C. EPA -- ENVIRONMENTAL PROTECTION AGENCY
- D. FS -- FEDERAL SPECIFICATIONS AND STANDARDS (General Services Administration)
- E. GSA -- U.S. GENERAL SERVICES ADMINISTRATION
- F. USGS -- UNITED STATES GEOLOGICAL SURVEY

1.09 STATE GOVERNMENT AND RELATED AGENCIES/DOCUMENTS

- A. CDB -- ILLINOIS CAPITAL DEVELOPMENT BOARD
- B. IDOL -- ILLINOIS DEPARTMENT OF LABOR
- C. IDPH -- ILLINOIS DEPARTMENT OF PUBLIC HEALTH
- D. IEPA -- ILLINOIS ENVIRONMENTAL PROTECTION AGENCY
- E. OSFM -- OFFICE OF THE ILLINOIS STATE FIRE MARSHAL.

PART 2 PRODUCTS - NOT USED

PART 3 EXECUTION - NOT USED

SECTION 01 50 00 TEMPORARY FACILITIES AND CONTROLS

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Temporary utilities.
- B. Temporary telecommunications services.
- C. Temporary sanitary facilities.
- D. Temporary Controls: Barriers, enclosures, and fencing.
- E. Security requirements.
- F. Vehicular access and parking.
- G. Waste removal facilities and services.

1.02 TEMPORARY UTILITIES

- A. Owner will provide the following:
 - 1. Electrical power, consisting of connection to existing facilities.
- B. Existing facilities may be used.

1.03 TELECOMMUNICATIONS SERVICES

- A. Provide, maintain, and pay for telecommunications services to field office at time of project mobilization.
- B. Telecommunications services shall include:
 - 1. One (1) mobile cellular telephone for each of Contractor's and any Subcontractor's field personnel.

1.04 TEMPORARY SANITARY FACILITIES

- A. Use of existing facilities located at lower level is permitted.
- B. Maintain daily in clean and sanitary condition.
- C. At end of construction, return facilities to same or better condition as originally found.

1.05 BARRIERS

- A. Provide barriers to prevent unauthorized entry to construction areas, to prevent access to areas that could be hazardous to workers or the public, to allow for owner's use of site and to protect existing facilities and adjacent properties from damage from construction operations and demolition.
- B. Provide barricades and covered walkways required by governing authorities for public rights-of-way and for public access to existing building.
- C. Protect non-owned vehicular traffic, stored materials, site, and structures from damage.

1.06 INTERIOR ENCLOSURES.

- A. Provide temporary partitions and ceilings as indicated to separate work areas from Owneroccupied areas, to prevent penetration of dust and moisture into Owner-occupied areas, and to prevent damage to existing materials and equipment.
- B. Construction: Framing and reinforced polyethylene sheet materials with closed joints and sealed edges at intersections with existing surfaces:

1.07 SECURITY

A. Provide security and facilities to protect Work, existing facilities, and Owner's operations from unauthorized entry, vandalism, or theft.

1.08 VEHICULAR ACCESS AND PARKING

- A. Comply with regulations relating to use of streets and sidewalks, access to emergency facilities, and access for emergency vehicles.
- B. Coordinate access and haul routes with governing authorities and Owner.
- C. Provide and maintain access to fire hydrants, free of obstructions.
- D. Provide means of removing mud from vehicle wheels before entering streets.
- E. Provide temporary parking areas to accommodate construction personnel. When site space is not adequate, provide additional off-site parking.
- F. Crane access to be along alley on east side of the building. Owner will remove and re-install the string lighting.

1.09 WASTE REMOVAL

- A. Provide waste removal facilities and services as required to maintain the site in clean and orderly condition.
- B. Provide containers with lids. Remove trash from site periodically.
- C. If materials to be recycled or re-used on the project must be stored on-site, provide suitable noncombustible containers; locate containers holding flammable material outside the structure unless otherwise approved by the authorities having jurisdiction.
- D. Open free-fall chutes are not permitted. Terminate closed chutes into appropriate containers with lids.
- E. Coordinate with Owner on dumpster locations. Anticipated location to be along Galena Road.

PART 2 PRODUCTS - NOT USED

PART 3 EXECUTION - NOT USED

SECTION 01 60 00 PRODUCT REQUIREMENTS

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. General product requirements.
- B. Transportation, handling, storage and protection.
- C. Product option requirements.
- D. Substitution limitations.
- E. Procedures for Owner-supplied products.
- F. Maintenance materials, including extra materials, spare parts, tools, and software.

1.02 SUBMITTALS

- A. Product Data Submittals: Submit manufacturer's standard published data. Mark each copy to identify applicable products, models, options, and other data. Supplement manufacturers' standard data to provide information specific to this Project.
- B. Shop Drawing Submittals: Prepared specifically for this Project; indicate utility and electrical characteristics, utility connection requirements, and location of utility outlets for service for functional equipment and appliances.
- C. Sample Submittals: Illustrate functional and aesthetic characteristics of the product, with integral parts and attachment devices. Coordinate sample submittals for interfacing work.
 - 1. For selection from standard finishes, submit samples of the full range of the manufacturer's standard colors, textures, and patterns.

PART 2 PRODUCTS

2.01 NEW PRODUCTS

- A. Provide new products unless specifically required or permitted by Contract Documents.
- B. Designed, manufactured, and tested in accordance with industry standards.

2.02 PRODUCT OPTIONS

- A. Products Specified by Reference Standards or by Description Only: Use any product meeting those standards or description.
- B. Products Specified by Naming One or More Manufacturers: Use a product of one of the manufacturers named and meeting specifications, or equal to or superior product as approved by Architect in accordance with Section L of the Instruction to Bidders.
- C. Products Specified by Naming One or More Manufacturers with a Provision for Substitutions: Submit a request for equal to or superior to substitution for any manufacturer not named.

2.03 MAINTENANCE MATERIALS

- A. Furnish extra materials, spare parts, tools, and software of types and in quantities specified in individual specification sections.
- B. Deliver to Project site; obtain Owner's signature on receipt for delivery prior to final payment. Submit signed receipts with Closeout Submittals.

PART 3 EXECUTION

3.01 SUBSTITUTION LIMITATIONS

- A. Substitutions Prior To Bid Opening: Architect/Engineer will consider a written request for substitution provided that such request is received at least seven (7) days prior to the Bid opening date. Requests received after that time will not be considered.
 - 1. If a request is approved, the Architect/Engineer will issue and appropriate addendum not less than three (3) days prior to the Bid opening date.
- B. Substitutions After Notice of Award: Architect/Engineer and Owner will consider a request for substitution only under one or more of the following conditions:
 - 1. Substitution is required for compliance with final interpretation of code requirements or insurance regulations.
 - 2. Specified product is not available through no fault of the Contractor.
 - 3. Specified product is not compatible with other specified materials/equipment.
 - 4. Manufacturer will not certify or warranty specified product as required.
 - 5. Owner shall have final approval of any substitutions requested after notice of award in accordance with Section 3.01B.
- C. A request for substitution constitutes a representation that the submitter:
 - 1. Has investigated proposed product and determined that it meets or exceeds the quality level of the specified product.
 - 2. Agrees to provide the same warranty for the substitution as for the specified product.
 - 3. Agrees to coordinate installation and make changes to other Work that may be required for the Work to be complete with no additional cost to Owner.
 - 4. Waives claims for additional costs or time extension that may subsequently become apparent.
 - 5. Agrees to reimburse Owner and Architect/Engineer for review or redesign services associated with re-approval by authorities having jurisdiction over the Project.
- D. Substitutions of products or product characteristics/components/accessories will not be considered when they are indicated or implied on Contractor's submittals, without separate written request, or when acceptance will require revision to the Contract Documents, whether rejection of said substitutions is expressly identified by Architect/Engineer on Contractor's submittals or not.

3.02 OWNER-SUPPLIED PRODUCTS

- A. See Section 01 10 00 Summary for identification of Owner-supplied products.
- B. Owner's Responsibilities:
 - 1. Arrange for and deliver Owner reviewed shop drawings, product data, and samples, to Contractor.
 - 2. Arrange and pay for product delivery to site.
 - 3. On delivery, inspect products jointly with Contractor.

- 4. Submit claims for transportation damage and replace damaged, defective, or deficient items.
- 5. Arrange for manufacturers' warranties, inspections, and service.
- C. Contractor's Responsibilities:
 - 1. Review Owner reviewed shop drawings, product data, and samples.
 - 2. Receive and unload products at site; inspect for completeness or damage jointly with Owner.
 - 3. Handle, store, install and finish products.
 - 4. Repair or replace items damaged after receipt.
 - 5. Make final connections to Owner-provided equipment, and test equipment.

3.03 TRANSPORTATION AND HANDLING

- A. Package products for shipment in manner to prevent damage; for equipment, package to avoid loss of factory calibration.
- B. If special precautions are required, attach instructions prominently and legibly on outside of packaging.
- C. Coordinate schedule of product delivery to designated prepared areas in order to minimize site storage time and potential damage to stored materials.
- D. Transport and handle products in accordance with manufacturer's instructions.
- E. Transport materials in covered trucks to prevent contamination of product and littering of surrounding areas.
- F. Promptly inspect shipments to ensure that products comply with requirements, quantities are correct, and products are undamaged.
- G. Provide equipment and personnel to handle products by methods to prevent soiling, disfigurement, or damage, and to minimize handling.
- H. Arrange for the return of packing materials, such as wood pallets, where economically feasible.

3.04 STORAGE AND PROTECTION

- A. Designate receiving/storage areas for incoming products so that they are delivered according to installation schedule and placed convenient to work area in order to minimize waste due to excessive materials handling and misapplication.
- B. Store and protect products in accordance with manufacturers' instructions.
- C. Store with seals and labels intact and legible.
- D. Store sensitive products in weathertight, climate-controlled enclosures in an environment favorable to product.
- E. For exterior storage of fabricated products, place on sloped supports above ground.
- F. Protect products from damage or deterioration due to construction operations, weather, precipitation, humidity, temperature, sunlight and ultraviolet light, dirt, dust, and other contaminants.
- G. Comply with manufacturer's warranty conditions, if any.

- H. Cover products subject to deterioration with impervious sheet covering. Provide ventilation to prevent condensation and degradation of products.
- I. Prevent contact with material that may cause corrosion, discoloration, or staining.
- J. Provide equipment and personnel to store products by methods to prevent soiling, disfigurement, or damage.
- K. Arrange storage of products to permit access for inspection. Periodically inspect to verify products are undamaged and are maintained in acceptable condition.



SUBSTITUTION REQUEST FORM

Project Name:	FINANCE DEPARTMENT INTERIOR RENOVATION
Project No.:	24-130-1552
Owner:	CITY OF AURORA

SPECIFIED ITEM:

Specification Section Page

Page Paragraph

Description

The undersigned requests consideration of the following:

PROPOSED SUBSTITUTION:

Attached data includes project description, specifications, drawings, photographs, performance and test data adequate for evaluation of the request; applicable portions of the data are clearly identified.

Attached data also includes a description of changes to the Contract Documents which the proposed substitution will require for its proper installation.

The undersigned certifies that the following paragraphs, unless modified by attachments, are correct:

- 1. The proposed substitution does not affect dimensions shown on drawings.
- 2. The undersigned will pay for changes to the building design, including engineering design, detailing, and construction costs caused by the requested substitution.
- The proposed substitution will have no adverse effect on other trades, the construction schedule, or specified warranty requirements.
- 4. Maintenance and service parts will be locally available for the proposed substitution.

The undersigned further states that the function, appearance, and quality of the proposed substitution are equivalent or superior to the specified item.

<u></u>		For Use By The Architect/Engineer:	
Printed Name		Accepted	Accepted As Noted
Signature	Date		Received Too Late
Firm		Bv:	
Telephone		Date:	
Email Attachments (list):		Remarks:	

Bloomington OfficeAurora Office2401 East Washington Street41 W. Benton StreetBloomington, Illinois 61704Aurora, Illinois 60506309.430.6460630.406.1213

SECTION 01 61 16 VOLATILE ORGANIC COMPOUND (VOC) CONTENT RESTRICTIONS

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Requirements for Indoor-Emissions-Restricted products.
- B. Requirements for VOC-Content-Restricted products.

1.02 DEFINITIONS

- A. Indoor-Emissions-Restricted Products: All products in the following product categories, whether specified or not:
- B. VOC-Content-Restricted Products: All products in the following product categories, whether specified or not:
 - 1. Interior paints and coatings applied on site.
 - 2. Interior adhesives and sealants applied on site, including flooring adhesives.
- C. Interior of Building: Anywhere inside the exterior weather barrier.
- D. Adhesives: All gunnable, trowelable, liquid-applied, and aerosol adhesives, whether specified or not; including flooring adhesives, resilient base adhesives, and pipe jointing adhesives.
- E. Sealants: All gunnable, trowelable, and liquid-applied joint sealants and sealant primers, whether specified or not; including firestopping sealants and duct joint sealers.
- F. Inherently Non-Emitting Materials: Products composed wholly of minerals or metals, unless they include organic-based surface coatings, binders, or sealants; and specifically the following:
 - 1. Concrete.
 - 2. Clay brick.
 - 3. Metals that are plated, anodized, or powder-coated.
 - 4. Glass.
 - 5. Ceramics.
 - 6. Solid wood flooring that is unfinished and untreated.

1.03 REFERENCE STANDARDS

- A. 40 CFR 59, Subpart D National Volatile Organic Compound Emission Standards for Architectural Coatings; U.S. Environmental Protection Agency; current edition.
- B. ASTM D3960 Standard Practice for Determining Volatile Organic Compound (VOC) Content of Paints and Related Coatings; 2005 (Reapproved 2018).
- C. CARB (SCM) Suggested Control Measure for Architectural Coatings; California Air Resources Board; 2007.
- D. SCAQMD 1113 Architectural Coatings; 1977 (Amended 2016).
- E. SCAQMD 1168 South Coast Air Quality Management District Rule No.1168; current edition.

1.04 SUBMITTALS

A. Product Data: For each VOC-restricted product used in the project, submit evidence of compliance.

1.05 QUALITY ASSURANCE

- A. VOC Content Test Method: 40 CFR 59, Subpart D (EPA Method 24), or ASTM D3960, unless otherwise indicated.
 - 1. Evidence of Compliance: Acceptable types of evidence are:
 - a. Report of laboratory testing performed in accordance with requirements.
- B. Testing Agency Qualifications: Independent firm specializing in performing testing and inspections of the type specified in this section.

PART 2 PRODUCTS

2.01 MATERIALS

- A. VOC-Content-Restricted Products: VOC content not greater than required by the following:
 - 1. Adhesives, Including Flooring Adhesives: SCAQMD 1168 Rule.
 - 2. Joint Sealants: SCAQMD 1168 Rule.
 - 3. Paints and Coatings: Each color; most stringent of the following:
 - a. 40 CFR 59, Subpart D.
 - b. SCAQMD 1113 Rule.
 - c. CARB (SCM).

PART 3 EXECUTION

3.01 FIELD QUALITY CONTROL

- A. Owner reserves the right to reject non-compliant products, whether installed or not, and require their removal and replacement with compliant products at no extra cost to Owner.
- B. Additional costs to restore indoor air quality due to installation of non-compliant products will be borne by Contractor.

SECTION 01 61 16.01 ACCESSORY MATERIAL VOC CONTENT CERTIFICATION FORM

PART 1

1.01 IDENTIFICATION:

- A. Project Name: _____
- B. Project No.: _____
- C. Architect/Engineer: _____

1.02 USE OF THIS FORM:

- A. Because installers are allowed and directed to choose accessory materials suitable for the applicable installation, there is a possibility that such accessory materials might contain VOC content in excess of that permitted, especially where such materials have not been explicitly specified.
- B. Contractor is required to obtain and submit this form from each installer of work on this project.
- C. For each product category listed, circle the correct words in brackets: either [HAS] or [HAS NOT].
- D. If any of these accessory materials has been used, attach to this form product data and MSDS sheet for each such product.

1.03 VOC CONTENT RESTRICTIONS ARE SPECIFIED IN SECTION 01 61 16.

PART 2

2.01 PRODUCT CERTIFICATION

- A. I certify that the installation work of my firm on this project:
 - 1. [HAS] [HAS NOT] required the use of any ADHESIVES.
 - 2. [HAS] [HAS NOT] required the use of any JOINT SEALANTS.
 - 3. [HAS] [HAS NOT] required the use of any PAINTS OR COATINGS.
 - 4. [HAS] [HAS NOT] required the use of any COMPOSITE WOOD or AGRIFIBER PRODUCTS.
- B. Product data and MSDS sheets are attached.

PART 3

3.01 CERTIFIED BY: (INSTALLER/MANUFACTURER/SUPPLIER FIRM)

- A. Firm Name:
- B. Print Name: _____
- C. Signature: _____
- D. Title: _____ (officer of company)
- E. Date: _____

SECTION 01 70 00 EXECUTION AND CLOSEOUT REQUIREMENTS

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Examination, preparation, and general installation procedures.
- B. Requirements for alterations work, including selective demolition, except removal, disposal, and/or remediation of hazardous materials and toxic substances.
- C. Pre-installation meetings.
- D. Cutting and patching.
- E. Cleaning and protection.
- F. Starting of systems and equipment.
- G. Closeout procedures, including Contractor's Correction Punch List, except payment procedures.
- H. General requirements for maintenance service.

1.02 RELATED REQUIREMENTS

- A. Section 01 10 00 Summary: Limitations on working in existing building; continued occupancy; work sequence; identification of salvaged and relocated materials.
- B. Section 01 30 00 Administrative Requirements: Submittals procedures, Electronic document submittal service.
- C. Section 01 50 00 Temporary Facilities and Controls: Temporary interior partitions.
- D. Section 01 77 00 Closeout Procedures: Additional requirements for Project Closeout.
- E. Section 01 78 00 Closeout Submittals: Project record documents, operation and maintenance data, warranties and bonds.
- F. Section 07 84 00 Firestopping.

1.03 REFERENCE STANDARDS

A. NFPA 241 - Standard for Safeguarding Construction, Alteration, and Demolition Operations; 2013.

1.04 SUBMITTALS

- A. See Section 01 30 00 Administrative Requirements, for submittal procedures.
- B. Cutting and Patching: Submit written request in advance of cutting or alteration that affects:
 - 1. Structural integrity of any element of Project.
 - 2. Integrity of weather exposed or moisture resistant element.
 - 3. Efficiency, maintenance, or safety of any operational element.
 - 4. Visual qualities of sight exposed elements.
 - 5. Work of Owner or separate Contractor.
 - 6. Include in request:
 - a. Identification of Project.

- b. Location and description of affected work.
- c. Necessity for cutting or alteration.
- d. Description of proposed work and products to be used.
- e. Alternatives to cutting and patching.
- f. Effect on work of Owner or separate Contractor.
- g. Written permission of affected separate Contractor.
- h. Date and time work will be executed.
- C. Project Record Documents: Accurately record actual locations of capped and active utilities.

1.05 PROJECT CONDITIONS

- A. Ventilate enclosed areas to assist cure of materials, to dissipate humidity, and to prevent accumulation of dust, fumes, vapors, or gases.
- B. Dust Control: Execute work by methods to minimize raising dust from construction operations. Provide positive means to prevent air-borne dust from dispersing into atmosphere and over adjacent property.
 - 1. Provide dust-proof enclosures to prevent entry of dust generated outdoors.
 - Provide dust-proof barriers between construction areas and areas continuing to be occupied by Owner.
- C. Noise Control: Provide methods, means, and facilities to minimize noise produced by construction operations.
 - 1. At All Times: Excessively noisy tools and operations will not be tolerated inside the building at any time of day; excessively noisy includes jackhammers.
 - 2. Outdoors: Limit conduct of especially noisy exterior work to the hours of 8 am to 5 pm.
 - 3. Indoors: Limit conduct of especially noisy interior work to the hours of 6 pm to 7 am.
- D. Pest and Rodent Control: Provide methods, means, and facilities to prevent pests and insects from damaging the work.
- E. Rodent Control: Provide methods, means, and facilities to prevent rodents from accessing or invading premises.
- F. Pollution Control: Provide methods, means, and facilities to prevent contamination of soil, water, and atmosphere from discharge of noxious, toxic substances, and pollutants produced by construction operations. Comply with federal, state, and local regulations.

1.06 COORDINATION

- A. See Section 01 10 00 for occupancy-related requirements.
- B. Coordinate scheduling, submittals, and work of the various sections of the Project Manual to ensure efficient and orderly sequence of installation of interdependent construction elements, with provisions for accommodating items installed later.
- C. Notify affected utility companies and comply with their requirements.
- D. Verify that utility requirements and characteristics of new operating equipment are compatible with building utilities. Coordinate work of various sections having interdependent responsibilities for installing, connecting to, and placing in service, such equipment.
- E. Coordinate space requirements, supports, and installation of mechanical and electrical work that are indicated diagrammatically on drawings. Follow routing indicated for pipes, ducts, and conduit, as closely as practicable; place runs parallel with lines of building. Utilize spaces efficiently to maximize accessibility for other installations, for maintenance, and for repairs.
- F. In finished areas except as otherwise indicated, conceal pipes, ducts, and wiring within the construction. Coordinate locations of fixtures and outlets with finish elements.
- G. Coordinate completion and clean-up of work of separate sections.
- H. After Owner occupancy of premises, coordinate access to site for correction of defective work and work not in accordance with Contract Documents, to minimize disruption of Owner's activities.

PART 2 PRODUCTS

2.01 PATCHING MATERIALS

- A. New Materials: As specified in product sections; match existing products and work for patching and extending work.
- B. Type and Quality of Existing Products: Determine by inspecting and testing products where necessary, referring to existing work as a standard.
- C. Product Substitution: For any proposed change in materials, submit request for substitution described in Section 01 60 00 Product Requirements.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify that existing site conditions and substrate surfaces are acceptable for subsequent work. Start of work means acceptance of existing conditions.
- B. Verify that existing substrate is capable of structural support or attachment of new work being applied or attached.
- C. Examine and verify specific conditions described in individual specification sections.
- D. Take field measurements before confirming product orders or beginning fabrication, to minimize waste due to over-ordering or misfabrication.
- E. Verify that utility services are available, of the correct characteristics, and in the correct locations.
- F. Prior to Cutting: Examine existing conditions prior to commencing work, including elements subject to damage or movement during cutting and patching. After uncovering existing work, assess conditions affecting performance of work. Beginning of cutting or patching means acceptance of existing conditions.

3.02 PREPARATION

- A. Clean substrate surfaces prior to applying next material or substance.
- B. Seal cracks or openings of substrate prior to applying next material or substance.
- C. Apply manufacturer required or recommended substrate primer, sealer, or conditioner prior to applying any new material or substance in contact or bond.

3.03 PREINSTALLATION MEETINGS

- A. When required in individual specification sections, convene a preinstallation meeting at the site prior to commencing work of the section.
- B. Require attendance of parties directly affecting, or affected by, work of the specific section.
- C. Notify Architect/Engineer four days in advance of meeting date.
- D. Prepare agenda and preside at meeting:
 - 1. Review conditions of examination, preparation and installation procedures.
 - 2. Review coordination with related work.
- E. Record minutes and distribute copies within two days after meeting to participants, with two copies to Architect/Engineer, Owner, participants, and those affected by decisions made.

3.04 GENERAL INSTALLATION REQUIREMENTS

- A. In addition to compliance with regulatory requirements, conduct construction operations in compliance with NFPA 241, including applicable recommendations in Appendix A.
- B. Install products as specified in individual sections, in accordance with manufacturer's instructions and recommendations, and so as to avoid waste due to necessity for replacement.
- C. Make vertical elements plumb and horizontal elements level, unless otherwise indicated.
- D. Install equipment and fittings plumb and level, neatly aligned with adjacent vertical and horizontal lines, unless otherwise indicated.
- E. Make consistent texture on surfaces, with seamless transitions, unless otherwise indicated.
- F. Make neat transitions between different surfaces, maintaining texture and appearance.

3.05 ALTERATIONS

- A. Drawings showing existing construction and utilities are based on casual field observation and existing record documents only.
 - 1. Verify that construction and utility arrangements are as indicated.
 - 2. Report discrepancies to Architect/Engineer before disturbing existing installation.
 - 3. Beginning of alterations work constitutes acceptance of existing conditions.
- B. Keep areas in which alterations are being conducted separated from other areas that are still occupied.
 - 1. Provide, erect, and maintain temporary dustproof partitions of construction specified in Section 01 50 00 in locations indicated on drawings.
 - 2. Provide sound retardant partitions of construction indicated on drawings in locations indicated on drawings.
- C. Maintain weatherproof exterior building enclosure except for interruptions required for replacement or modifications; take care to prevent water and humidity damage.
 - 1. Where openings in exterior enclosure exist, provide construction to make exterior enclosure weatherproof.
 - 2. Insulate existing ducts or pipes that are exposed to outdoor ambient temperatures by alterations work.

- D. Remove existing work as indicated and as required to accomplish new work.
 - 1. Remove rotted wood, corroded metals, and deteriorated masonry and concrete; replace with new construction specified.
 - 2. Remove items indicated on drawings.
 - 3. Relocate items indicated on drawings.
 - 4. Where new surface finishes are to be applied to existing work, perform removals, patch, and prepare existing surfaces as required to receive new finish; remove existing finish if necessary for successful application of new finish.
 - 5. Where new surface finishes are not specified or indicated, patch holes and damaged surfaces to match adjacent finished surfaces as closely as possible.
- E. Services (Including but not limited to HVAC, Plumbing, Fire Protection, Electrical, and Telecommunications): Remove, relocate, and extend existing systems to accommodate new construction.
 - 1. Maintain existing active systems that are to remain in operation; maintain access to equipment and operational components; if necessary, modify installation to allow access or provide access panel.
 - Where existing systems or equipment are not active and Contract Documents require reactivation, put back into operational condition; repair supply, distribution, and equipment as required.
 - Where existing active systems serve occupied facilities but are to be replaced with new services, maintain existing systems in service until new systems are complete and ready for service.
 - a. Disable existing systems only to make switchovers and connections; minimize duration of outages.
 - b. See Section 01 10 00 for other limitations on outages and required notifications.
 - c. Provide temporary connections as required to maintain existing systems in service.
 - 4. Verify that abandoned services serve only abandoned facilities.
 - 5. Remove abandoned pipe, ducts, conduits, and equipment; remove back to source of supply where possible, otherwise cap stub and tag with identification; patch holes left by removal using materials specified for new construction.
- F. Protect existing work to remain.
 - 1. Prevent movement of structure; provide shoring and bracing if necessary.
 - 2. Perform cutting to accomplish removals neatly and as specified for cutting new work.
 - 3. Repair adjacent construction and finishes damaged during removal work.
- G. Adapt existing work to fit new work: Make as neat and smooth transition as possible.
 - 1. When existing finished surfaces are cut so that a smooth transition with new work is not possible, terminate existing surface along a straight line at a natural line of division and make recommendation to Architect/Engineer.
 - 2. Where removal of partitions or walls results in adjacent spaces becoming one, rework floors, walls, and ceilings to a smooth plane without breaks, steps, or bulkheads.
 - 3. Where a change of plane of 1/4 inch or more occurs in existing work, submit recommendation for providing a smooth transition for Architect/Engineer review and request instructions.
 - 4. Trim existing wood doors as necessary to clear new floor finish. Refinish trim as required.
- H. Patching: Where the existing surface is not indicated to be refinished, patch to match the surface finish that existed prior to cutting. Where the surface is indicated to be refinished, patch so that the

substrate is ready for the new finish.

- I. Refinish existing surfaces as indicated:
 - 1. Where rooms or spaces are indicated to be refinished, refinish all visible existing surfaces to remain to the specified condition for each material, with a neat transition to adjacent finishes.
 - 2. If mechanical or electrical work is exposed accidentally during the work, re-cover and refinish to match.
- J. Clean existing systems and equipment.
- K. Remove demolition debris and abandoned items from alterations areas and dispose of off-site; do not burn or bury.
- L. Do not begin new construction in alterations areas before demolition is complete.
- M. Comply with all other applicable requirements of this section.

3.06 CUTTING AND PATCHING

- A. Whenever possible, execute the work by methods that avoid cutting or patching.
- B. See Alterations article above for additional requirements.
- C. Perform whatever cutting and patching is necessary to:
 - 1. Complete the work.
 - 2. Fit products together to integrate with other work.
 - 3. Provide openings for penetration of mechanical, electrical, and other services.
 - 4. Match work that has been cut to adjacent work.
 - 5. Repair areas adjacent to cuts to required condition.
 - 6. Repair new work damaged by subsequent work.
 - 7. Remove samples of installed work for testing when requested.
 - 8. Remove and replace defective and non-conforming work.
- D. Execute work by methods that avoid damage to other work and that will provide appropriate surfaces to receive patching and finishing. In existing work, minimize damage and restore to original condition.
- E. Employ original installer to perform cutting for weather exposed and moisture resistant elements, and sight exposed surfaces.
- F. Cut rigid materials using masonry saw or core drill. Pneumatic tools not allowed without prior approval.
- G. Restore work with new products in accordance with requirements of Contract Documents.
- H. Fit work air tight to pipes, sleeves, ducts, conduit, and other penetrations through surfaces.
- I. At penetrations of fire rated walls, partitions, ceiling, or floor construction, completely seal voids with fire rated material in accordance with Section 07 84 00, to full thickness of the penetrated element.
- J. Patching:
 - 1. Finish patched surfaces to match finish that existed prior to patching. On continuous surfaces, refinish to nearest intersection or natural break. For an assembly, refinish entire unit.
 - 2. Match color, texture, and appearance.

3. Repair patched surfaces that are damaged, lifted, discolored, or showing other imperfections due to patching work. If defects are due to condition of substrate, repair substrate prior to repairing finish.

3.07 PROGRESS CLEANING

- A. Maintain areas free of waste materials, debris, and rubbish. Maintain site in a clean and orderly condition.
- B. Remove debris and rubbish from pipe chases, plenums, attics, crawl spaces, and other closed or remote spaces, prior to enclosing the space.
- C. Broom and vacuum clean interior areas prior to start of surface finishing, and continue cleaning to eliminate dust.
- D. Collect and remove waste materials, debris, and trash/rubbish from site periodically and dispose off-site; do not burn or bury.

3.08 PROTECTION OF INSTALLED WORK

- A. Protect installed work from damage by construction operations.
- B. Provide special protection where specified in individual specification sections.
- C. Provide temporary and removable protection for installed products. Control activity in immediate work area to prevent damage.
- D. Provide protective coverings at walls, projections, jambs, sills, and soffits of openings.
- E. Protect finished floors, stairs, and other surfaces from traffic, dirt, wear, damage, or movement of heavy objects, by protecting with durable sheet materials.
- F. Protect work from spilled liquids. If work is exposed to spilled liquids, immediately remove protective coverings, dry out work, and replace protective coverings.
- G. Prohibit traffic or storage upon waterproofed or roofed surfaces. If traffic or activity is necessary, obtain recommendations for protection from waterproofing or roofing material manufacturer.
- H. Prohibit traffic from landscaped areas.
- I. Remove protective coverings when no longer needed; reuse or recycle coverings if possible.

3.09 SYSTEM STARTUP

- A. Coordinate schedule for start-up of various equipment and systems.
- B. Notify Architect/Engineer and owner seven days prior to start-up of each item.
- C. Verify that each piece of equipment or system has been checked for proper lubrication, drive rotation, belt tension, control sequence, and for conditions that may cause damage.
- D. Verify tests, meter readings, and specified electrical characteristics agree with those required by the equipment or system manufacturer.
- E. Verify that wiring and support components for equipment are complete and tested.
- F. Execute start-up under supervision of applicable Contractor personnel and manufacturer's representative in accordance with manufacturers' instructions.

- G. When specified in individual specification Sections, require manufacturer to provide authorized representative to be present at site to inspect, check, and approve equipment or system installation prior to start-up, and to supervise placing equipment or system in operation.
- H. Submit a written report that equipment or system has been properly installed and is functioning correctly.

3.10 ADJUSTING

- A. Adjust operating products and equipment to ensure smooth and unhindered operation.
- B. Testing, adjusting, and balancing HVAC systems: See Section 23 05 93 Testing, Adjusting, and Balancing for HVAC.

3.11 FINAL CLEANING

- A. Execute final cleaning prior to final project assessment.1. Clean areas to be occupied by Owner prior to final completion before Owner occupancy.
- B. Use cleaning materials that are nonhazardous.
- C. Clean interior and exterior glass, surfaces exposed to view; remove temporary labels, stains and foreign substances, polish transparent and glossy surfaces, vacuum carpeted and soft surfaces.
- D. Remove all labels that are not permanent. Do not paint or otherwise cover fire test labels or nameplates on mechanical and electrical equipment.
- E. Clean equipment and fixtures to a sanitary condition with cleaning materials appropriate to the surface and material being cleaned.
- F. Clean filters of operating equipment.
- G. Clean debris from roofs, gutters, downspouts, scuppers, overflow drains, area drains, and drainage systems.
- H. Clean site; sweep paved areas, rake clean landscaped surfaces.
- I. Remove waste, surplus materials, trash/rubbish, and construction facilities from the site; dispose of in legal manner; do not burn or bury.

3.12 CLOSEOUT PROCEDURES

- A. See Section 01 77 00 for additional requirements.
- B. Make submittals that are required by governing or other authorities.1. Provide copies to Architect/Engineer and Owner.
- C. Accompany Project Coordinator on preliminary inspection to determine items to be listed for completion or correction in the Contractor's Correction Punch List for Contractor's Notice of Substantial Completion.
- D. Notify Architect/Engineer when work is considered ready for Architect/Engineer's Substantial Completion inspection.
- E. Submit written certification containing Contractor's Correction Punch List, that Contract Documents have been reviewed, work has been inspected, and that work is complete in accordance with

Contract Documents and ready for Architect/Engineer's Substantial Completion inspection.

- F. Conduct Substantial Completion inspection and create Final Correction Punch List containing Architect/Engineer's and Contractor's comprehensive list of items identified to be completed or corrected and submit to Architect/Engineer.
- G. Correct items of work listed in Final Correction Punch List and comply with requirements for access to Owner-occupied areas.
- H. Accompany Project Coordinator on Contractor's preliminary final inspection.
- I. Notify Architect/Engineer when work is considered finally complete and ready for Architect/Engineer's Substantial Completion final inspection.
- J. Complete items of work determined by Architect/Engineer listed in executed Certificate of Substantial Completion.

3.13 MAINTENANCE

- A. Provide service and maintenance of components indicated in specification sections.
- B. Maintenance Period: As indicated in specification sections or, if not indicated, not less than one year from the Date of Substantial Completion or the length of the specified warranty, whichever is longer.
- C. Examine system components at a frequency consistent with reliable operation. Clean, adjust, and lubricate as required.
- D. Include systematic examination, adjustment, and lubrication of components. Repair or replace parts whenever required. Use parts produced by the manufacturer of the original component.
- E. Maintenance service shall not be assigned or transferred to any agent or subcontractor without prior written consent of the Owner.

SECTION 01 77 00 CLOSEOUT PROCEDURES

PART 1 GENERAL

1.01 SECTION INCLUDES:

- A. Substantial Completion Procedures.
- B. Final Completion Procedures.

1.02 RELATED REQUIREMENTS:

- A. Section 01 10 00 Summary.
- B. Section 01 78 00 Closeout Submittals.

1.03 SUBSTANTIAL COMPLETION PROCEDURES

- A. Pre-Substantial Completion Conference:
 - 1. General Contractor to schedule a Pre-substantial Completion Conference 15 days prior to the date of Substantial Completion, prepare an agenda with copies for the participants and preside over the meeting.
 - 2. Attendance Required: Contractor, Architect/Engineer and Owner.
 - 3. Minimum Agenda:
 - a. Schedule dates of Substantial Completion and Owner occupancy.
 - b. Schedule dates for Initial Punch Lists of respective Subcontractors to be produced.
 - c. Schedule date for written request for Substantial Completion.
 - d. Schedule target date for completion of Initial Punch List items.
 - e. Schedule delivery times for Owner-furnished items to be installed by Contractor, Owner's own forces or others under separate Contracts.
 - f. Schedule dates for Demonstration and Training of equipment and systems specified.
 - g. Schedule completion dates of testing and balancing reports for engineered Systems.
 - h. Scheduling and Sequencing of Construction operations around areas partially occupied.
 - i. Review job site security during transition of Owner occupancy.
 - j. Schedule dates for final inspections from authorities having jurisdiction for Occupancy Permits.
 - k. Review protocol for claims from potential move-in damage.
 - I. Review procedures for final cleaning.
 - m. Review potential concerns regarding environmental conditions.
 - 4. Record minutes and distribute copies within three days after meeting to participants and those affected by decisions made.
- B. Substantial Completion Procedures will be in accordance with the General Conditions of the Contract for Construction, Article 9.8 and include the following:
 - 1. When the Work or a portion of the Work is considered to be substantially complete, the Contractor inspects the project and prepares a comprehensive list of outstanding items to be completed or corrected, Initial Punch List.
 - 2. Contractor submits notice of Substantial Completion.
 - 3. Contractor completes items on the Initial Punch List.
 - 4. Architect/Engineer inspects the project to verify substantial completion and prepares a Final Punch List.

5. Architect/Engineer prepares Certificate of Substantial Completion, acceptance is required by Owner and Contractor.

1.04 FINAL COMPLETION PROCEDURES

- A. Final Completion Procedures will be in accordance with the General Conditions of the Contract for Construction, Article 9.10, and include the following:
 - 1. When items on Initial and Final Punch Lists are complete, the Contractor submits notice of final completion and final application for payment.
 - 2. Contractor submits Final Closeout Submittals as specified in Section 01 78 00.
 - 3. Architect inspects project and verifies the Work is acceptable and conforms with the Contract Documents.
 - 4. Architect processes final application for payment and closeout submittals.

1.05 CORRECTION PERIOD

- A. Correction Period commences on the date of Substantial Completion and expires two years from that date.
- B. Owner: document non-conforming or defective work over course of Correction Period. Notify Contractor in writing of nonconforming or defective work. Copy Architect/Engineer.
 - 1. Life safety issues requiring immediate corrective work: Contact Contractor for action.
- C. Post Construction Walk Through:
 - 1. Time: eleven months after the date of Substantial Completion convene a meeting on site.
 - 2. Attendees: Architect/Engineer, Owner's Representative, End User and Maintenance Staff.
 - 3. Minimum Agenda:
 - a. Review Owner's list of non-conforming or defective work.
 - b. Conduct a walk through of the building and grounds.
 - c. Prepare a list of additional non-conforming or defective work items.
 - 4. Architect/Engineer:
 - a. Prepare written report of findings within two weeks of meeting.
 - b. Notify Contractor of impending corrective work requiring action.
 - c. Monitor execution of corrective Work.
- PART 2 PRODUCTS NOT USED.
- PART 3 EXECUTION NOT USED.

SECTION 01 78 00 CLOSEOUT SUBMITTALS

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Project Record Documents.
- B. Operation and Maintenance Data.
- C. Warranties and bonds.

1.02 RELATED REQUIREMENTS

- A. Section 01 30 00 Administrative Requirements: Submittals procedures, shop drawings, product data, and samples.
- B. Section 01 70 00 Execution and Closeout Requirements: Contract closeout procedures.
- C. Individual Product Sections: Specific requirements for operation and maintenance data.
- D. Individual Product Sections: Warranties required for specific products or Work.

1.03 SUBMITTALS

- A. Project Record Documents: Submit documents to Architect/Engineer with claim for final Application for Payment.
- B. Operation and Maintenance Data:
 - 1. Submit two copies of preliminary draft or proposed formats and outlines of contents before start of Work. Architect/Engineer will review draft and return one copy with comments.
 - 2. For equipment, or component parts of equipment put into service during construction and operated by Owner, submit completed documents within ten days after acceptance.
 - 3. Submit one copy of completed documents 15 days prior to final inspection. This copy will be reviewed and returned after final inspection, with Architect/Engineer comments. Revise content of all document sets as required prior to final submission.
 - 4. Submit two sets of revised final documents in final form within 10 days after final inspection.
- C. Warranties and Bonds:
 - 1. For equipment or component parts of equipment put into service during construction with Owner's permission, submit documents within 10 days after acceptance.
 - 2. Make other submittals within 10 days after Date of Substantial Completion, prior to final Application for Payment.
 - 3. For items of Work for which acceptance is delayed beyond Date of Substantial Completion, submit within 10 days after acceptance, listing the date of acceptance as the beginning of the warranty period.

PART 2 PRODUCTS - NOT USED

PART 3 EXECUTION

3.01 PROJECT RECORD DOCUMENTS

A. Maintain on site one set of the following record documents; record actual revisions to the Work:
1. Drawings.

- 2. Specifications.
- 3. Addenda.
- 4. Change Orders and other modifications to the Contract.
- 5. Reviewed shop drawings, product data, and samples.
- 6. Manufacturer's instruction for assembly, installation, and adjusting.
- B. Ensure entries are complete and accurate, enabling future reference by Owner.
- C. Store record documents separate from documents used for construction.
- D. Record information concurrent with construction progress.
- E. Specifications: Legibly mark and record at each product section description of actual products installed, including the following:
 - 1. Manufacturer's name and product model and number.
 - 2. Product substitutions or alternates utilized.
 - 3. Changes made by Addenda and modifications.
- F. Record Drawings and Shop Drawings: Legibly mark each item to record actual construction including:
 - 1. Measured depths of foundations in relation to finish first floor datum.
 - 2. Measured horizontal and vertical locations of underground utilities and appurtenances, referenced to permanent surface improvements.
 - 3. Measured locations of internal utilities and appurtenances concealed in construction, referenced to visible and accessible features of the Work.
 - 4. Field changes of dimension and detail.
 - 5. Details not on original Contract drawings.

3.02 OPERATION AND MAINTENANCE DATA

- A. Source Data: For each product or system, list names, addresses and telephone numbers of Subcontractors and suppliers, including local source of supplies and replacement parts.
- B. Product Data: Mark each sheet to clearly identify specific products and component parts, and data applicable to installation. Delete inapplicable information.
- C. Drawings: Supplement product data to illustrate relations of component parts of equipment and systems, to show control and flow diagrams. Do not use Project Record Documents as maintenance drawings.
- D. Typed Text: As required to supplement product data. Provide logical sequence of instructions for each procedure, incorporating manufacturer's instructions.

3.03 OPERATION AND MAINTENANCE DATA FOR MATERIALS AND FINISHES

- A. For Each Product, Applied Material, and Finish:
 - 1. Product data, with catalog number, size, composition, and color and texture designations.
 - 2. Information for re-ordering custom manufactured products.
- B. Instructions for Care and Maintenance: Manufacturer's recommendations for cleaning agents and methods, precautions against detrimental cleaning agents and methods, and recommended schedule for cleaning and maintenance.

- C. Moisture protection and weather-exposed products: Include product data listing applicable reference standards, chemical composition, and details of installation. Provide recommendations for inspections, maintenance, and repair.
- D. Additional information as specified in individual product specification sections.
- E. Where additional instructions are required, beyond the manufacturer's standard printed instructions, have instructions prepared by personnel experienced in the operation and maintenance of the specific products.

3.04 OPERATION AND MAINTENANCE DATA FOR EQUIPMENT AND SYSTEMS

- A. For Each Item of Equipment and Each System:
 - 1. Description of unit or system, and component parts.
 - 2. Identify function, normal operating characteristics, and limiting conditions.
 - 3. Include performance curves, with engineering data and tests.
 - 4. Complete nomenclature and model number of replaceable parts.
- B. Where additional instructions are required, beyond the manufacturer's standard printed instructions, have instructions prepared by personnel experienced in the operation and maintenance of the specific products.
- C. Panelboard Circuit Directories: Provide electrical service characteristics, controls, and communications; typed.
- D. Include color coded wiring diagrams as installed.
- E. Operating Procedures: Include start-up, break-in, and routine normal operating instructions and sequences. Include regulation, control, stopping, shut-down, and emergency instructions. Include summer, winter, and any special operating instructions.
- F. Maintenance Requirements: Include routine procedures and guide for preventative maintenance and troubleshooting; disassembly, repair, and reassembly instructions; and alignment, adjusting, balancing, and checking instructions.
- G. Provide servicing and lubrication schedule, and list of lubricants required.
- H. Include manufacturer's printed operation and maintenance instructions.
- I. Include sequence of operation by controls manufacturer.
- J. Provide original manufacturer's parts list, illustrations, assembly drawings, and diagrams required for maintenance.
- K. Provide control diagrams by controls manufacturer as installed.
- L. Provide Contractor's coordination drawings, with color coded piping diagrams as installed.
- M. Provide charts of valve tag numbers, with location and function of each valve, keyed to flow and control diagrams.
- N. Provide list of original manufacturer's spare parts, current prices, and recommended quantities to be maintained in storage.
- O. Include test and balancing reports.

P. Additional Requirements: As specified in individual product specification sections.

3.05 ASSEMBLY OF OPERATION AND MAINTENANCE MANUALS

- A. Assemble operation and maintenance data into durable manuals for Owner's personnel use, with data arranged in the same sequence as, and identified by, the specification sections.
- B. Where systems involve more than one specification section, provide separate tabbed divider for each system.
- C. Prepare instructions and data by personnel experienced in maintenance and operation of described products.
- D. Prepare data in the form of an instructional manual.
- E. Binders: Commercial quality, 8-1/2 by 11 inch three D side ring binders with durable plastic covers;
 2 inch maximum ring size. When multiple binders are used, correlate data into related consistent groupings.
- F. Cover: Identify each binder with typed or printed title OPERATION AND MAINTENANCE INSTRUCTIONS; identify title of Project; identify subject matter of contents.
- G. Project Directory: Title and address of Project; names, addresses, and telephone numbers of Architect/Engineer, Consultants, Contractor and subcontractors, with names of responsible parties.
- H. Tables of Contents: List every item separated by a divider, using the same identification as on the divider tab; where multiple volumes are required, include all volumes Tables of Contents in each volume, with the current volume clearly identified.
- I. Dividers: Provide tabbed dividers for each separate product and system; identify the contents on the divider tab; immediately following the divider tab include a description of product and major component parts of equipment.
- J. Text: Manufacturer's printed data, or typewritten data on 24 pound paper.
- K. Drawings: Provide with reinforced punched binder tab. Bind in with text; fold larger drawings to size of text pages.
- L. Arrangement of Contents: Organize each volume in parts as follows:
 - 1. Project Directory.
 - 2. Table of Contents, of all volumes, and of this volume.
 - 3. Operation and Maintenance Data: Arranged by system, then by product category.
 - a. Source data.
 - b. Product data, shop drawings, and other submittals.
 - c. Operation and maintenance data.
 - d. Field quality control data.
 - e. Photocopies of warranties and bonds.
 - Design Data: To allow for addition of design data furnished by Architect/Engineer or others, provide a tab labeled "Design Data" and provide a binder large enough to allow for insertion of at least 20 pages of typed text.
 - a. Operating instructions.
 - b. Maintenance instructions for equipment and systems.

c. Maintenance instructions for special finishes, including recommended cleaning methods and materials, and special precautions identifying detrimental agents.

3.06 WARRANTIES AND BONDS

- A. Obtain warranties and bonds, executed in duplicate by responsible Subcontractors, suppliers, and manufacturers, within 10 days after completion of the applicable item of work. Except for items put into use with Owner's permission, leave date of beginning of time of warranty until Date of Substantial completion is determined.
- B. Verify that documents are in proper form, contain full information, and are notarized.
- C. Co-execute submittals when required.
- D. Retain warranties and bonds until time specified for submittal.
- E. Cover: Identify each binder with typed or printed title WARRANTIES AND BONDS, with title of Project; name, address and telephone number of Contractor and equipment supplier; and name of responsible company principal.
- F. Table of Contents: Neatly typed, in the sequence of the Table of Contents of the Project Manual, with each item identified with the number and title of the specification section in which specified, and the name of product or work item.
- G. Separate each warranty or bond with index tab sheets keyed to the Table of Contents listing. Provide full information, using separate typed sheets as necessary. List Subcontractor, supplier, and manufacturer, with name, address, and telephone number of responsible principal.

SECTION 02 41 00 DEMOLITION

PART 1 GENERAL

1.01 SECTION INCLUDES

A. Selective demolition of building elements for alteration purposes.

1.02 RELATED REQUIREMENTS

- A. Section 01 10 00 Summary: Limitations on Contractor's use of site and premises.
- B. Section 01 50 00 Temporary Facilities and Controls: Protective barriers, and waste removal.
- C. Section 01 70 00: Project conditions and existing construction to remain.

1.03 REFERENCE STANDARDS

- A. 29 CFR 1926 U.S. Occupational Safety and Health Standards; current edition.
- B. NFPA 241 Standard for Safeguarding Construction, Alteration, and Demolition Operations; 2013.

PART 2 PRODUCTS -- NOT USED

PART 3 EXECUTION

3.01 SCOPE

- A. Remove portions of existing building elements to accommodate new work.
- B. Remove other items indicated, for salvage, relocation, and recycling.

3.02 GENERAL PROCEDURES AND PROJECT CONDITIONS

- A. Comply with other requirements specified in Section 01 70 00.
- B. Comply with applicable codes and regulations for demolition operations and safety of adjacent structures and the public.
 - 1. Obtain required permits.
 - 2. Provide, erect, and maintain temporary barriers and security devices.
 - 3. Use physical barriers to prevent access to areas that could be hazardous to workers or the public.
 - 4. Conduct operations to minimize effects on and interference with adjacent structures and occupants.
 - Conduct operations to minimize obstruction of public and private entrances and exits; do not obstruct required exits at any time; protect persons using entrances and exits from removal operations.
- C. If hazardous materials are discovered during removal operations, stop work and notify Architect/Engineer and Owner; hazardous materials include regulated asbestos containing materials, lead, PCB's, and mercury.
- D. Perform demolition in a manner that maximizes salvage and recycling of materials.
 - 1. Dismantle existing construction and separate materials.

2. Set aside reusable, recyclable, and salvageable materials; store and deliver to collection point or point of reuse.

3.03 SELECTIVE DEMOLITION FOR ALTERATIONS

- A. Drawings showing existing construction are based on casual field observation and existing record documents only.
 - 1. Verify that construction are as shown.
 - 2. Report discrepancies to Architect/Engineer before disturbing existing installation.
 - 3. Beginning of demolition work constitutes acceptance of existing conditions that would be apparent upon examination prior to starting demolition.
- B. Separate areas in which demolition is being conducted from other areas that are still occupied.
 - 1. Provide, erect, and maintain temporary dustproof partitions of construction specified in Section 01 50 00 .
- C. Maintain weatherproof exterior building enclosure except for interruptions required for replacement or modifications; take care to prevent water and humidity damage.
- D. Remove existing work as indicated and as required to accomplish new work.
 - 1. Remove rotted wood, corroded metals, and deteriorated masonry and concrete; replace with new construction specified.
 - 2. Remove items indicated on drawings.
- E. Services (Including but not limited to HVAC, Plumbing, Fire Protection, Electrical, and Telecommunications): Remove existing systems and equipment as indicated.
 - 1. Maintain existing active systems that are to remain in operation; maintain access to equipment and operational components.
 - Where existing active systems serve occupied facilities but are to be replaced with new services, maintain existing systems in service until new systems are complete and ready for service.
 - 3. See Section 01 10 00 for other limitations on outages and required notifications.
 - 4. Verify that abandoned services serve only abandoned facilities before removal.
 - 5. Remove abandoned pipe, ducts, conduits, and equipment, including those above accessible ceilings; remove back to source of supply where possible, otherwise cap stub and tag with identification.
- F. Protect existing work to remain.
 - 1. Prevent movement of structure; provide shoring and bracing if necessary.
 - 2. Perform cutting to accomplish removals neatly and as specified for cutting new work.
 - 3. Repair adjacent construction and finishes damaged during removal work.
 - 4. Patch as specified for patching new work.

3.04 DEBRIS AND WASTE REMOVAL

- A. Remove debris, junk, and trash from site.
- B. Leave site in clean condition, ready for subsequent work.
- C. Clean up spillage and wind-blown debris from public and private lands.

SECTION 06 10 00 ROUGH CARPENTRY

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Fire retardant treated wood materials.
- B. Concealed wood blocking, nailers, and supports.

1.02 REFERENCE STANDARDS

- A. ASTM A153/A153M Standard Specification for Zinc Coating (Hot-Dip) on Iron and Steel Hardware; 2016a.
- B. ASTM E84 Standard Test Method for Surface Burning Characteristics of Building Materials; 2023d.
- C. AWPA U1 Use Category System: User Specification for Treated Wood; 2024.
- D. PS 1 Structural Plywood; 2023.
- E. PS 20 American Softwood Lumber Standard; 2021.

1.03 DELIVERY, STORAGE, AND HANDLING

- A. General: Cover wood products to protect against moisture. Support stacked products to prevent deformation and to allow air circulation.
- B. Fire Retardant Treated Wood: Prevent exposure to precipitation during shipping, storage, or installation.

PART 2 PRODUCTS

2.01 GENERAL REQUIREMENTS

- A. Dimension Lumber: Comply with PS 20 and requirements of specified grading agencies.
 - 1. If no species is specified, provide any species graded by the agency specified; if no grading agency is specified, provide lumber graded by any grading agency meeting the specified requirements.
 - Grading Agency: Any grading agency whose rules are approved by the Board of Review, American Lumber Standard Committee (www.alsc.org) and who provides grading service for the species and grade specified; provide lumber stamped with grade mark unless otherwise indicated.

2.02 DIMENSION LUMBER

- A. Grading Agency: Western Wood Products Association; WWPA G-5.
- B. Miscellaneous Framing, Blocking, Nailers, Grounds, and Furring:
 - 1. Lumber: S4S, No. 2 or Standard Grade.
 - 2. Boards: Standard or No. 3.

2.03 CONSTRUCTION PANELS

A. PS 1, C-D Plugged or better.

2.04 ACCESSORIES

- A. Fasteners and Anchors:
 - 1. Metal and Finish: Hot-dipped galvanized steel complying with ASTM A153/A153M for fireretardant-treated wood locations.

2.05 FACTORY WOOD TREATMENT

- A. Treated Lumber and Plywood: Comply with requirements of AWPA U1 Use Category System for wood treatments determined by use categories, expected service conditions, and specific applications.
 - 1. Fire-Retardant Treated Wood: Mark each piece of wood with producer's stamp indicating compliance with specified requirements.
- B. Fire Retardant Treatment:
 - Interior Type A: AWPA Use Category UCFA, Commodity Specification H (Treatment C20 for lumber and C27 for plywood), low temperature (low hygroscopic) type, chemically treated and pressure impregnated; capable of providing a maximum flame spread rating of 25 when tested in accordance with ASTM E 84, with no evidence of significant combustion when test is extended for an additional 20 minutes.
 - a. Kiln dry wood after treatment to a maximum moisture content of 19 percent for lumber and 15 percent for plywood.
 - b. Treat rough carpentry items as scheduled.
 - c. Do not use treated wood in applications exposed to weather or where the wood may become wet.

PART 3 EXECUTION

3.01 INSTALLATION - GENERAL

- A. Select material sizes to minimize waste.
- B. Reuse scrap to the greatest extent possible; clearly separate scrap for use on site as accessory components, including: shims, bracing, and blocking.
- C. Where treated wood is used on interior, provide temporary ventilation during and immediately after installation sufficient to remove indoor air contaminants.

3.02 BLOCKING, NAILERS, AND SUPPORTS

- A. Provide framing and blocking members as indicated or as required to support finishes, fixtures, specialty items, and trim.
- B. In framed assemblies that have concealed spaces, provide solid wood fireblocking as required by applicable local code, to close concealed draft openings between floors and between top story and roof/attic space; other material acceptable to code authorities may be used in lieu of solid wood blocking.
- C. In metal stud walls, provide continuous blocking around door and window openings for anchorage of frames, securely attached to stud framing.
- D. In walls, provide blocking attached to studs as backing and support for wall-mounted items, unless item can be securely fastened to two or more studs or other method of support is explicitly

indicated.

- E. Provide the following specific non-structural framing and blocking:
 - 1. Cabinets and shelf supports.
 - 2. Wall brackets.
 - 3. Grab bars.
 - 4. Towel and bath accessories.
 - 5. Wall-mounted door stops.
 - 6. Wall paneling and trim.
 - 7. Joints of rigid wall coverings that occur between studs.

3.03 INSTALLATION OF CONSTRUCTION PANELS

- A. Wall Sheathing: Secure with long dimension perpendicular to wall studs, with ends over firm bearing and staggered, using nails, screws, or staples.
 - 1. Use plywood or other acceptable structural panels at building corners, for not less than 96 inches, measured horizontally.

3.04 SITE APPLIED WOOD TREATMENT

- A. Apply preservative treatment compatible with factory applied treatment at site-sawn cuts, complying with manufacturer's instructions.
- B. Allow preservative to dry prior to erecting members.

3.05 TOLERANCES

- A. Framing Members: 1/4 inch from true position, maximum.
- B. Variation from Plane (Other than Floors): 1/4 inch in 10 feet maximum, and 1/4 inch in 30 feet maximum.

3.06 CLEANING

- A. Waste Disposal:
 - 1. Comply with applicable regulations.
 - 2. Do not burn scrap on project site.
 - 3. Do not burn scraps that have been pressure treated.
 - 4. Do not send materials treated with pentachlorophenol, CCA, or ACA to co-generation facilities or "waste-to-energy" facilities.
- B. Do not leave any wood, shavings, sawdust, etc. on the ground or buried in fill.
- C. Prevent sawdust and wood shavings from entering the storm drainage system.

3.07 SCHEDULES

- A. Blocking in Gypsum Board Walls: Fire retardant treated.
- B. Plywood Sheathing for backing in Gypsum Board Walls: Fire retardant treated.

SECTION 06 41 00 CUSTOM CASEWORK

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Specially fabricated cabinet units.
- B. Hardware.
- C. Preparation for installing utilities.

1.02 RELATED REQUIREMENTS

A. Section 12 36 00 - Countertops.

1.03 REFERENCE STANDARDS

- A. ANSI A208.1 American National Standard for Particleboard; 2022.
- B. ANSI A208.2 Medium Density Fiberboard (MDF) for Interior Applications; 2022.
- C. AWI/AWMAC/WI (AWS) Architectural Woodwork Standards; 2014, with Errata (2018).
- D. AWMAC/WI (NAAWS) North American Architectural Woodwork Standards, U.S. Version 3.1; 2016, with Errata (2018).
- E. NEMA LD 3 High-Pressure Decorative Laminates; 2005.

1.04 ADMINISTRATIVE REQUIREMENTS

A. Preinstallation Meeting: Convene a preinstallation meeting not less than one week before starting work of this section; require attendance by all affected installers.

1.05 SUBMITTALS

- A. See Section 01 30 00 Administrative Requirements, for submittal procedures.
- B. Shop Drawings: Indicate materials, component profiles and elevations, assembly methods, fastening methods, jointing details, and accessories, hardware locations and schedule of finishes.
 1. Scale of Drawings: 1-1/2 inch to 1 foot, minimum.
 - 2. Provide the information required by AWI/AWMAC/WI (AWS) or AWMAC/WI (NAAWS).
- C. Product Data: Provide data for hardware accessories.
- D. Samples: Submit actual samples of architectural cabinet construction, minimum 12 inches square, illustrating proposed cabinet and shelf unit substrate and finish.
- E. Samples: Submit actual sample items of proposed pulls, hinges, shelf standards, and locksets, demonstrating hardware design, quality, and finish.

1.06 QUALITY ASSURANCE

A. Fabricator Qualifications: Company specializing in fabricating the products specified in this section with minimum five years of documented experience.

1. Company with at least one project in the past 5 years with value of woodwork within 20 percent of cost of woodwork for this Project.

1.07 DELIVERY, STORAGE, AND HANDLING

- A. Reject and return to fabricator units that are missing hardware components.
- B. Protect units from moisture damage.

1.08 FIELD CONDITIONS

A. During and after installation of custom cabinets, maintain temperature and humidity conditions in building spaces at same levels planned for occupancy.

PART 2 PRODUCTS

2.01 CABINETS

A. Quality Standard: Custom Grade, in accordance with AWI/AWMAC/WI (AWS) or AWMAC/WI (NAAWS), unless noted otherwise.

B. Cabinets:

- 1. Finish Exposed Exterior Surfaces: Decorative laminate.
- 2. Finish Exposed Interior Surfaces: Decorative laminate.
- 3. Finish Semi-Exposed Surfaces: Decorative laminate.
- 4. Finish Concealed Surfaces: Manufacturer's option.
- 5. Door and Drawer Front Edge Profiles: Square edge with thick applied band.
- 6. Door and Drawer Front Retention Profiles: Removable stop.
- 7. Casework Construction Type: Type A Frameless.
- 8. Interface Style for Cabinet and Door: Style 1 Overlay; flush overlay.
- 9. Grained Face Layout for Cabinet and Door Fronts: Flush panel.
 - a. Premium Grade:
 - 1) Provide vertical run and match for doors, drawer fronts and false fronts within each cabinet unit.
 - 2) Provide well-matched doors, drawer fronts and false fronts across multiple cabinet faces in one elevation.
 - 3) Cathedral Grain: Point grain crown up and run in the same direction for entire project.
- 10. Cabinet Design Series: As indicated on drawings.
- 11. Adjustable Shelf Loading: 50 lbs. per sq. ft.
 - a. Deflection: L/144.
- 12. Casework Integrity: Comply with Acceptance Level requirements of AWI/AWMAC/WI (AWS) Appendix A for the following tests.
 - a. Structural Integrity Test Base Cabinet.
 - b. Concentrated Load Test Base Cabinet.
 - c. Torsion Test Base Cabinet.
 - d. Structural Integrity Test Wall Cabinet.
 - e. Door Durability Test.
 - f. Door Impact Test.
 - g. Door Hinge Test.
 - h. Drawer Bottom Impact Test.
 - i. Drawer Support Test.

- j. Drawer and Door Pull Test.
- k. Drawer Rolling Load Test.
- I. Shelf Load Test.
- 13. Drawer Construction Technique: Dovetail joints.

2.02 WOOD-BASED COMPONENTS

A. Wood fabricated from old growth timber is not permitted.

2.03 PANEL MATERIALS

- A. Medium Density Fiberboard (MDF): ANSI A208.2; type as specified in AWI/AWMAC/WI (AWS); composed of cellulosic fibers pressure bonded with moisture resistant adhesive to suit application; sanded faces; thicknesses as specified under AWI/AWMAC/WI (AWS) Section 10.4.7 for each component type.
 - 1. Use for cabinet and countertop components, including cabinet backs (1/2" min.) and drawer bottoms (1/2" min.), unless another material is indicated on drawings.
 - 2. Use as core for decorative laminate-faced panels unless otherwise indicated.
- B. Hardboard: AHA A135.4; Pressed wood fiber with resin binder, Class 1 Tempered, 1/4 inch thick, smooth two sides (S2S); use for dividers, mail slots and other components specifically indicated on drawings.
- C. Particleboard: ANSI A208.1; Grade M-3 medium density or any Grade high density industrial type as specified in AWI/AWMAC/WI (AWS), composed of wood chips bonded with interior grade adhesive under heat and pressure; sanded faces; thickness as specified under AWI/AWMAC/WI (AWS) Section 10.4.7 for each component type; use for components indicated on drawings.
 - 1. Density: 40 lb/cu ft (minimum for low end of range).
 - 2. Screw Holding:
 - a. Face: 225 lb (minimum).
 - b. Edge: 202 lb (minimum).

2.04 LAMINATE MATERIALS

- A. Manufacturers:
 - 1. Wilsonart LLC: www.wilsonart.com.
 - 2. Substitutions: Not permitted.
- B. High Pressure Decorative Laminate (HPDL): NEMA LD 3, types as recommended for specific applications.
- C. Provide specific types as indicated.
 - 1. Horizontal Surfaces: HGS, 0.048 inch nominal thickness, through color, color as selected, finish as indicated.
 - 2. Vertical Surfaces: VGS, 0.028 inch nominal thickness, through color, color as selected, finish as indicated.
 - 3. Post-Formed Horizontal Surfaces: HGP, 0.039 inch nominal thickness, color as selected, finish as indicated.

- 4. Post-Formed Vertical Surfaces: VGP, 0.028 inch nominal thickness, color as selected, finish as indicated.
- 5. Cabinet Liner: CLS, 0.020 inch nominal thickness, through color, finish as indicated.
- 6. Laminate Backer: BKL, nominal thickness to match that of opposing face sheet, undecorated; for application to concealed backside of panels faced with high pressure decorative laminate.

2.05 COUNTERTOPS

A. Countertops are specified in Section 12 36 00.

2.06 ACCESSORIES

- A. Adhesive: Type recommended by fabricator to suit application.
- B. Plastic Edgebanding: Extruded 3mm PVC or ABS, flat shaped; smooth finish; bonded to edge of component; of width to match component thickness. Provide "flexible" PVC material for curved component edges.
 - 1. Manufacturers:
 - a. Charter Industries: www.charterindustries.com.
 - b. EdgeCo, Inc.: www.edgecoinc.com.
 - c. Frama-Tech, Inc.: www.framatech.net.
 - d. Teknaform: www.teknaform.com.
 - 2. Color: Custom, to match selected laminate materials colors and patterns.
 - 3. Use at exposed edges of shelves, cabinet doors, and cabinet drawers.
- C. Fasteners: Size and type to suit application.
- D. Bolts, Nuts, Washers, Lags, Pins, and Screws: Of size and type to suit application; galvanized or chrome-plated finish in concealed locations and stainless steel or chrome-plated finish in exposed locations.
- E. Concealed Joint Fasteners: Threaded steel.

2.07 HARDWARE

- A. Adjustable Shelf Supports: Standard side-mounted system using recessed metal shelf standards or multiple holes for pin supports and coordinated self rests, polished chrome finish, for nominal 1 inch spacing adjustments.
 - 1. Manufacturer: Knape & Vogt Manufacturing Company: www.kv.com.
 - 2. Standards: #255 ZC zinc coated steel pilaster strips.
 - 3. Support Clips for Standards: #239 ZC zinc-plated steel.
 - 4. Pin Supports for drilled holes: #333 ZC zinc-plated steel.
 - 5. Use for adjustable shelving within cabinet assemblies.
 - 6. Other acceptable manufacturers:
 - a. John Sterling Company: www.johnsterling.com.
- B. Adjustable Shelf Supports: Standard back-mounted system using surface mounted metal shelf standards and coordinated cantilevered shelf brackets for nominal 1 inch spacing adjustments.
 - 1. Heavy Duty Standards and Brackets:
 - a. Product: #85 standards and #185 brackets manufactured by Knape & Vogt Manufacturing Company: www.kv.com.

- b. Finish: Electroplated, Anachrome.
- c. Use for wall-attached adjustable shelving.
- C. Shelf and Rod Supports: Standard back-mounted system using surface mounted metal shelf brackets, white finish, for nominal 1 inch spacing adjustments.
 - 1. Product: #1195 WH Heavy Duty Shelf and Rod Support manufactured by Knape & Vogt Manufacturing Company: www.kv.com.
 - 2. Product: #RP-0045-WT manufactured by John Sterling Corporation: www.johnsterling.com.
 - 3. Product: #858-WH manufactured by EPCO Sales, LLC: www.epcohardware.com.
 - 4. Closet Rods: 1-5/16" o.d. chromed steel tubing. Provide support flanges at each end.
 - 5. Use for closet shelves and rods.
- D. Drawer and Door Pulls: "U" shaped 10 mm dia. steel wire pull, with nickel plated matte finish, 96 mm centers. Provide two (2) pulls for drawers greater than 24 inches wide.
 - 1. Product: 116.09.617 or 116.09.617.AL manufactured by Hafele America Co.: www.hafele.com.
- E. Cabinet Locks: Cam-type to suit door/drawer application, non-captive key operation, steel with chrome finish.
 - 1. Manufacturer:
 - a. CompX International, Inc.: www.compxnet.com.
 - b. Substitutions: Not permitted.
 - 2. Products: CompX Timberline Series.
 - a. Door Locks: 290 Series.
 - b. Drawer Locks: 280 Series.
 - c. Locks for Doors Taller Than 48": System 260 Wardrobe Lock.
 - d. Double Door Locks: 250 Series, complete with strike plates.
 - 3. Cam Rotation: 180° CW turn to unlock; 180° CCW turn to lock. Key removable in both locked and unlocked positions.
 - 4. Core Type: Flat key, 5 disc tumbler.
 - 5. Keying: Doors and drawers keyed alike per room and master keyed.
 - 6. Strikes: Provide to match specified lock requirements. Notching or routing of cabinet panel is acceptable where appropriate to the specified lock application/operation.
 - 7. Provide one lock (1) per drawer, one lock (1) per single door and (1) lock per paired set of doors.
 - a. For paired cabinet doors up to 48" high, provide double door lock on right-hand leaf.
 - b. For paired cabinet doors taller than 48" high, provide wardrobe lock on right-hand leaf and double door latches at top and bottom of cabinet to secure left-hand leaf.
 - c. Locate drawer locks at top center of drawers, unless another location is indicated on the Drawings.
 - d. Locate door locks at the top latch side of door for base cabinets and at the bottom latch side of door for wall cabinets, unless another location is indicated on the Drawings.
 - 8. Provide two keys per lock and 8 master keys.
- F. Drawer Slides:
 - 1. Type: Full extension.
 - 2. Static Load Capacity: 150 pounds, minimum.

- 3. Mounting: Side mounted.
- 4. Stops: Positive type.
- 5. Features: Provide soft-closing type, with lever disconnect and vertical drawer adjustment.
- 6. Manufacturers:
 - a. Accuride International, Inc: 3932 EC Easy Close Slides: www.accuride.com.
 - b. Substitutions: Not permitted.
- G. Door Hinges: European style concealed self-closing type, steel with satin finish, allowing 3dimensional adjustment. Provide complete with black plastic cover caps, and manufacturer's recommended mounting plates with dowel inserts and fasteners.
 - 1. Manufacturers:
 - a. Grass America Inc.; 165 Degree Snap On 3000 Series: www.grassusa.com.
 - b. Hardware Resources; 170 Degree Basic Clip On with Dowels #248.0M73.05: www.hardwareresources.com.
 - c. Blum, Inc; CLIP top 170° Press-in #71T6580: www.blum.com.
 - d. Substitutions: Not permitted.

2.08 FABRICATION

- A. Assembly: Shop assemble cabinets for delivery to site in units easily handled and to permit passage through building openings.
- B. Edging: Fit shelves, doors, and exposed edges with specified edging. Do not use more than one piece for any single length.
- C. Fitting: When necessary to cut and fit on site, provide materials with ample allowance for cutting. Provide matching trim for scribing and site cutting.
- D. Plastic Laminate: Apply plastic laminate finish in full uninterrupted sheets consistent with manufactured sizes. Fit corners and joints hairline; secure with concealed fasteners. Slightly bevel arises.
 - 1. Apply laminate backing sheet to reverse side of plastic laminate finished surfaces.
 - 2. Cap exposed plastic laminate finish edges with plastic trim.
- E. Provide cutouts for fixtures and fittings. Verify locations of cutouts from on-site dimensions. Prime paint cut edges.
- F. Shop glaze glass materials using the Interior Dry method as specified in Section 08 80 00.
- G. Hardware: Install hardware components in fabricator's shop. Carpenter installation of cabinet hardware components in field is not permitted.

2.09 SHOP FINISHING

A. Hardware: Install hardware components in fabricator's shop. Carpenter installation of cabinet hardware components in field is not permitted.

PART 3 EXECUTION

3.01 EXAMINATION

A. Verify adequacy of backing and support framing.

B. Verify location and sizes of utility rough-in associated with work of this section.

3.02 INSTALLATION

- A. Install work in accordance with AWI/AWMAC/WI (AWS) or AWMAC/WI (NAAWS) requirements for grade indicated.
- B. Set and secure custom cabinets in place, assuring that they are rigid, plumb, and level.
- C. Use fixture attachments in concealed locations for wall mounted components.
- D. Use concealed joint fasteners to align and secure adjoining cabinet units.
- E. Carefully scribe casework abutting other components, with maximum gaps of 1/32 inch. Do not use additional overlay trim for this purpose.
- F. Secure cabinets to floor using appropriate angles and anchorages.

3.03 ADJUSTING

- A. Test installed work for rigidity and ability to support loads.
- B. Adjust moving or operating parts to function smoothly and correctly. Clean sawdust from drawer slides. Re-grease slides after removing sawdust.
- C. Repair damaged and defective casework to eliminate defects functionally and visually. Where not possible to repair properly, replace casework.

3.04 CLEANING

- A. Clean casework, counters, shelves, hardware, fittings, and fixtures.
- B. Remove sawdust, leftover materials and other debris from within cabinets and drawers.

SECTION 07 05 53 FIRE AND SMOKE ASSEMBLY IDENTIFICATION

PART 1 GENERAL

1.01 SECTION INCLUDES

A. Identification markings for fire and smoke rated partitions, and fire rated walls.

1.02 REFERENCE STANDARDS

A. ICC (IBC) - International Building Code; Most Recent Edition Adopted by Authority Having Jurisdiction, Including All Applicable Amendments and Supplements.

1.03 SUBMITTALS

- A. See Section 01 30 00 Administrative Requirements, for submittal procedures.
- B. Product Data: Manufacturer's printed product literature for each type of marking, indicating font, foreground and background colors, wording, and overall dimensions.
- C. Schedule: Completely define scope of proposed marking, and indicate location of affected walls and partitions, and number of markings.

1.04 QUALITY ASSURANCE

A. Manufacturer Qualifications: Company specializing in manufacturing the products specified in this section with minimum three years of documented experience.

1.05 FIELD CONDITIONS

A. Do not install painted markings when ambient temperature is lower than recommended by coating manufacturer.

PART 2 PRODUCTS

2.01 MANUFACTURERS

- A. Partition Identification Labels:
 - 1. Fire Wall Signs, Inc: www.firewallsigns.com.
 - 2. Safety Supply Warehouse, Inc: www.safetysupplywarehouse.com.
 - 3. Substitutions: See Section 01 60 00 Product Requirements.

2.02 FIRE AND SMOKE ASSEMBLY IDENTIFICATION

- A. Regulatory Requirements: Comply with "Marking and Identification" requirements of "Fire-Resistance Ratings and Fire Tests" Chapter 703.7 of ICC (IBC).
- B. Adhered Fire and Smoke Assembly Identification Signs: Printed vinyl sign with factory applied adhesive backing.
- C. Languages: Provide sign markings in English.

PART 3 EXECUTION

3.01 EXAMINATION

A. Verify that substrate surfaces are ready to receive work.

3.02 INSTALLATION

- A. Locate markings as required by ICC (IBC).
- B. Install adhered markings in accordance with manufacturer's instructions.
- C. Install neatly, with horizontal edges level.
- D. Protect from damage until Date of Substantial Completion; repair or replace damaged markings.

SECTION 07 21 19.02 FOAMED-IN-PLACE INSULATION

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Foamed-in-place insulation.
 - 1. In chase wall on North side of Restroom 404 and 405.

1.02 RELATED REQUIREMENTS

A. Section 01 61 16 - Volatile Organic Compound (VOC) Content Restrictions.

1.03 REFERENCE STANDARDS

- A. ASTM C518 Standard Test Method for Steady-State Thermal Transmission Properties by Means of the Heat Flow Meter Apparatus; 2010.
- B. ASTM D2842 Standard Test Method for Water Absorption of Rigid Cellular Plastics; 2019.
- C. ASTM E84 Standard Test Method for Surface Burning Characteristics of Building Materials; 2023d.
- D. ASTM E96/E96M Standard Test Methods for Gravimetric Determination of Water Vapor Transmission Rate of Materials; 2023.
- E. ASTM E283 Standard Test Method for Determining the Rate of Air Leakage Through Exterior Windows, Curtain Walls, and Doors Under Specified Pressure Differences Across the Specimen; 2004 (Reapproved 2012).
- F. ASTM E2178 Standard Test Method for Determining Air Leakage Rate and Calculation of Air Permeance of Building Materials; 2021a.

1.04 ADMINISTRATIVE REQUIREMENTS

A. Preinstallation Meeting: Convene one week prior to commencing work of this section.

1.05 SUBMITTALS

- A. See Section 01 30 00 Administrative Requirements, for submittal procedures.
- B. Product Data: Provide product description, insulation properties, overcoat properties, and preparation requirements.
- C. Certificates: Certify that products of this section meet or exceed specified requirements.
- D. Manufacturer's Installation Instructions: Indicate special procedures, and perimeter conditions requiring special attention.

1.06 QUALITY ASSURANCE

- A. Manufacturer Qualifications: Company specializing in manufacturing products of the type specified in this section, with not less than three years of documented experience.
- B. Applicator Qualifications: Company specializing in performing work of the type specified, with minimum three years documented experience.

1.07 FIELD CONDITIONS

- A. Do not apply foam when temperature is below that specified by the manufacturer for ambient air and substrate.
- B. Do not apply foam when temperature is within 5 degrees F of dew point.

PART 2 PRODUCTS

2.01 MATERIALS

- A. Foamed-In-Place Insulation: Medium-density, rigid or semi-rigid, closed cell polyurethane foam; foamed on-site, using blowing agent of water or non-ozone-depleting gas.
 - 1. Aged Thermal Resistance: R-value of 6.9 (deg F hr sq ft)/Btu, minimum, when tested at 1 inch thickness in accordance with ASTM C518 after aging for 180 days at 41 degrees F.
 - 2. Water Vapor Permeance: Vapor retarder; 2 perm, maximum, when tested at intended thickness in accordance with ASTM E96/E96M, desiccant method.
 - 3. Water Absorption: Less than 2 percent by volume, maximum, when tested in accordance with ASTM D2842.
 - 4. Air Permeance: 0.004 cfm/sq ft, maximum, when tested at intended thickness in accordance with ASTM E2178 or ASTM E283 at 1.5 psf.
 - 5. Closed Cell Content: At least 90 percent.
 - 6. Surface Burning Characteristics: Flame spread/Smoke developed index of 25/450, maximum, when tested in accordance with ASTM E84.
 - 7. Products:
 - a. BASF Corporation; WALLTITE US: www.spf.basf.com.
 - b. Demilec LLC; HEATLOK SOY 200 Plus: www.demilec.com/#sle.
 - c. Henry Company; PERMAX 2.0: www.henry.com/sle.
 - d. Icynene Inc; Icynene ProSeal Eco MD-R-210: www.icynene.com.
 - e. Johns Manville; JM Corbond III Closed Cell Spray Polyurethane Foam: www.jm.com/#sle.
 - f. Substitutions: Not permitted.

2.02 ACCESSORIES

- A. Primer: As required by insulation manufacturer.
- B. Overcoat: Intumescent coating of type recommended by insulation manufacturer and as required to comply with applicable codes.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify work within construction spaces or crevices is complete prior to insulation application.
- B. Verify that surfaces are clean, dry, and free of matter that may inhibit insulation or overcoat adhesion.

3.02 PREPARATION

- A. Mask and protect adjacent surfaces from over spray or dusting.
- B. Apply primer in accordance with manufacturer's instructions.

3.03 APPLICATION

- A. Apply insulation in accordance with manufacturer's instructions.
- B. Apply insulation by spray method, to a uniform monolithic density without voids.
- C. Apply to achieve a thermal resistance R-value of 13 Minimum.
- D. Apply overcoat monolithically, without voids to fully cover foam insulation, to achieve fire rating required.
- E. Patch damaged areas.
- F. Where applied to voids and gaps assure space for expansion to avoid pressure on adjacent materials that may bind operable parts.
- G. Trim excess away for applied trim or remove as required for continuous sealant bead.

3.04 PROTECTION

A. Do not permit subsequent construction work to disturb applied insulation.

SECTION 07 84 00 FIRESTOPPING

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Firestopping systems.
- B. Firestopping of joints and penetrations in fire resistance rated and smoke resistant assemblies, whether indicated on drawings or not, and other openings indicated.
- C. Smoke-stopping of all penetrations of and joints in smoke partitions, whether indicated on drawings or not, and other openings indicated.

1.02 RELATED REQUIREMENTS

- A. Section 01 70 00 Execution and Closeout Requirements: Cutting and patching.
- B. Section 07 05 53 Fire and Smoke Assembly Identification.
- C. Section 09 21 16 Gypsum Board Assemblies: Gypsum wallboard fireproofing.

1.03 REFERENCE STANDARDS

- A. ASTM E119 Standard Test Methods for Fire Tests of Building Construction and Materials; 2022.
- B. ASTM E814 Standard Test Method for Fire Tests of Through-Penetration Fire Stops; 2013a.
- C. ITS (DIR) Directory of Listed Products; current edition.
- D. FM 4991 Approval Standard for Firestop Contractors; 2013.
- E. FM (AG) FM Approval Guide; current edition.
- F. SCAQMD 1168 South Coast Air Quality Management District Rule No.1168; current edition.
- G. UL 1479 Standard for Fire Tests of Penetration Firestops; Current Edition, Including All Revisions.
- H. UL (FRD) Fire Resistance Directory; Current Edition.

1.04 DEFINITIONS

- A. Assembly: Particular arrangement of materials specific to given type of construction described or detailed in referenced documents.
- B. Barriers: Time rated fire walls, smoke barrier walls, time rated ceiling/floor assemblies and structural floors.
- C. Firestopping: Methods and materials applied in penetrations and unprotected openings to limit spread of heat, fire gasses and smoke.
- D. Penetration: Opening or foreign material passing through or into barrier or structural floor such that full thickness of rated materials is not obtained.
- E. Joint: Interruption to a fire-rated assembly occurring at interface between 1) adjacent sections of wall, 2) intersecting walls, 3) top of wall and ceiling, structural floor or roof deck, 4) wall and edge of structural floor, 5) adjacent sections of structural floor.

- F. System: Specific products and applications, classified and numbered by Underwriters Laboratories, Inc. to close specific barrier penetrations and joints.
- G. Sleeve: Metal fabrication or pipe section extending through thickness of barrier and used to permanently guard penetration. Sleeves are described as part of penetrating system in other sections and may or may not be required.

1.05 SYSTEM DESCRIPTION

- A. Design Requirements:
 - Fire-rated construction: Maintain barrier and structural floor fire resistance ratings including resistance to cold smoke at all penetrations, connections with other surfaces or types of construction, at separations required to permit building movement and sound or vibration absorption, and at other construction gaps.
 - 2. Smoke barrier construction: Maintain barrier and structural floor resistance to cold smoke at all penetrations, connections with other surfaces and types of construction and at all separations required to permit building movement and sound or vibration absorption, and at other construction gaps.

1.06 SUBMITTALS

- A. See Section 01 30 00 Administrative Requirements, for submittal procedures.
- B. Schedule of Firestopping: List each type of penetration, fire rating of the penetrated assembly, and firestopping test or design number.
 - 1. Provide manufacturer's qualified engineering judgements for non-standard applications.
- C. Product Data: Provide data on product characteristics, performance ratings, and limitations.
- D. Sustainable Design Submittal: Submit VOC content documentation for all non-preformed materials.
- E. Manufacturer's Installation Instructions: Indicate preparation and installation instructions.
- F. Manufacturer's Certificate: Certify that products meet or exceed specified requirements.

1.07 QUALITY ASSURANCE

- A. Fire Testing: Provide firestopping assemblies of designs that provide the scheduled fire ratings when tested in accordance with methods indicated.
 - 1. Listing in UL (FRD), FM (AG), or ITS (DIR) will be considered as constituting an acceptable test report.
 - 2. Submission of actual test reports is required for assemblies for which none of the above substantiation exists.
- B. Manufacturer Qualifications: Company specializing in manufacturing the products specified in this section with minimum three years documented experience.
- C. Installer Qualifications: Company specializing in performing the work of this section and:
 - 1. Approved by Factory Mutual Research Corporation under FM 4991, or meeting any two of the following requirements:
 - 2. Verification of minimum three years documented experience installing work of this type.
 - 3. Verification of at least five satisfactorily completed projects of comparable size and type.

4. Licensed by local authorities having jurisdiction (AHJ).

1.08 DELIVERY, STORAGE AND HANDLING

- A. Deliver products in original, unopened packaging with legible manufacturer's identification.
- B. Coordinate delivery with scheduled installation date to minimize storage time at site.
- C. Store materials in a clean, dry, ventilated location. Protect materials from freezing if required by manufacturer.

1.09 FIELD CONDITIONS

- A. Comply with firestopping manufacturer's recommendations for temperature and conditions during and after installation; maintain minimum temperature before, during, and for three days after installation of materials.
- B. Provide ventilation in areas where solvent-cured materials are being installed.

PART 2 PRODUCTS

2.01 MANUFACTURERS

- A. Firestopping Manufacturers:
 - 1. 3M Fire Protection Products: www.3m.com/firestop.
 - 2. A/D Fire Protection Systems Inc: www.adfire.com.
 - 3. Hilti, Inc: www.us.hilti.com/#sle.
 - 4. Nelson FireStop Products: www.nelsonfirestop.com.
 - 5. Specified Technologies Inc: www.stifirestop.com/#sle.
 - 6. Tremco Commercial Sealants & Waterproofing: www.tremcosealants.com/#sle.
 - 7. Substitutions: See Section 01 60 00 Product Requirements.

2.02 MATERIALS

- A. Firestopping Materials: Any materials meeting requirements.
- B. Volatile Organic Compound (VOC) Content: Provide products having VOC content lower than that required by SCAQMD 1168.
- C. Primers, Sleeves, Forms, Insulation, Packing, Stuffing, and Accessories: Provide type of materials as required for tested firestopping assembly.
- D. Fire Ratings: Refer to drawings for required systems and ratings.

2.03 FIRESTOPPING SYSTEMS

- A. Firestopping: Any material meeting requirements.
 - 1. Fire Ratings: Use system that is listed by FM (AG), ITS (DIR), or UL (FRD) and tested in accordance with ASTM E814, ASTM E119, or UL 1479 with F Rating equal to fire rating of penetrated assembly and minimum T Rating Equal to F Rating and in compliance with other specified requirements.
- B. Acceptable Manufacturers: As listed in UL (FRD) for specific UL Design Number.
- C. Fill, Void or Cavity Materials: Conform to UL (FRD) XHHW.
- D. Firestop Devices: Conform to UL (FRD) XHJI.

- E. Forming Materials: Conform to UL (FRD) XHKU.
- F. Mechanical Joint Assemblies: Conform to UL (FRD) XHLP.
- G. Packing Material: As required by specific UL Design Number for joint system or throughpenetration firestop system.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify openings are ready to receive the work of this section.
 - 1. Verify barrier joints and penetrations are properly sized and in suitable condition for application of materials.

3.02 PREPARATION

- A. Clean substrate surfaces of dirt, dust, grease, oil, loose material, or other materials that could adversely affect bond of firestopping material.
- B. Remove incompatible materials that could adversely affect bond.

3.03 INSTALLATION

- A. Install materials in manner described in UL (FRD) or fire test report and in accordance with manufacturer's instructions, completely closing openings.
- B. Do not cover installed firestopping until inspected by authorities having jurisdiction.
- C. Install peel and stick labeling to identify fire-resistant rated assemblies on each side of fire barrier walls at 48 inches on center that are indicated on the drawings as a fire barrier. Labeling shall be installed in above acoustical ceiling cavities at public accessed areas, on wall surfaces in rooms without finished ceilings at 96" AFF or in areas as directed by the Authority Having Jurisdiction.

3.04 CLEANING

A. Clean adjacent surfaces of firestopping materials.

3.05 PROTECTION

- A. Protect adjacent surfaces from damage by material installation.
- B. Patch or replace firestopping damaged by work of other sections.

SECTION 07 92 00 JOINT SEALANTS

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Nonsag gunnable joint sealants.
- B. Joint backings and accessories.

1.02 RELATED REQUIREMENTS

- A. Section 01 61 16 Volatile Organic Compound (VOC) Content Restrictions: Additional requirements for sealants and primers.
- B. Section 09 30 00 Tiling: Sealant between tile and plumbing fixtures and at junctions with other materials and changes in plane.

1.03 REFERENCE STANDARDS

- A. ASTM C920 Standard Specification for Elastomeric Joint Sealants; 2018.
- B. ASTM C1193 Standard Guide for Use of Joint Sealants; 2016 (Reapproved 2023).
- C. ASTM C1330 Standard Specification for Cylindrical Sealant Backing for Use with Cold Liquid-Applied Sealants; 2023.
- D. SWRI (VAL) SWR Institute Validated Products Directory; Current Edition.

1.04 SUBMITTALS

- A. See Section 01 30 00 Administrative Requirements for submittal procedures.
- B. Product Data: Submit manufacturer's technical datasheets for each product to be used; include the following:
 - 1. Physical characteristics, including movement capability, VOC content, hardness, cure time, and color availability.
 - 2. List of backing materials approved for use with the specific product.
 - 3. Backing material recommended by sealant manufacturer.
 - 4. Substrates that product is known to satisfactorily adhere to and with which it is compatible.
 - 5. Substrates the product should not be used on.
 - 6. Substrates for which use of primer is required.
 - 7. Substrates for which laboratory adhesion and/or compatibility testing is required.
 - 8. Installation instructions, including precautions, limitations, and recommended backing materials and tools.
 - 9. Sample product warranty.
 - 10. Certification by manufacturer indicating that product complies with specification requirements.
 - 11.SWRI Validation: Provide currently available sealant product validations as listed by SWRI (VAL) for specified sealants.
- C. Product Data for Accessory Products: Submit manufacturer's technical data sheet for each product to be used, including physical characteristics, installation instructions, and recommended tools.
- D. Color Cards for Selection: Where sealant color is not specified, submit manufacturer's color cards showing standard colors available for selection.
- E. Samples for Verification: Where custom sealant color is specified, obtain directions from Architect/Engineer and submit at least two physical samples for verification of color of each required sealant.
- F. Installer's qualification statement.
- G. Executed warranty.

1.05 QUALITY ASSURANCE

- A. Manufacturer Qualifications: Company specializing in manufacturing the products specified in this section with minimum ten years experience.
- B. Installer Qualifications: Company specializing in performing the work of this section and with at least five years of documented experience.

1.06 WARRANTY

- A. See Section 01 78 00 Closeout Submittals for additional warranty requirements.
- B. Manufacturer Warranty: Provide 2-year manufacturer warranty for installed sealants and accessories that fail to achieve a watertight seal, exhibit loss of adhesion or cohesion, or do not cure. Complete forms in Owner's name and register with manufacturer.
- C. Extended Correction Period: Correct defective work within 2-year period commencing on Date of Substantial Completion.

PART 2 PRODUCTS

2.01 MANUFACTURERS

- A. Nonsag Sealants:
 - 1. Dow Corning Corporation: www.dowcorning.com/construction.
 - 2. Hilti, Inc: www.us.hilti.com.
 - 3. Master Builders Solutions by BASF: www.master-builders-solutions.basf.us/en-us.
 - 4. Momentive Performance Materials, Inc (formerly GE Silicones): www.momentive.com.
 - 5. Pecora Corporation: www.pecora.com.
 - 6. Sika Corporation: www.usa-sika.com.
 - 7. Tremco Commercial Sealants & Waterproofing: www.tremcosealants.com.
 - 8. W.R. Meadows, Inc: www.wrmeadows.com.

2.02 JOINT SEALANT APPLICATIONS

- A. Scope:
 - 1. Interior Joints:
 - a. Seal open joints except specific open joints indicated on drawings as not sealed.
 - 2. Do Not Seal:
 - a. Intentional weep holes in masonry.
 - b. Weep holes in curtain wall, storefront and window systems.
 - c. Joints indicated to be covered with expansion joint cover assemblies.

- d. Joints where sealant is specified to be furnished and installed by manufacturer of product to be sealed.
- e. Joints where sealant installation is specified in other sections.
- f. Joints between suspended ceilings and walls.
- B. Interior Joints: Use non-sag acrylic-urethane sealant, unless otherwise indicated.
 - 1. Wall and Ceiling Joints in Non-Wet Areas: Acrylic emulsion latex sealant.
 - 2. Wall and Ceiling Joints in Wet Areas: Non-sag polyurethane sealant for continuous liquid immersion.
 - 3. Floor Joints in Wet Areas: Non-sag polyurethane "non-traffic-grade" sealant suitable for continuous liquid immersion.
 - 4. Joints between Fixtures in Wet Areas and Floors, Walls, and Ceilings: Mildew-resistant silicone sealant.
 - a. Use white color aound plumbing fixtures; use clear color around other fixtures.
- C. Interior Wet Areas: restrooms and kitchenettes; fixtures in wet areas include plumbing fixtures, countertops, cabinets, and other similar items.

2.03 JOINT SEALANTS - GENERAL

A. Sealants and Primers: Provide products with acceptable levels of volatile organic compound (VOC) content; see Section 01 61 16.

2.04 NONSAG JOINT SEALANTS

- A. Mildew-Resistant Silicone Sealant: ASTM C920, Grade NS, Uses M and A; single component, mildew resistant; not expected to withstand continuous water immersion or traffic.
 - 1. Colors: White and clear.
- B. Polyurethane Sealant: ASTM C920, Grade NS, Uses M and A; single or multi-component; not expected to withstand continuous water immersion or traffic.
 - 1. Hardness Range: 35 to 45, Shore A, when tested in accordance with ASTM C661.
 - 2. Products:
 - a. Sika Corporation; Sikaflex-15 LM: www.usa-sika.com.
 - b. Sika Corporation; Sikaflex-2c NS: www.usa-sika.com.
 - c. Tremco Commercial Sealants & Waterproofing; Dymonic 100: www.tremcosealants.com.
 - d. Substitutions: See Section 01 60 00 Product Requirements.
- C. Polyurethane Sealant for Continuous Water Immersion: ASTM C920, Grade NS, Uses M and A; single or multi-component; explicitly approved by manufacturer for continuous water immersion; suitable for traffic exposure when recessed below traffic surface.
 - 1. Products:
 - a. Sika Corporation; Sikaflex-2c NS: www.usa-sika.com.
 - b. Substitutions: See Section 01 60 00 Product Requirements.
- D. Acrylic-Urethane Sealant: ASTM C920, Grade NS, Uses M and A; single component; paintable; not expected to withstand continuous water immersion or traffic.
 - 1. Products:
 - a. Sherwin-Williams Company; Shermax Urethanized Elastomeric Sealant: www.sherwinwilliams.com.
 - b. Top Gun, a brand of PPG Architectural Coatings; Top Gun 400: www.ppgpaints.com.

c. Substitutions: See Section 01 60 00 - Product Requirements.

2.05 ACCESSORIES

- A. Sealant Backing Rod, Closed-Cell Type:
 - 1. Cylindrical flexible sealant backings complying with ASTM C1330 Type C.
 - 2. Size: 25 to 50 percent larger in diameter than joint width.
- B. Sealant Backing Rod, Bi-Cellular Type:
 - 1. Cylindrical flexible sealant backings complying with ASTM C1330 Type B.
 - 2. Size: 25 to 50 percent larger in diameter than joint width.
- C. Backing Tape: Self-adhesive polyethylene tape with surface that sealant will not adhere to and recommended by tape and sealant manufacturers for specific application.
- D. Masking Tape: Self-adhesive, nonabsorbent, nonstaining, removable without adhesive residue, and compatible with surfaces adjacent to joints and sealants.
- E. Joint Cleaner: Noncorrosive and nonstaining type, type recommended by sealant manufacturer; compatible with joint forming materials.
- F. Primers: Type recommended by sealant manufacturer to suit application; nonstaining.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify that joints are ready to receive work.
- B. Verify that backing materials are compatible with sealants.

3.02 PREPARATION

- A. Remove loose materials and foreign matter that could impair adhesion of sealant.
- B. Clean joints, and prime as necessary, in accordance with manufacturer's instructions.
- C. Perform preparation in accordance with manufacturer's instructions and ASTM C1193.
- D. Mask elements and surfaces adjacent to joints from damage and disfigurement due to sealant work; be aware that sealant drips and smears may not be completely removable.
- E. Concrete Floor Joints That Will Be Exposed in Completed Work: Test joint filler in an inconspicuous area to verify that it does not stain or discolor slab.

3.03 INSTALLATION

- A. Install this work in accordance with sealant manufacturer's requirements for preparation of surfaces and material installation instructions.
- B. Provide joint sealant installations complying with ASTM C1193.
- C. Measure joint dimensions and size joint backers to achieve width-to-depth ratio, neck dimension, and surface bond area as recommended by manufacturer, except where specific dimensions are indicated.
- D. Install bond breaker backing tape where backer rod cannot be used.

- E. Install sealant free of air pockets, foreign embedded matter, ridges, and sags, and without getting sealant on adjacent surfaces.
- F. Do not install sealant when ambient temperature is outside manufacturer's recommended temperature range, or will be outside that range during the entire curing period, unless manufacturer's approval is obtained and instructions are followed.
- G. Nonsag Sealants: Tool surface concave, unless otherwise indicated; remove masking tape immediately after tooling sealant surface.

3.04 POST-OCCUPANCY

A. Post-Occupancy Inspection: Perform visual inspection of entire length of project sealant joints at a time that joints have opened to their greatest width, i.e., at low temperature in thermal cycle. Report failures immediately and repair them.

SECTION 08 12 13 HOLLOW METAL FRAMES

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Non-fire-rated hollow metal frames for wood doors.
- B. Interior glazed borrowed lite frames.

1.02 RELATED REQUIREMENTS

- A. Section 08 71 00 Door Hardware: Hardware, silencers, and weatherstripping.
- B. Section 08 80 00 Glazing: Glazed borrowed lites.
- C. Section 09 90 00 Painting and Coating: Field Painting.

1.03 REFERENCE STANDARDS

- A. ADA Standards 2010 ADA Standards for Accessible Design; 2010.
- B. ANSI/SDI A250.4 Test Procedure and Acceptance Criteria for Physical Endurance for Steel Doors, Frames and Frame Anchors; 2024.
- C. ANSI/SDI A250.8 Specifications for Standard Steel Doors and Frames (SDI-100); 2023.
- D. ANSI/SDI A250.10 Test Procedure and Acceptance Criteria for Prime Painted Steel Surfaces for Steel Doors and Frames; 2020.
- E. ASTM A653/A653M Standard Specification for Steel Sheet, Zinc-Coated (Galvanized) or Zinc-Iron Alloy-Coated (Galvannealed) by the Hot-Dip Process; 2023.
- F. ASTM A1008/A1008M Standard Specification for Steel, Sheet, Cold-Rolled, Carbon, Structural, High-Strength Low-Alloy, High-Strength Low-Alloy with Improved Formability, Required Hardness, Solution Hardened, and Bake Hardenable; 2023, with Editorial Revision.
- G. ASTM A1011/A1011M Standard Specification for Steel, Sheet and Strip, Hot-Rolled, Carbon, Structural, High-Strength Low-Alloy, High-Strength Low-Alloy with Improved Formability, and Ultra-High Strength; 2023.
- H. BHMA A156.115 Hardware Preparation in Steel Doors and Frames; 2016.
- I. ICC A117.1 Accessible and Usable Buildings and Facilities; 2017.
- J. NAAMM HMMA 830 Hardware Selection for Hollow Metal Doors and Frames; 2002.
- K. NAAMM HMMA 831 Hardware Locations for Hollow Metal Doors and Frames; 2011.
- L. NAAMM HMMA 840 Guide Specifications for Receipt, Storage and Installation of Hollow Metal Doors and Frames; 2024.
- M. NAAMM HMMA 861 Guide Specifications for Commercial Hollow Metal Doors and Frames; 2014.
- N. SDI 117 Manufacturing Tolerances for Standard Steel Doors and Frames; 2023.

1.04 SUBMITTALS

- A. See Section 01 30 00 Administrative Requirements for submittal procedures.
- B. Product Data: Materials and details of design and construction, hardware locations, reinforcement type and locations, anchorage and fastening methods, and finishes; and one copy of referenced grade standard.
- C. Shop Drawings: Details of each opening, showing elevations, glazing, frame profiles, and identifying location of different finishes, if any.
- D. Installation Instructions: Manufacturer's published instructions, including any special installation instructions relating to this project.

1.05 QUALITY ASSURANCE

A. Installer Qualifications: Company specializing in performing work of the type specified and with at least five years of experience.

1.06 DELIVERY, STORAGE, AND HANDLING

- A. Store in accordance with applicable requirements and in compliance with standards and/or custom guidelines as indicated.
- B. Protect with resilient packaging; avoid humidity build-up under coverings; prevent corrosion.

PART 2 PRODUCTS

2.01 MANUFACTURERS

- A. Hollow Metal Frames:
 - 1. Ceco Door, an Assa Abloy Group company: www.assaabloydss.com.
 - 2. Curries, an Assa Abloy Group company: www.assaabloydss.com.
 - 3. Republic Doors, an Allegion brand: www.republicdoor.com.
 - 4. Steelcraft, an Allegion brand: www.allegion.com/us.
 - 5. Substitutions: See Section 01 60 00 Product Requirements.

2.02 PERFORMANCE REQUIREMENTS

- A. Hollow Metal Frames: Design and size components to support assembly dead loads, and to withstand live loads caused by positive and negative wind pressure acting normal to plane of side hinged doors.
- B. Refer to Door and Frame Schedule on drawings for frame sizes, finishing, door hardware to be installed, and other variations, if any.
- C. Steel Sheet: Comply with one or more of the following requirements; galvannealed steel complying with ASTM A653/A653M, cold-rolled steel complying with ASTM A1008/A1008M, or hot-rolled pickled and oiled (HRPO) steel complying with ASTM A1011/A1011M, commercial steel (CS) Type B, for each.
- D. Accessibility: Comply with ICC A117.1 and ADA Standards.

- E. Glazed Lights: Non-removable stops on non-secure side; sizes and configurations as indicated on drawings. Style: Manufacturers standard.
- F. Hardware Preparations, Selections and Locations: Comply with BHMA A156.115, NAAMM HMMA 830, NAAMM HMMA 831 or ANSI/SDI A250.8 (SDI-100) in accordance with specified requirements.
- G. Zinc Coating: Components zinc-coated (galvanized) and/or zinc-iron alloy-coated (galvannealed) by the hot-dip process in accordance with ASTM A653/A653M, with manufacturer's standard coating thickness, unless noted otherwise.
- H. Frames for Interior Glazing or Borrowed Lites: Construction and face dimensions to match door frames, and as indicated on drawings.
- I. Frames Wider than 48 Inches: Reinforce with steel channel fitted tightly into head of frame, and flush with top.

2.03 HOLLOW METAL DOOR FRAMES

- A. Interior Door Frames, Non-Fire Rated: Face welded type.
 - 1. Based on SDI Standards: ANSI/SDI A250.8 (SDI-100).
 - a. Level 3 Extra Heavy-duty.
 - b. Physical Performance Level A 1 000 000 cycles; in accordance with ANSI/SDI A250.4.
 - c. Frame Metal Thickness: 16 gauge, 0.053 inch, minimum.
 - d. Zinc Coating: A40/ZF120 galvannealed coating; ASTM A653/A653M.
 - 2. Frame Finish: Factory primed and field finished.

2.04 FINISHES

A. Primer: Rust-inhibiting, complying with ANSI/SDI A250.10, door manufacturer's standard.

2.05 ACCESSORIES

- A. Silencers: Resilient rubber, fitted into drilled hole; provide three on strike side of single door, three on center mullion of pairs, and two on head of pairs without center mullions.
- B. Temporary Frame Spreaders: Provide for factory- or shop-assembled frames.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify existing conditions before starting work.
- B. Verify that opening sizes and tolerances are acceptable.
- C. Verify that finished walls are in plane to ensure proper door alignment.

3.02 INSTALLATION

- A. Install frames in accordance with manufacturer's instructions and related requirements of specified frame standards or custom guidelines indicated.
- B. Coordinate frame anchor placement with wall construction.
- C. Comply with glazing installation requirements of Section 08 80 00.

- D. Install door hardware as specified in Section 08 71 00.
- E. Coordinate installation of electrical connections to electrical hardware items.
- F. Touch up damaged factory finishes.

3.03 TOLERANCES

- A. Clearances Between Door and Frame: Comply with related requirements of specified frame standards or custom guidelines indicated in accordance with SDI 117 or NAAMM HMMA 861.
- B. Maximum Diagonal Distortion: 1/16 inch measured with straight edges, crossed corner to corner.

3.04 SCHEDULE

A. Refer to Door and Frame Schedule on the Drawings.

SECTION 08 14 16 FLUSH WOOD DOORS

PART 1 GENERAL

1.01 SECTION INCLUDES

A. Flush wood doors; flush and flush glazed configuration; fire-rated and non-rated.

1.02 RELATED REQUIREMENTS

- A. Section 08 12 13 Hollow Metal Frames.
- B. Section 08 71 00 Door Hardware.
- C. Section 08 80 00 Glazing.

1.03 REFERENCE STANDARDS

- A. AWI/AWMAC/WI (AWS) Architectural Woodwork Standards, 2nd Edition; 2014, with Errata (2016).
- B. AWMAC/WI (NAAWS) North American Architectural Woodwork Standards; 2021, with Errata.
- C. ICC (IBC) International Building Code; Most Recent Edition Adopted by Authority Having Jurisdiction, Including All Applicable Amendments and Supplements.
- D. NFPA 80 Standard for Fire Doors and Other Opening Protectives; 2022.

1.04 SUBMITTALS

- A. See Section 01 30 00 Administrative Requirements for submittal procedures.
- B. Product Data: Indicate door core materials and construction; veneer species, type and characteristics.
- C. Shop Drawings: Show doors and frames, elevations, sizes, types, swings, undercuts, beveling, blocking for hardware, factory machining, factory finishing, cutouts for glazing and other details.
- D. Samples: Submit two samples of door veneer, 9 by 12 inches in size illustrating wood grain, stain color, and sheen.
- E. Manufacturer's Installation Instructions: Indicate special installation instructions.

1.05 QUALITY ASSURANCE

- A. Manufacturer Qualifications: Company specializing in manufacturing the products specified in this section, with not less than ten years of experience.
- B. Installer Qualifications: Company specializing in performing work of the type specified in this section, with not less than five years of experience.

1.06 DELIVERY, STORAGE, AND HANDLING

- A. Package, deliver and store doors in accordance with specified quality standard.
- B. Accept doors on site in manufacturer's packaging, and inspect for damage.

C. Protect doors with resilient packaging sealed with heat shrunk plastic; do not store in damp or wet areas or areas where sunlight might bleach veneer; seal top and bottom edges with tinted sealer if stored more than one week, and break seal on site to permit ventilation.

1.07 WARRANTY

A. See Section 01 78 00 - Closeout Submittals for additional warranty requirements.

PART 2 PRODUCTS

2.01 MANUFACTURERS

- A. Wood Veneer Faced Doors:
 - 1. Masonite Architectural: www.architectural.masonite.com.
 - 2. Oshkosh Door Company: www.oshkoshdoor.com.
 - 3. VT Industries, Inc: www.vtindustries.com.
 - 4. Substitutions: See Section 01 60 00 Product Requirements.

2.02 DOORS

- A. Doors: See drawings for locations and additional requirements.
 - 1. Quality Standard: Premium Grade, Heavy Duty performance, in accordance with AWI/AWMAC/WI (AWS) or AWMAC/WI (NAAWS), unless noted otherwise.
 - 2. Wood Veneer Faced Doors: 5-ply unless otherwise indicated.
- B. Interior Doors: 1-3/4 inches thick unless otherwise indicated; flush construction.
 - 1. Provide solid core doors at each location.
 - Fire Rated Doors: Tested to ratings indicated on drawings in accordance with ICC (IBC) -Positive Pressure; Underwriters Laboratories Inc. (UL) or Intertek/Warnock Hersey (WHI) labeled without any visible seals when door is open.

2.03 DOOR AND PANEL CORES

- A. Non-Rated Solid Core and 20 Minute Rated Doors: Type particleboard core (PC), plies and faces as indicated.
- B. Fire-Rated Doors: Mineral core type, with fire resistant composite core (FD), plies and faces as indicated above; with core blocking as required to provide adequate anchorage of hardware without through-bolting.

2.04 DOOR FACINGS

- A. Veneer Facing for Transparent Finish: Red oak, veneer grade in accordance with quality standard indicated, plain sliced (flat cut), with book match between leaves of veneer, running match of spliced veneer leaves assembled on door or panel face.
 - 1. Vertical Edges: Any option allowed by quality standard for grade.
 - 2. "Running Match" each pair of doors and doors in close proximity to each other.
 - 3. "Pair Match" each pair of doors; "Set Match" pairs of doors within 10 feet of each other when doors are closed.

2.05 DOOR CONSTRUCTION

A. Fabricate doors in accordance with door quality standard specified.

- B. Provide solid blocks at lock edge for hardware reinforcement.
 - 1. Provide solid blocking for other throughbolted hardware.
- C. Glazed Openings: Non-removable stops on non-secure side; sizes and configurations as indicated on drawings.
- D. Factory machine doors for hardware other than surface-mounted hardware, in accordance with hardware requirements and dimensions.
- E. Factory fit doors for frame opening dimensions identified on shop drawings, with edge clearances in accordance with specified quality standard.
- F. Provide edge clearances in accordance with the quality standard specified.

2.06 FINISHES - WOOD VENEER DOORS

- A. Finish work in accordance with AWI/AWMAC/WI (AWS) or AWMAC/WI (NAAWS), Section 5 Finishing for grade specified and as follows:
 - 1. Transparent:
 - a. System 9, UV Curable, Acrylated Epoxy, Polyester or Urethane.
 - b. Stain: Match VT Industries "Oasis OA18"
 - c. Sheen: Satin.

2.07 ACCESSORIES

- A. Hollow Metal Door Frames: See Section 08 12 13.
- B. Glazing Stops: Wood, of same species as door facing, butted corners; prepared for countersink style tamper proof screws.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify existing conditions before starting work.
- B. Verify that opening sizes and tolerances are acceptable.
- C. Do not install doors in frame openings that are not plumb or are out-of-tolerance for size or alignment.

3.02 INSTALLATION

- A. Install doors in accordance with manufacturer's instructions and specified quality standard.
 1. Install fire-rated doors in accordance with NFPA 80 requirements.
- B. Factory-Finished Doors: Do not field cut or trim; if fit or clearance is not correct, replace door.
- C. Trim fire-rated doors in strict compliance with fire rating limitations.
- D. Use machine tools to cut or drill for hardware.
- E. Coordinate installation of doors with installation of frames and hardware.
- F. Coordinate installation of glazing.

3.03 TOLERANCES

- A. Comply with specified quality standard for fit and clearance tolerances.
- B. Comply with specified quality standard for telegraphing, warp, and squareness.

3.04 ADJUSTING

- A. Adjust doors for smooth and balanced door movement.
- B. Adjust closers for full closure.

3.05 SCHEDULE

A. See Door and Frame Schedule on the Drawings.

SECTION 08 31 00 ACCESS DOORS AND PANELS

PART 1 GENERAL

1.01 SECTION INCLUDES

A. Ceiling mounted access units.

1.02 RELATED REQUIREMENTS

A. Section 09 90 00 - Painting and Coating: Field paint finish.

1.03 REFERENCE STANDARDS

- A. ASTM A36/A36M Standard Specification for Carbon Structural Steel; 2019.
- B. ASTM A500/A500M Standard Specification for Cold-Formed Welded and Seamless Carbon Steel Structural Tubing in Rounds and Shapes; 2018.
- C. ASTM A1008/A1008M Standard Specification for Steel, Sheet, Cold-Rolled, Carbon, Structural, High-Strength Low-Alloy, High-Strength Low-Alloy with Improved Formability, Solution Hardened, and Bake Hardenable; 2018.
- D. ASTM A1011/A1011M Standard Specification for Steel, Sheet and Strip, Hot-Rolled, Carbon, Structural, High-Strength Low-Alloy, High-Strength Low-Alloy with Improved Formability, and Ultra-High Strength; 2014.

1.04 SUBMITTALS

- A. See Section 01 30 00 Administrative Requirements, for submittal procedures.
- B. Product Data: Provide sizes, types, finishes, hardware, scheduled locations, and details of adjoining work.
- C. Manufacturer's Installation Instructions: Indicate installation requirements.

1.05 QUALITY ASSURANCE

- A. Manufacturer Qualifications: Company specializing in manufacturing the products specified in this section with minimum three years experience.
- B. Installer Qualifications: Company specializing in performing work of the type specified and with at least three years experience.

PART 2 PRODUCTS

2.01 ACCESS DOORS AND PANELS ASSEMBLIES

- A. Ceiling-Mounted Units:
 - 1. Location: As indicated on drawings.
 - 2. Panel Material: Aluminum extrusion with gypsum board inlay.
 - 3. Size Lay-In Grid Ceilings: To match module of ceiling grid.
 - 4. Size Other Ceilings: 24 inch by 24 inch.
 - 5. Door/Panel: Standard Dut

2.02 CEILING MOUNTED ACCESS UNITS

- A. Manufacturers:
 - 1. Activar Construction Products Group JL Industries: www.activarcpg.com/#sle.
 - 2. ACUDOR Products Inc: www.acudor.com/#sle.
 - 3. Bauco Access Panel Solutions Inc: www.accesspanelsolutions.com/#sle.
 - 4. Cendrex, Inc: www.cendrex.com/#sle.
 - 5. Milcor, Inc: www.milcorinc.com/#sle.
 - 6. Substitutions: See Section 01 60 00 Product Requirements.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify that rough openings are correctly sized and located.
- B. Begin installation only after substrates have been properly prepared, and if the responsibility of another installer, notify Architect of unsatisfactory preparation before proceeding.

3.02 PREPARATION

- A. Clean surfaces thoroughly prior to proceeding with this work.
- B. Prepare surfaces using methods recommended by manufacturer for applicable substrates in accordance with project conditions.

3.03 INSTALLATION

- A. Install units in accordance with manufacturer's instructions.
- B. Install frames plumb and level in openings, and secure units rigidly in place.
- C. Position units to provide convenient access to concealed equipment when necessary.

SECTION 08 56 53 SECURITY WINDOWS

PART 1 GENERAL

1.01 SECTION INCLUDES

A. Security transaction windows with pass-through device.

1.02 RELATED REQUIREMENTS

- A. Section 08 80 00 Glazing: Requirements for bullet-resistant glazing.
- B. Section 12 36 00 Countertops: Custom solid surface counter beneath transaction window.

1.03 REFERENCE STANDARDS

- A. AAMA 611 Voluntary Specification for Anodized Architectural Aluminum; 2020.
- B. ASTM A36/A36M Standard Specification for Carbon Structural Steel; 2019.
- C. ASTM A653/A653M Standard Specification for Steel Sheet, Zinc-Coated (Galvanized) or Zinc-Iron Alloy-Coated (Galvannealed) by the Hot-Dip Process; 2023.
- D. ASTM A1008/A1008M Standard Specification for Steel, Sheet, Cold-Rolled, Carbon, Structural, High-Strength Low-Alloy, High-Strength Low-Alloy with Improved Formability, Solution Hardened, and Bake Hardenable; 2018.
- E. ASTM B221 Standard Specification for Aluminum and Aluminum-Alloy Extruded Bars, Rods, Wire, Profiles, and Tubes; 2014.
- F. ASTM B221M Standard Specification for Aluminum and Aluminum-Alloy Extruded Bars, Rods, Wire, Profiles, and Tubes (Metric); 2013.
- G. UL (DIR) Online Certifications Directory; Current Edition.
- H. UL 752 Standard for Bullet-Resisting Equipment; Current Edition, Including All Revisions.

1.04 ADMINISTRATIVE REQUIREMENTS

A. Preinstallation Meeting: Prior to start of installation arrange a meeting on site to familiarize installer and installers of related work with requirements relating to this work.

1.05 SUBMITTALS

- A. See Section 01 30 00 Administrative Requirements for submittal procedures.
- B. Product Data: Manufacturer's published data showing materials, construction details, dimensions of components, and finishes.
- C. Shop Drawings: Drawings prepared specifically for this project, showing plans, elevations, sections, details of construction, anchorage to other work, hardware, and glazing.
 - 1. For new work show required opening dimensions and allowance for field deviation.
 - 2. For field glazed windows, include detailed instructions for glazing installation.

1.06 QUALITY ASSURANCE

- A. Manufacturer Qualifications: Firm with at least 10 years experience in the manufacture of windows of the type specified and able to provide test reports showing that their standard manufactured products meet the specified requirements; custom designed products not acceptable.
- B. Installer Qualifications: Company specializing in performing work of the type specified and with at least five years of experience.

1.07 WARRANTY

- A. See Section 01 78 00 Closeout Submittals for additional warranty requirements.
- B. Provide manufacturer's warranty agreeing to repair or replace windows and window components that fail within one year after Date of Substantial Completion due to, but not limited to, the following:
 - 1. Structural failure, failure of welds, and deterioration of metals and finishes beyond that expected under detention use and normal weathering.
 - 2. Failure of glazing due to excessive deflection of supporting members under wind load.
- C. Provide manufacturer's five-year warranty on laminated security glazing.

PART 2 PRODUCTS

2.01 MANUFACTURERS

- A. Security Transaction Windows with Pass-Through Device:
 - 1. Chicago Bullet Proof Systems: www.chicagobulletproof.com.
 - 2. Total Security Solutions: www.tssbulletproof.com.
 - 3. Substitutions: See Section 01 60 00 Product Requirements.

2.02 ASSEMBLIES

- A. Security and Detention Windows:
 - 1. Dimensions, profiles, features, and performance specified and indicated on drawings are required; do not deviate unless specifically approved by Architect/Engineer under substitution procedures; see Section 01 60 00.
 - 2. Design to fit openings indicated on drawings; design to accommodate deviation of actual construction from dimensions indicated on drawings.
 - 3. Fabricate frames and sash with corners mitered or coped full depth with concealed welded joints.
 - 4. Design anchorages to provide performance equivalent to that required for window unit; provide anchorages at least equivalent to those by which the tested units were anchored to the test frame.
 - 5. Design interface between frame and adjacent construction so that gap between them has at least the equivalent performance as specified for window; coordinate with anchorage requirements; custom testing is not required.
 - 6. Separate dissimilar metals to prevent corrosion by galvanic action by painting contact surfaces with primer or with sealant or tape recommended by manufacturer for the purpose.
 - 7. Weld components before finishing and in concealed locations, to greatest extent possible; minimize distortion and discoloration of finish; remove residue of welding; grind exposed welds

smooth and finish to match.

8. Label units to indicate which side is which, such as inside/outside or secure/non-secure; use labels that are removable after installation but durable enough not to be lost during delivery, storage, handling, and installation.

2.03 SECURITY TRANSACTION WINDOWS WITH PASS-THROUGH DEVICE

- A. Security Transaction Windows with Pass-Though Device:
 - 1. Location: Built within interior wall, as indicated on drawings.
 - 2. Type of Use: As indicated on drawings.
 - 3. Ballistic Resistance: Tested to meet UL 752, Level 3.
 - 4. Window Type: Fixed.
 - a. Frame Material: Aluminum.
 - 1) Finish: Color anodized.
 - 5. Glazing: Type BG1 Laminated, clear, and ballistic resistant see Section 08 80 00.
 - 6. Pass-Through Device: Deal tray built into window counter.
 - 7. Customization: Omit manufacturer's standard counter and coordinate installation of deal tray recessed into custom solid surface counter provided under Section 12 36 00 Countertops.
 - 8. Product:
 - a. Total Security Solutions; Aluminum BL 1.75 Transaction Window: www.tssbulletproof.com.
 - b. Substitutions: See Section 01 60 00 Product Requirements.

2.04 ASSEMBLY COMPONENTS

- A. Formed Steel Framing: ASTM A1008/A1008M, Designation CS (commercial steel), cold-rolled steel sheet; 12 gauge, 0.1046 inch minimum thickness.
- B. Galvannealed Formed Steel Framing: ASTM A653/A653M galvannealed to A60/ZF180 coating; 12 gauge, 0.1046 inch minimum base metal thickness.
- C. Rolled Steel Framing: ASTM A36/A36M steel shapes, plates, and bars.
- D. Aluminum Framing: ASTM B221 (ASTM B221M) extrusions of alloy and temper selected by manufacturer for strength, corrosion resistance, and finish required; not less than 1/8 inch thick at any location of frame and sash members.
- E. Frame Anchors: Mild steel plates, shapes, or bars, concealed in completed construction; provide anchorage devices as necessary to securely fasten windows to adjacent construction; use security fasteners for exposed anchors.
 - 1. Provide minimum of two anchors per side of window plus one additional anchor for each 18 inches or fraction thereof more than 36 inches in height or width.
- F. Glazing Seals: Factory installed; molded EPDM or neoprene compressible gaskets and compression strips.
- G. Deal Trays: Formed stainless steel, recessed into counter or sill for mounting under glazing frame.
 - 1. Style: Ricochet-resistant, with recessed bullet trap on secure side.
 - 2. Clear Opening Height: 1-1/2 inches.
 - 3. Tray Dimensions: 16 by 10 inches, wide by deep.
 - 4. Listed and labeled by UL as bullet resisting to UL 752 Level 3.

H. Speaking Aperture Covers: Stainless steel, round, allowing passage of speech at normal volume without distortion; listed and labeled by UL (DIR) as bullet resisting to UL 752, Level 3.

2.05 FINISHES

- A. Class I Color Anodized Finish: AAMA 611 AA-M12C22A44 Electrolytically deposited colored anodic coating not less than 0.7 mils thick.
- B. Color: Dark bronze.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify that window openings are ready for installation of windows.
- B. Notify Architect/Engineer if conditions are not suitable for installation of windows; do not proceed until conditions are satisfactory.

3.02 INSTALLATION

- A. Install in accordance with manufacturer's instructions and drawing details.
- B. Install windows in correct orientation (inside/outside or secure/non-secure).
- C. Anchor windows securely in manner so as to achieve performance specified.

3.03 CLEANING

- A. Clean exposed surfaces promptly after installation without damaging finishes.
- B. Remove and replace defective work.

SECTION 08 71 00 DOOR HARDWARE

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Hardware for wood doors.
- B. Hardware for fire-rated doors.
- C. Weatherstripping, seals and door gaskets.

1.02 RELATED REQUIREMENTS

- A. Section 08 12 13 Hollow Metal Frames.
- B. Section 08 14 16 Flush Wood Doors.

1.03 REFERENCE STANDARDS

- A. 36 CFR 1191 Americans with Disabilities Act (ADA) Accessibility Guidelines for Buildings and Facilities; Architectural Barriers Act (ABA) Accessibility Guidelines; current edition.
- B. ADA Standards 2010 ADA Standards for Accessible Design; 2010.
- C. BHMA A156.2 American National Standard for Bored and Preassembled Locks & Latches; 2011.
- D. BHMA A156.3 American National Standard for Exit Devices; 2014.
- E. BHMA A156.4 American National Standard for Door Controls Closers; 2013.
- F. BHMA A156.6 American National Standard for Architectural Door Trim; 2010.
- G. BHMA A156.8 American National Standard for Door Controls Overhead Stops and Holders; 2010.
- H. BHMA A156.13 American National Standard for Mortise Locks & Latches Series 1000; 2012.
- I. BHMA A156.18 American National Standard for Materials and Finishes; 2012.
- J. BHMA A156.31 American National Standard for Electric Strikes and Frame Mounted Actuators; 2013.
- K. BHMA A156.115 American National Standard for Hardware Preparation in Steel Doors and Steel Frames; 2014.
- L. DHI (LOCS) Recommended Locations for Architectural Hardware for Standard Steel Doors and Frames; 2004.
- M. DHI WDHS.3 Recommended Locations for Architectural Hardware for Flush Wood Doors; 1993; also in WDHS-1/WDHS-5 Series, 1996.
- N. ICC A117.1 Accessible and Usable Buildings and Facilities; 2009.
- O. NFPA 80 Standard for Fire Doors and Other Opening Protectives; 2016.
- P. UL (DIR) Online Certifications Directory; Current Edition.

1.04 ADMINISTRATIVE REQUIREMENTS

- A. Coordinate the manufacture, fabrication, and installation of products that door hardware will be installed upon.
- B. Furnish templates for door and frame preparation to manufacturers and fabricators of products requiring internal reinforcement for door hardware.
- C. Convey Owner's keying requirements to manufacturers.
- D. Preinstallation Meeting: Convene a preinstallation meeting one week prior to commencing work of this section; require attendance by all affected installers.
 - 1. Review with supplier, installers and related trades: Materials, rough-in and installation procedures, sequence of operation for each opening and coordination of related Work.
- E. Sequence installation to ensure utility connections are achieved in an orderly and expeditious manner.

1.05 SUBMITTALS

- A. See Section 01 30 00 Administrative Requirements, for submittal procedures.
- B. Product Data: Manufacturer's catalog literature for each type of hardware, marked to clearly show products to be furnished for this project. Include catalog cuts, installation details, material descriptions, dimensions of individual components and profiles, and finishes.
- C. Submittal Sequence:
 - 1. Door hardware supplier to visit site for a keying meeting with Owner prior to submitting schedules for review. Coordinate keying with shop drawings submittal.
 - 2. Submit hardware schedule at earliest possible date, so as not to delay fabrication of other work. Note long lead items that may be of particular concern.
- D. Final Hardware Schedule: Detailed listing of each item of hardware to be installed on each door. Use door numbering scheme as included in the Contract Documents. Identify electrically operated items and include power requirements. Coordinate with doors, frames and related work to ensure proper size, thickness, hand, function, and finish of door hardware.
 - 1. Format: Comply with scheduling sequence and vertical format in DHI SEQF.
 - 2. Organization: Organize the Door Hardware Schedule into door hardware sets indicating complete designations of every item required for each door or opening.
 - 3. Content: Schedules without the following will not be acceptable:
 - a. Location, type, style, function, size, fire rating, hand, and finish of each door hardware item.
 - b. Manufacturer of each item.
 - c. Fastenings and other pertinent information
 - d. Cross reference of specification set number to schedule item number.
 - e. Cross reference manufacturer's product numbers of each type of Hardware specified to the specified hardware included in schedule.
 - f. door index.
 - g. Explanation of abbreviations, symbols, and codes contained in schedule.
 - h. Mounting locations for door hardware.
 - i. Door and frame sizes and materials.

- 4. Include in Hardware Schedule a description of each electrified door hardware function, including product's location sequence of operation, and interface with other building control systems.
 - a. Sequence of Operation: include description of component functions that occur in the following situations: outside operation, inside operation, LED indicators, power on/power off and any other pertinent information.
- E. Keying Schedule: Submit for approval of Owner.
- F. Manufacturer's Installation Instructions: Indicate special procedures, perimeter conditions requiring special attention.
- G. Maintenance Data: Include data on operating hardware, lubrication requirements, and inspection procedures related to preventative maintenance.
 - 1. Submit manufacturer's parts lists and templates.
 - 2. Bitting List: List of combinations as furnished, indexed by key set number and door number.
- H. Keys: Deliver with identifying tags to Owner by security shipment direct from hardware supplier.
- I. Warranty: Submit manufacturer's warranty and ensure that forms have been completed in Owner's name and registered with manufacturer.
- J. Project Record Documents: Record actual locations of concealed equipment, services, and conduit.

1.06 QUALITY ASSURANCE

- A. Manufacturer Qualifications: Company specializing in manufacturing the products specified in this section with minimum three years of documented experience.
- B. Hardware Supplier Qualifications: Company specializing in supplying commercial door hardware with 10 years of documented experience.
- C. Hardware Supplier Personnel: Employ an Architectural Hardware Consultant (AHC), certified by DHI, to prepare hardware schedules, perform Post Installation Inspection, and otherwise assist in the work of this section.
- D. Hardware Installer: Factory-authorized personnel certified for installation of the Products of this Section.

1.07 KEYING MEETING

- A. Arrange meeting with door hardware supplier and Owner. Submit keying schedule for Architect's review after this meeting.
- B. Review with supplier, installers and related trades: Materials, rough-in and installation procedures, sequence of operation for each opening and coordination of related Work.

1.08 DELIVERY, STORAGE, AND HANDLING

A. Package hardware items individually; label and identify each package with door opening code to match hardware schedule.

1.09 WARRANTY

A. Provide manufacturer's three year warranty for locksets & 5 year warranty for door closers.

PART 2 PRODUCTS

2.01 DOOR HARDWARE - GENERAL

- A. Provide hardware specified or required to make doors fully functional, compliant with applicable codes, and secure to the extent indicated.
- B. Provide items of a single type of the same model by the same manufacturer.
- C. Provide products that comply with the following:
 - 1. Applicable provisions of federal, state, and local codes.
 - 2. Accessibility: ADA Standards and ICC A117.1.
 - 3. Fire-Rated Doors: NFPA 80.
 - 4. Hardware Preparation for Steel Doors and Steel Frames: BHMA A156.115.
 - 5. Hardware for Smoke and Draft Control Doors (Indicated as "S" on Drawings): Provide hardware that enables door assembly to comply with air leakage requirements of the applicable code.
 - 6. Products Requiring Electrical Connection: Listed and classified by UL (DIR) as suitable for the purpose specified and indicated.
- D. Function: Lock and latch function numbers and descriptions of manufactures series as shown on the drawings.
- E. Finishes: Provide door hardware of the same finish unless otherwise indicated.
 - 1. Finish: Satin chrome plated over nickel on brass or bronze, 626 (approx US26D).
 - 2. Finish Definitions: BHMA A156.18.
 - 3. Exceptions:
 - a. Where base metal is specified to be different, provide finish that is an appearance equivalent according to BHMA A156.18.
 - b. Hinges for Fire-Rated Doors: Steel base metal with plated finish.
- F. Fasteners:
 - 1. Mineral Core Wood Doors: Sex bolts.

2.02 LOCKS AND LATCHES - GENERAL

- A. Locks: Provide a lock for every door, unless specifically indicated as not requiring locking.
 - 1. Hardware Sets indicate locking functions required for each door.
 - 2. If no hardware set is indicated for a swinging door provide an office lockset.
 - 3. Trim: Provide lever handle or pull trim on outside of all locks unless specifically stated to have no outside trim.
 - 4. Lock Cylinders: Provide key access on outside of all locks unless specifically stated to have no locking or no outside trim.
- B. Electrically Operated Lock Strikes: Fail secure unless otherwise indicated.
- C. Latches: Provide a latch for every door that is not required to lock, unless specifically indicated "push/pull" or "not required to latch".

2.03 CYLINDERS, KEYS AND KEYING

- A. Lock Cylinders: Tumbler type core.
 - 1. Comply with ANSI/BHMA A156.5 and ANSI/BHMA A156.13.
 - 2. Manufacturer:

- a. Schlage Lock Company: www.schlage.com.
- b. Substitutions: Not permitted.
- 3. Standard Security Cylinders: six-pin standard core.
 - a. Schlage 30-000 Series.
 - b. Provide cylinders to fill the requirements of the building and still allow the convenience of a single top level key to operate all interior locks.
- 4. Provide cams and/or tailpieces as required for locking devices required.
- 5. Finish: For each opening, match finish of lockset, exit device or other hardware component into which cylinder is inserted.
- B. Keying System: Grand master keyed.
 - 1. Key to Owner's existing building keying system.
 - Properly tag cylinders and keys to indicate their intended location and to enable Owner, with minimum effort, to incorporate into its key control system.
 - 3. When providing keying information, comply with DHI Handbook "Keying systems and nomenclature".

2.04 BUTT HINGES

- A. General: Provide hinges on every swinging door.
 - 1. Provide concealed five-knuckle, anti-friction bearing, button tip, full mortise butt hinges with square corners and non-rising loose pins unless otherwise indicated.
 - 2. Provide anti-friction bearing hinges at all doors having closers.
 - 3. Provide hinges in the quantities indicated.
 - 4. Provide non-removable pins or security studs on exterior outswinging doors.
 - 5. Provide non-removable pins security studs on outswinging doors at "secured" areas.
 - 6. Where electrified hardware is mounted in door leaf, provide power transfer hinges. Provide fouror eight-wire type as appropriate for complete installation of:
 - a. Concealed door monitoring contacts and other security access components.
 - b. Power transfer to/from other scheduled door hardware.
- B. Manufacturers Hinges:
 - 1. Assa Abloy Brands; McKinney: www.assaabloydss.com/#sle.
 - 2. Hager Companies: www.hagerco.com/#sle.
 - 3. Ives, an Allegion brand: www.allegion.com/us.
 - 4. Stanley, dormakaba Group: www.stanleyhardwarefordoors.com.
- C. Imported or So-Called "Economical" Hinges: Not acceptable.
- D. Quantity:
 - 1. Doors From 60 inches High up to 90 inches High: Three hinges per leaf.
- E. Material:
 - 1. Interior Door Leafs Up To 36 Inches Wide: Wrought or stainless steel, standard weight (0.134 inch).
- F. Size: Sufficient to clear trim and allow doors, otherwise free of obstruction, to open 180 degrees.
 - 1. $4\frac{1}{2} \times 4\frac{1}{2}$ inch: For door leafs up to 36 inches wide and $1\frac{3}{4}$ inches thick.
 - 2. 5 x 5 inch: For door leafs over 36 inches wide and/or over $1\frac{3}{4}$ inches thick.
- G. Finish: For each opening, match finish of other hardware components.

2.05 CYLINDRICAL LOCKS AND LATCHES

- A. Comply with ANSI/BHMA A156.2, Series 4000, Grade 1 requirements, except as noted below.
- B. Locking Functions: As defined in BHMA A156.2, and as follows:
 - 1. Passage: F75, no locking, always free entry and exit.
 - 2. Privacy: F76, emergency tool unlocks.
 - 3. Office: F81, key not required to lock, remains locked upon exit.
 - 4. Classroom: F84, key required to lock.
 - 5. Store Room: F86, key required to lock, may not be left unlocked.
- C. Manufacturers:
 - 1. Schlage, an Allegion brand: www.allegion.com/us.
 - 2. Substitutions: Not permitted.
- D. Single Source Responsibility: Provide locksets, latchsets, electrified locksets, and trim of one manufacturer as listed above for continuity of design and consideration of warranty.
- E. Heavy Duty Cylindrical Locksets and Latchsets:
 - 1. Mechanical Locks:
 - a. Model:
 - 1) Schlage ND Series.
 - 2. Function: As scheduled in the individual hardware sets.
 - 3. Construction: Comply with ANSI/ICC A117.1 accessibility requirements.
 - a. Lock Body: Corrosion resistant wrought steel.
 - 1) Provide non-ferrous lock bodies and internal parts in corrosive environment areas and wet areas.
 - b. Handing: Easily field reversible without disassembly of lock body case.
- F. Trim: Comply with ANSI/ICC A117.1 accessibility requirements, and with ANSI/BHMA A156.6 requirements for a minimum of 1,000 inch pounds of pressure without allowing access.
 - 1. Construction: Cast zinc with wrought roses of heavy cold-forged material; welded thru-posts bolted through the door and lock body.
 - 2. Lever and Rose Style:
 - a. Schlage Rhodes.
- G. Strikes: Curved lip with proper lip length to protect trim of the frame; match function of lock; straight strikes are acceptable for pairs of doors and deadbolt locks.
- H. Finish Hardware: BHMA 626 Satin Chromium Plated.

2.06 ELECTRIC STRIKES

- A. Comply with BHMA A156.31 and UL listed as a Burglary-Resistant Electric Door Strike; style to suit locks.
- B. Manufacturers Electric Strikes:
 - 1. Assa Abloy Brands; Folger Adam EDC, HES, or Securitron: www.assaabloydss.com.

2.07 EXIT DEVICES

A. Comply with ANSI/BHMA A156.3, Grade 1 requirements; comply with performance requirements of NFPA 80 and NFPA 101.

- B. Locking Functions: Functions as defined in BHMA A156.3, and as follows:
 - 1. Entry/Exit, Always-Latched: Key outside retracts latchbolt but does not unlock lever. Presentation of authorized credential at existing proximity reader engages lever to allow retraction of latchbolt.
- C. Manufacturers:
 - 1. Von Duprin, an Allegion brand: www.allegion.com/us.
 - 2. Substitutions: See Section 01 60 00 Product Requirements.
- D. Single Source Responsibility: Provide exit devices and trim, including electrified items, of one manufacturer as listed above for continuity of design and consideration of warranty.
- E. Models : Use for all doors except narrow stile doors.
 - 1. Von Duprin 99 Series.
- F. Performance: Provide units rated and successfully tested as follows:
 - 1. Rim Devices: 13,000,000 cycles.
 - 2. Security Rim Devices: 8,000,000 cycles.
 - 3. Vertical Rod Devices: 3,000,000 cycles.
 - 4. Mortise Devices: 6,000,000 cycles.
- G. Function: As listed in the individual hardware sets.
- H. Construction:
 - Heavy duty, chassis mounted design, with one piece removable covers, eliminating necessity of removing the device from the door for standard maintenance and keying requirements. Plastic parts are not acceptable.
 - 2. Rail Assemblies: Solid stainless steel, aluminum, brass or bronze base material, plated, painted or anodized to standard architectural finish specified.
 - 3. End Caps: Heavy weight; impact resistant; of same metal and finish as the rail assemblies.
 - 4. Handing: Furnish devices non-handed and capable of direct field conversion for all available trim functions
- I. Push Pads: Comply with NFPA 101 means of egress requirements.
 - 1. Dogging: Keyed cylinder; provide on all exit devices except for those installed on fire rated doors; to hold push pad in depressed position and latchbolt in retracted position.
- J. Latches: Stainless steel; Pullman type; deadlocking.
- K. Electrified Exit Devices:
 - 1. Motor Driven Electrified Lever Trim: Provide a power supply/controller exclusively for this function unless indicated otherwise on Drawings.
- L. Fire Rated Doors: Provide UL listed devices labeled "Fire Exit Hardware". Provide proper quantity and type of fasteners to install devices as tested and listed by UL and required by the manufacturer. Consult manufacturer's catalog and template book for specific requirements.
- M. Outside Trim: Heavy duty forged brass, fastened by means of concealed welded lugs and throughbolts from the inside.
- N. Finish: 626 Satin Chromium Plated.

2.08 CLOSERS

A. Comply with ANSI/BHMA A156.4, Grade 1 requirements; comply with ICC/ANSI A117.1 accessibility requirements for opening force and delayed action closing.

B. General:

- 1. Provide surface-mounted, door-mounted closers unless otherwise indicated.
- 2. Provide a door closer on every fire- and smoke-rated door. Spring hinges are not an acceptable self-closing device unless specifically so indicated.
- 3. At corridors, locate door-mounted closer on room side of door.
- 4. Provide appropriate arm assemblies, installation accessories, and special templating for each closer so that closer body and arm are mounted on non-public side of door opening and on the interior side of exterior openings, except where required otherwise in the hardware sets.
- 5. Provide inspection after installation by a factory representative to ensure proper adjustment and operation. File report with the architect after said visit has been made.
- C. Manufacturers:
 - 1. DORMA USA, Inc.: www.dorma.com.
 - 2. LCN, an Allegion brand: www.allegion.com/us.
 - 3. Substitutions: See Section 01 60 00 Product Requirements.
- D. Single Source Responsibility: All door closers to be of one manufacturer as listed above to provide for proper installation and servicing after installation.
- E. Models:
 - 1. LCN 4040XP Series.
- F. Optional Functions: Provide as indicated in hardware sets.
 - 1. Cushion Stop: Heavy-duty arm and built-in spring-loaded stop in soffit shoe.
- G. Materials:
 - 1. Cylinders: High strength cast iron, with one-piece forged steel piston.
 - Hydraulic Fluid: Temperature stable fluid capable of withstanding temperature ranges of 120 degrees F. to -30F without requiring seasonal adjustment of closer speed to properly close the door.
 - 3. Arms: Forged steel with 1-9/16" x 1/2" steel stud shoulder bolts.
 - 4. Parallel Arms: Forged steel with bronze bushings.
 - 5. Covers: Plastic, with installation and adjusting information on inside of cover.
- H. Sizing: Double arm closers shall have non-sized cylinders adjustable over a range of at least 5 closing power sizes. Size closers in accordance with manufacturer's recommendations, depending upon size of door, exposure to weather, compliance with ADA requirements for operating force and anticipated frequency of use.
- Operation: Fully hydraulic, rack and pinion action with adjustable back-check to provide a cushioning effect toward the end of the closing cycle for double-arm closers; low friction track and roller combination for single arm closers. Provide back-check positioning valve and separate, noncritical valves for adjusting sweep and latch speeds.
- J. Finish: Powder coated aluminum matching finish of other hardware components for each opening.

2.09 STOPS AND HOLDERS

A. Comply with BHMA A156.8 requirements.

B. General:

- 1. Provide a stop for every swinging door.
- 2. Provide wall stops, unless otherwise indicated.
- 3. If wall stops are not practical, due to configuration of room or furnishings, provide overhead stop.
- 4. Locate stops in such a position that they permit maximum door swing, but do not present a hazard or obstruction.
- 5. Where overhead stops and holders are specified, or otherwise required for proper door operation, provide heavy duty assemblies of extruded brass or bronze with no plastic parts.
- 6. Stop is not required if stop function is specified for door closer.
- C. Manufacturers Wall Stops:
 - 1. Hager Companies: www.hagerco.com.
 - 2. Ives, an Allegion brand: www.allegion.com/us.
 - 3. Trimco, originally called Triangle Brass Manufacturing Co., Inc: www.trimcohardware.com.

D. Models:

- 1. Wall Stops:
 - a. Hager #232W.
 - b. lves #WS401/402.
 - c. Trimco #1270.
- E. Finish: For each opening, same as other hardware components, except use 32D and 32 (stainless steel) in lieu of 26D and 26 (plated chrome finishes), respectively, where available.

2.10 PROTECTION PLATES AND ARCHITECTURAL TRIM

- A. Comply with ANSI/BHMA A156.6 requirements.
- B. Protection Plates:
 - 1. Kickplate: Provide on push side of every door with closer, except aluminum storefront and glass entry doors.
 - 2. Mop Plates: Provide on door sides facing areas with hard surface floor finishes, unless kickplate or armor plate are specified.
 - 3. Width:
 - a. Pull side: 1 inch less than door width (LDW).
 - b. Push (Stop) Side: 2 inches less than door width (LDW).
 - 4. Height:
 - a. Kickplates: 10 inches.
 - b. Mop Plates: 6 inches.
 - c. Doors with louvers or narrow bottom rails: 1 inch less than dimension from the bottom of the door to the bottom of the louver or lite, or to the top of the bottom rail.
- C. Manufacturers:
 - 1. Assa Abloy Brands; McKinney: www.assaabloydss.com.
 - 2. C. R. Laurence Co., Inc: www.crl-arch.com.
 - 3. Hager Companies: www.hagerco.com.

- 4. Hiawatha, Inc, division of Activar Construction Products Group, Inc: www.activarcpg.com/hiawatha.
- 5. Ives, an Allegion brand: www.allegion.com/us.
- 6. Rockwood Manufacturing Company: www.rockwood.com.
- 7. Trimco, originally called Triangle Brass Manufacturing Co., Inc: www.trimcohardware.com.
- 8. Substitutions: See Section 01 60 00 Product Requirements.
- D. Finish: For each opening, same as other hardware components, except use 32D and 32 (stainless steel) in lieu of 26D and 26 (plated chrome finishes), respectively, where available.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify that doors and frames are ready to receive work; labeled, fire-rated doors and frames are present and properly installed, and dimensions are as indicated on shop drawings.
- B. Verify that electric power is available to power operated devices and of the correct characteristics.

3.02 INSTALLATION

- A. Install hardware in accordance with manufacturer's instructions and applicable codes.
- B. Use templates provided by hardware item manufacturer.
- C. Do not install surface mounted items until finishes applied to substrate are complete.
- D. Install hardware on fire-rated doors and frames in accordance with code and NFPA 80.
- E. Mounting heights for hardware from finished floor to center line of hardware item.
 - 1. For steel frames: Comply with DHI "Recommended Locations for Architectural Hardware for Steel Doors and Frames."
 - 2. For Wood Doors: Comply with DHI "Recommended Locations for Architectural Hardware for Wood Flush Doors."

3.03 FIELD QUALITY CONTROL

- A. Post Installation Inspection: Provide an Architectural Hardware Consultant to inspect installation and certify that hardware and installation has been furnished and installed in accordance with manufacturer's instructions and as specified.
 - 1. Submit report to Architect/Engineer after inspection has been made.

3.04 ADJUSTING

A. Adjust hardware for smooth operation.

3.05 CLEANING

A. Clean adjacent surfaces soiled by hardware installation. Clean finished hardware per manufacturer's instructions after final adjustments has been made. Replace items that cannot be cleaned to manufacturer's level of finish quality at no additional cost.

3.06 PROTECTION

A. Do not permit adjacent work to damage hardware or finish.

3.07 SCHEDULE

A. Refer to Door Hardware Schedule on the Drawings.

SECTION 08 80 00 GLAZING

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Glazing units.
- B. Laminated glass interlayers.

1.02 RELATED REQUIREMENTS

A. Section 08 56 53 - Security Windows: Glazing provided as part of security assembly.

1.03 REFERENCE STANDARDS

- A. 16 CFR 1201 Safety Standard for Architectural Glazing Materials; current edition.
- B. ANSI Z97.1 American National Standard for Safety Glazing Materials Used in Buildings Safety Performance Specifications and Methods of Test; 2015.
- C. ASTM C864 Standard Specification for Dense Elastomeric Compression Seal Gaskets, Setting Blocks, and Spacers; 2005 (Reapproved 2019).
- D. ASTM C1048 Standard Specification for Heat-Strengthened and Fully Tempered Flat Glass; 2012.
- E. ASTM C1172 Standard Specification for Laminated Architectural Flat Glass; 2014.
- F. ASTM C1193 Standard Guide for Use of Joint Sealants; 2013.
- G. ASTM F1233 Standard Test Method for Security Glazing Materials And Systems; 2021.
- H. GANA (GM) GANA Glazing Manual; 2022.
- I. GANA (SM) GANA Sealant Manual; 2008.
- J. GANA (LGRM) Laminated Glazing Reference Manual; 2019.
- K. UL 752 Standard for Bullet-Resisting Equipment; Current Edition, Including All Revisions.

1.04 SUBMITTALS

- A. See Section 01 30 00 Administrative Requirements for submittal procedures.
- B. Product Data on Glazing Unit and Plastic Film Glazing Types: Provide structural, physical and environmental characteristics, size limitations, special handling and installation requirements.
- C. Product Data on Accessories: Provide chemical, functional, and environmental characteristics, limitations, special application requirements, and identify available colors.
- D. Samples: Submit two samples 12 by 12 inch in size of glass units.
- E. Certificate: Certify that products of this section meet or exceed specified requirements.
- F. Warranty Documentation: Submit manufacturer warranty and ensure that forms have been completed in Owner's name and registered with manufacturer.

1.05 QUALITY ASSURANCE

- A. Perform Work in accordance with GANA (GM) and GANA (LGRM) for glazing installation methods.
- B. Manufacturer Qualifications: Company specializing in manufacturing the products specified in this section with minimum ten years of experience.
- C. Installer Qualifications: Company specializing in performing work of the type specified and with at least five years experience.

1.06 WARRANTY

- A. See Section 01 78 00 Closeout Submittals for additional warranty requirements.
- B. Laminated Glass: Provide a five (5) year manufacturer warranty to include coverage for delamination, including providing products to replace failed units.

PART 2 PRODUCTS

2.01 GLASS MATERIALS

- A. Float Glass: Provide float glass based glazing unless otherwise indicated.
 - 1. Kind FT Fully Tempered Type: Complies with ASTM C1048.
 - a. Complies with ANSI Z97.1 or 16 CFR 1201 criteria for safety glazing used in hazardous locations.
 - b. Complies with ANSI Z97.1 Class A and 16 CFR 1201 Category II criteria.
- B. Laminated Glass: Float glass laminated in accordance with ASTM C1172.
 - 1. Laminated Safety Glass: Complies with ANSI Z97.1 Class B or 16 CFR 1201 Category I impact test requirements.

2.02 GLAZING UNITS

- A. Type FG1 Monolithic Interior Vision Glazing:
 - 1. Applications: Interior glazing unless otherwise indicated.
 - 2. Glass Type: Fully tempered float glass.
 - 3. Tint: Clear.
 - 4. Thickness: 1/4 inch, nominal.
 - 5. Glazing Method: Tape and tape.
- B. Type BG1 Security Glazing: Laminated glass, multi-ply.
 - 1. Applications: Locations as indicated on drawings.
 - 2. Tint: Clear.
 - 3. Total Thickness: 1-1/4 inch.
 - a. Layer 1 (Threat Side): 3/8 inch thick glass.
 - b. Layer 2: 0.025 inch thick urethane.
 - c. Layer 3: 3/8 inch thick glass.
 - d. Layer 4: 0.075 inch thick urethane.
 - e. Layer 5: 1/8 inch thick polycarbonate.
 - f. Layer 6: 0.075 inch thick urethane.
 - g. Layer 7 (Secure Side): 3/16 inch glass.

- 4. Performance Criteria:
 - a. Bullet Resistance: Pass ASTM F1233 tests in compliance with ballistic criteria class indicated; Level 3 per UL 752.
- 5. Visible Light Transmittance (VLT): 75 percent, nominal.
- 6. Glazing Method: As required to meet performance criteria.
- 7. Manufacturers:
 - a. Total Security Solutions; TSS 003 LS 1 1/4" Glass Clad Polycarbonate: www.tssbulletproof.com.
 - b. Chicago Bullet Proof Systems; www.chicagobulletproof.com
 - c. Substitutions: See Section 01 60 00 Product Requirements.

2.03 ACCESSORIES

- A. Setting Blocks: Silicone, with 80 to 90 Shore A durometer hardness; ASTM C864 Option II. Length of 0.1 inch for each square foot of glazing or minimum 4 inch by width of glazing rabbet space minus 1/16 inch by height to suit glazing method and pane weight and area.
- B. Glazing Tape, Back Bedding Mastic Type: Preformed, butyl-based, 100 percent solids compound with integral resilient spacer rod applicable to application indicated; 5 to 30 cured Shore A durometer hardness; coiled on release paper; clear color.
- C. Glazing Splines: Resilient extruded shape to suit glazing channel retaining slot; ASTM C864 Option II; color black.

PART 3 EXECUTION

3.01 VERIFICATION OF CONDITIONS

- A. Verify that openings for glazing are correctly sized and within tolerances, including those for size, squareness, and offsets at corners.
- B. Verify that the minimum required face and edge clearances are being provided.
- C. Verify that surfaces of glazing channels or recesses are clean, free of obstructions that may impede moisture movement, weeps are clear, and support framing is ready to receive glazing system.
- D. Verify that sealing between joints of glass framing members has been completed effectively.
- E. Proceed with glazing system installation only after unsatisfactory conditions have been corrected.

3.02 PREPARATION

- A. Clean contact surfaces with appropriate solvent and wipe dry within maximum of 24 hours before glazing. Remove coatings that are not tightly bonded to substrates.
- B. Seal porous glazing channels or recesses with substrate compatible primer or sealer.
- C. Prime surfaces scheduled to receive sealant or tape where required for proper adhesion.

3.03 INSTALLATION, GENERAL

A. Install glazing in compliance with written instructions of glass, gaskets, and other glazing material manufacturers, unless more stringent requirements are indicated, including those in glazing referenced standards.

- B. Install glazing sealants in accordance with ASTM C1193, GANA (SM), and manufacturer's instructions.
- C. Do not exceed edge pressures around perimeter of glass lites as stipulated by glass manufacturer.
- D. Set glass lites of system with uniform pattern, draw, bow, and similar characteristics.
- E. Set glass lites in proper orientation so that coatings face exterior or interior as indicated.
- F. Prevent glass from contact with any contaminating substances that may be the result of construction operations such as, and not limited to the following; weld splatter, fire-safing, plastering, mortar droppings, etc.

3.04 INSTALLATION - DRY GLAZING METHOD (GASKET GLAZING)

- A. Application Exterior and/or Interior Glazed: Set glazing infills from either the exterior or the interior of the building.
- B. Place setting blocks at 1/4 points with edge block no more than 6 inch from corners.
- C. Rest glazing on setting blocks and push against fixed stop with sufficient pressure on gasket to attain full contact.
- D. Install removable stops without displacing glazing gasket; exert pressure for full continuous contact.

3.05 INSTALLATION - DRY GLAZING METHOD (TAPE AND TAPE)

- A. Application Interior Glazed: Set glazing infills from the interior of the building.
- B. Cut glazing tape to length and set against permanent stops, projecting 1/16 inch above sight line.
- C. Place setting blocks at 1/4 points with edge block no more than 6 inch from corners.
- D. Rest glazing on setting blocks and push against tape for full contact at perimeter of pane or unit.
- E. Place glazing tape on free perimeter of glazing in same manner described above.
- F. Install removable stop without displacement of tape. Exert pressure on tape for full continuous contact.
- G. Carefully trim protruding tape with knife.

3.06 FIELD QUALITY CONTROL

- A. Glass and Glazing product manufacturers to provide field surveillance of the installation of their products.
- B. Monitor and report installation procedures and unacceptable conditions.

3.07 CLEANING

- A. Remove excess glazing materials from finish surfaces immediately after application using solvents or cleaners recommended by manufacturers.
- B. Remove nonpermanent labels immediately after glazing installation is complete.
- C. Clean glass and adjacent surfaces after sealants are fully cured.

D. Clean glass on both exposed surfaces not more than 4 days prior to Date of Substantial Completion in accordance with glass manufacturer's written recommendations.

3.08 PROTECTION

- A. After installation, mark pane with an 'X' by using removable plastic tape or paste.
- B. Remove and replace glass that is damaged during construction period prior to Date of Substantial Completion.

SECTION 09 05 61 COMMON WORK RESULTS FOR FLOORING PREPARATION

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. This section applies to all floors identified in the contract documents as to receive the following types of floor coverings:
 - 1. Luxury Vinyl Plank.
 - 2. Porcelain Tile.
- B. Removal of existing floor coverings.
- C. Preparation of new and existing concrete floor slabs for installation of floor coverings.
- D. Testing of concrete floor slabs for moisture and alkalinity (pH). Testing shall be performed by General Contractor as Base Bid work.
- E. Contractor shall perform all specified testing & remediation of concrete floor slabs. If such remediation is indicated by testing agency's report and is due to a condition not under Contractor's control or could not have been predicted by examination prior to entering into the contract, a contract modification will be issued.
- F. Patching compound.
- G. Remedial floor coatings.

1.02 REFERENCE STANDARDS

- A. ASTM C109/C109M Standard Test Method for Compressive Strength of Hydraulic Cement Mortars (Using 2-in. or (50-mm) Cube Specimens); 2013.
- B. ASTM C472 Standard Test Methods for Physical Testing of Gypsum, Gypsum Plasters and Gypsum Concrete; 1999 (Reapproved 2014).
- C. ASTM F710 Standard Practice for Preparing Concrete Floors to Receive Resilient Flooring; 2022.
- D. ASTM F1869 Standard Test Method for Measuring Moisture Vapor Emission Rate of Concrete Subfloor Using Anhydrous Calcium Chloride; 2022.
- E. ASTM F2170 Standard Test Method for Determining Relative Humidity in Concrete Floor Slabs Using in situ Probes; 2019a.
- F. RFCI (RWP) Recommended Work Practices for Removal of Resilient Floor Coverings; 2011.

1.03 ADMINISTRATIVE REQUIREMENTS

A. Coordinate scheduling of cleaning and testing, so that preliminary cleaning has been completed for at least 24 hours prior to testing.

1.04 SUBMITTALS

- A. Visual Observation Report: For existing floor coverings to be removed.
- B. Floor Covering and Adhesive Manufacturers' Product Literature: For each specific combination of substrate, floor covering, and adhesive to be used; showing:

- 1. Moisture and alkalinity (pH) limits and test methods.
- 2. Manufacturer's required bond/compatibility test procedure.
- C. Testing Agency's Report:
 - 1. Description of areas tested; include floor plans and photographs if helpful.
 - 2. Summary of conditions encountered.
 - 3. Moisture and alkalinity (pH) test reports.
 - 4. Copies of specified test methods.
 - 5. Recommendations for remediation of unsatisfactory surfaces.
 - 6. Submit report to Architect/Engineer.
 - 7. Submit report not more than two business days after conclusion of testing.
- D. Adhesive Bond and Compatibility Test Report.
- E. Copy of RFCI (RWP).

1.05 QUALITY ASSURANCE

- A. Moisture and alkalinity (pH) testing shall be performed by an independent testing agency employed and paid by Contractor.
- B. Testing Agency Qualifications: Independent testing agency experienced in the types of testing specified.
 - 1. Submit evidence of experience consisting of at least 3 test reports of the type required, with project Owner's project contact information.
- C. Contractor's Responsibility Relating to Independent Agency Testing:
 - 1. Provide access for and cooperate with testing agency.
 - 2. Confirm date of start of testing at least 10 days prior to actual start.
 - 3. Allow at least 4 business days on site for testing agency activities.
 - 4. Achieve and maintain specified ambient conditions.
 - 5. Notify Architect/Engineer when specified ambient conditions have been achieved and when testing will start.

1.06 DELIVERY, STORAGE, AND HANDLING

- A. Deliver, store, handle, and protect products in accordance with manufacturer's instructions and recommendations.
- B. Deliver materials in manufacturer's packaging; include installation instructions.
- C. Keep materials from freezing.

1.07 FIELD CONDITIONS

- A. Maintain ambient temperature in spaces where concrete testing is being performed, and for at least 48 hours prior to testing, at not less than 65 degrees F or more than 85 degrees F.
- B. Maintain relative humidity in spaces where concrete testing is being performed, and for at least 48 hours prior to testing, at not less than 40 percent and not more than 60 percent.
PART 2 PRODUCTS

2.01 MATERIALS

- A. Patching Compound: Floor covering manufacturer's recommended product, suitable for conditions, and compatible with adhesive and floor covering. In the absence of any recommendation from flooring manufacturer, provide a product with the following characteristics:
 - 1. Cementitious moisture-, mildew-, and alkali-resistant compound, compatible with floor, floor covering, and floor covering adhesive, and capable of being feathered to nothing at edges.
 - 2. Latex or polyvinyl acetate additions are permitted; gypsum content is prohibited.
 - 3. Compressive Strength: 3000 psi, minimum, after 28 days, when tested in accordance with ASTM C109/C109M or ASTM C472, whichever is appropriate.
- B. Alternate Flooring Adhesive: Floor covering manufacturer's recommended product, suitable for the moisture and pH conditions present; low-VOC. In the absence of any recommendation from flooring manufacturer, provide a product recommended by adhesive manufacturer as suitable for substrate and floor covering and for conditions present.
- C. Remedial Floor Coating: Single- or multi-layer coating or coating/overlay combination intended by its manufacturer to resist water vapor transmission to degree sufficient to meet flooring manufacturer's emission limits, resistant to the level of alkalinity (pH) found, and suitable for adhesion of flooring without further treatment.
 - 1. Products:
 - a. ARDEX Engineered Cements; ARDEX MC RAPID: www.ardexamericas.com/#sle.
 - b. Custom Building Products; TechMVC Moisture Vapor and Alkalinity Barrier: www.custombuildingproducts.com/#sle.
 - c. Floor Seal Technology, Inc; MES 100 with Floor Seal FloorCem SLU: www.floorseal.com/#sle.
 - d. Koster American Corporation; Koster VAP I 2000 with Koster SL Premium overlay: www.kosterusa.com/#sle.
 - e. LATICRETE International, Inc; LATICRETE NXT Vapor Reduction Coating with LATICRETE NXT Level Plus: www.laticrete.com/#sle.
 - f. LATICRETE International, Inc; LATICRETE SUPERCAP Moisture Vapor Control with LATICRETE SUPERCAP Underlayment: www.laticrete.com/#sle.
 - g. Proflex Products, Inc; Moisture Barrier 25 with DPU Deep Pour Underlayment: www.proflex.us/#sle.
 - h. Sika Corporation; Sikafloor Moisture Tolerance Epoxy Primer and Sikafloor Self-Leveling Moisture Tolerant Resurfacer: www.sikafloorusa.com/#sle.
 - i. Stauf USA, LLC; ERP-270 Perma-Seal: www.staufusa.com/#sle.
 - j. UZIN, a division of UFLOOR Systems Inc; UZIN PE 460 with UZIN PE 280 and UZIN NC 170 LevelStar: www.ufloorsystems.com/#sle.

PART 3 EXECUTION

3.01 CONCRETE SLAB PREPARATION (BASE BID)

- A. Follow recommendations of testing agency.
- B. Perform following operations in the order indicated:
 - 1. Existing concrete slabs (on-grade and elevated) with existing floor coverings:

- a. Visual observation of existing floor covering, for adhesion, water damage, alkaline deposits, and other defects.
- b. Removal of existing floor covering.
- 2. Preliminary cleaning.
- 3. Moisture vapor emission tests; 3 tests in the first 1000 square feet and one test in each additional 1000 square feet, unless otherwise indicated or required by flooring manufacturer.
- 4. Internal relative humidity tests; in same locations as moisture vapor emission tests, unless otherwise indicated.
- Alkalinity (pH) tests; in same locations as moisture vapor emission tests, unless otherwise indicated.
- 6. Specified remediation, if required.
- 7. Patching, smoothing, and leveling, as required.
- 8. Other preparation specified.
- 9. Adhesive bond and compatibility test.
- 10. Protection.
- C. Remediations:
 - 1. Active Water Leaks or Continuing Moisture Migration to Surface of Slab: Correct this condition before doing any other remediation; re-test after correction.
 - Excessive Moisture Emission or Relative Humidity: If an adhesive that is resistant to the level
 of moisture present is available and acceptable to flooring manufacturer, use that adhesive for
 installation of the flooring; if not, apply remedial floor coating or remedial sheet membrane over
 entire suspect floor area.
 - 3. Excessive Alkalinity (pH): If remedial floor coating is necessary to address excessive moisture, no additional remediation is required; if not, if an adhesive that is resistant to the level present is available and acceptable to the flooring manufacturer, use that adhesive for installation of the flooring; otherwise, apply a skim coat of specified patching compound over entire suspect floor area.

3.02 REMOVAL OF EXISTING FLOOR COVERINGS (BASE BID)

- A. Comply with local, State, and federal regulations and recommendations of RFCI Recommended Work Practices for Removal of Resilient Floor Coverings, as applicable to floor covering being removed.
- B. Dispose of removed materials in accordance with local, State, and federal regulations and as specified.

3.03 PRELIMINARY CLEANING (BASE BID)

- A. Clean floors of dust, solvents, paint, wax, oil, grease, asphalt, residual adhesive, adhesive removers, film-forming curing compounds, sealing compounds, alkaline salts, excessive laitance, mold, mildew, and other materials that might prevent adhesive bond.
- B. Do not use solvents or other chemicals for cleaning.

3.04 MOISTURE VAPOR EMISSION TESTING (BASE BID)

A. Where the floor covering manufacturer's requirements conflict with either the referenced test method or this specification, comply with the manufacturer's requirements.

- B. Where this specification conflicts with the referenced test method, comply with the requirements of this section.
- C. Test in accordance with ASTM F1869 and as follows.
- D. Plastic sheet test and mat bond test may not be substituted for the specified ASTM test method, as those methods do not quantify the moisture content sufficiently.
- E. In the event that test values exceed floor covering manufacturer's limits, perform remediation as indicated. In the absence of manufacturer limits, perform remediation if test values exceed 3 pounds per 1000 square feet per 24 hours.
- F. Report: Report the information required by the test method.

3.05 INTERNAL RELATIVE HUMIDITY TESTING (BASE BID)

- A. Where the floor covering manufacturer's requirements conflict with either the referenced test method or this specification, comply with the manufacturer's requirements.
- B. Where this specification conflicts with the referenced test method, comply with the requirements of this section.
- C. Test in accordance with ASTM F2170 Procedure A and as follows.
- D. Testing with electrical impedance or resistance apparatus may not be substituted for the specified ASTM test method, as the values determined are not comparable to the ASTM test values and do not quantify the moisture content sufficiently.
- E. In the event that test values exceed floor covering manufacturer's limits, perform remediation as indicated. In the absence of manufacturer limits, perform remediation if any test value exceeds 75 percent relative humidity.
- F. Report: Report the information required by the test method.

3.06 ALKALINITY TESTING (BASE BID)

- A. Where the floor covering manufacturer's requirements conflict with either the referenced test method or this specification, comply with the manufacturer's requirements.
- B. The following procedure is the equivalent of that described in ASTM F710, repeated here for the Contractor's convenience.
 - 1. Use a wide range alkalinity (pH) test paper, its associated chart, and distilled or deionized water.
 - Place several drops of water on a clean surface of concrete, forming a puddle approximately 1 inch in diameter. Allow the puddle to set for approximately 60 seconds, then dip the alkalinity (pH) test paper into the water, remove it, and compare immediately to chart to determine alkalinity (pH) reading.
 - 3. Use of a digital pH meter with probe is acceptable; follow meter manufacturer's instructions.
- C. In the event that test values exceed floor covering manufacturer's limits, perform remediation as indicated. In the absence of manufacturer limits, perform remediation if alkalinity (pH) test value is over 10.

3.07 PREPARATION (BASE BID)

- A. See individual floor covering section(s) for additional requirements.
- B. Comply with recommendations of testing agency.
- C. Comply with requirements and recommendations of floor covering manufacturer.
- D. Fill and smooth surface cracks, grooves, depressions, control joints and other non-moving joints, and other irregularities with patching compound.
- E. Do not fill expansion joints, isolation joints, or other moving joints.

3.08 ADHESIVE BOND AND COMPATIBILITY TESTING (BASE BID)

A. Comply with requirements and recommendations of floor covering manufacturer.

3.09 APPLICATION OF REMEDIAL FLOOR COATING (CHANGE ORDER WORK)

A. Comply with requirements and recommendations of coating manufacturer.

3.10 PROTECTION (BASE BID)

A. Cover prepared floors with building paper or other durable covering.

SECTION 09 21 16 GYPSUM BOARD ASSEMBLIES

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Metal deflection relief top track for metal stud partitions.
- B. Acoustic insulation.
- C. Gypsum wallboard.
- D. Joint treatment and accessories.
- E. Bullet resistant sheathing and wallboard.

1.02 RELATED REQUIREMENTS

- A. Section 06 10 00 Rough Carpentry: Wood blocking product and execution requirements.
- B. Section 07 84 00 Firestopping: Top-of-wall assemblies at fire rated walls.

1.03 REFERENCE STANDARDS

- A. AISI S100-12 North American Specification for the Design of Cold-Formed Steel Structural Members; 2012.
- B. ASTM A653/A653M Standard Specification for Steel Sheet, Zinc-Coated (Galvanized) or Zinc-Iron Alloy-Coated (Galvannealed) by the Hot-Dip Process; 2023.
- C. ASTM C473 Standard Test Methods for Physical Testing of Gypsum Panel Products; 2010.
- D. ASTM C475/C475M Standard Specification for Joint Compound and Joint Tape for Finishing Gypsum Board; 2017 (Reapproved 2022).
- E. ASTM C645 Standard Specification for Nonstructural Steel Framing Members; 2018.
- F. ASTM C665 Standard Specification for Mineral-Fiber Blanket Thermal Insulation for Light Frame Construction and Manufactured Housing; 2023.
- G. ASTM C754 Standard Specification for Installation of Steel Framing Members to Receive Screw-Attached Gypsum Panel Products; 2020.
- H. ASTM C840 Standard Specification for Application and Finishing of Gypsum Board; 2023.
- ASTM C954 Standard Specification for Steel Drill Screws for the Application of Gypsum Panel Products or Metal Plaster Bases to Steel Studs from 0.033 in. (0.84 mm) to 0.112 in. (2.84 mm) in Thickness; 2022.
- J. ASTM C1002 Standard Specification for Steel Self-Piercing Tapping Screws for Application of Gypsum Panel Products or Metal Plaster Bases to Wood Studs or Steel Studs; 2022.
- K. ASTM C1047 Standard Specification for Accessories for Gypsum Wallboard and Gypsum Veneer Base; 2019.
- L. ASTM C1396/C1396M Standard Specification for Gypsum Board; 2017.

- M. ASTM E90 Standard Test Method for Laboratory Measurement of Airborne Sound Transmission Loss of Building Partitions and Elements; 2009 (Reapproved 2016).
- N. ASTM E413 Classification for Rating Sound Insulation; 2022.
- O. GA-216 Application and Finishing of Gypsum Panel Products; 2021.
- P. UL 752 Standard for Bullet-Resisting Equipment; Current Edition, Including All Revisions.

1.04 SUBMITTALS

- A. See Section 01 30 00 Administrative Requirements, for submittal procedures.
- B. Product Data: Provide data on metal framing, gypsum board, accessories, and joint finishing system.
- C. Product Data: Provide manufacturer's data on partition head to structure connectors, showing compliance with requirements.
- D. Test Reports: Bullet resistant sheathing and wallboard.

1.05 QUALITY ASSURANCE

A. Installer Qualifications: Company specializing in performing work of the type specified and with at least five years of experience.

PART 2 PRODUCTS

2.01 GYPSUM BOARD ASSEMBLIES

A. Provide completed assemblies complying with ASTM C840 and GA-216.1. See PART 3 for finishing requirements.

2.02 METAL FRAMING MATERIALS

- A. Manufacturers Metal Framing, Connectors, and Accessories:
 - 1. ClarkDietrich: www.clarkdietrich.com/#sle.
 - 2. Jaimes Industries: www.jaimesind.com/#sle.
 - 3. Marino: www.marinoware.com/#sle.
 - 4. Phillips Manufacturing Co: www.phillipsmfg.com.
 - 5. Steel Construction Systems: www.steelconsystems.com/#sle.
 - 6. The Steel Network, Inc: www.SteelNetwork.com.
 - 7. Substitutions: See Section 01 60 00 Product Requirements.
- B. Non-Loadbearing Framing System Components: ASTM C645; sheet steel galvanized to G60 class.
 - 1. Studs: "C" shaped with flat or formed webs with knurled faces.
 - 2. Runners: 20 ga., U shaped, 2 inch minimum leg depth, web width sized to match wood studs specified in Section 06 10 00.
 - 3. Ceiling Channels: C-shaped.
 - 4. Furring Members: Hat-shaped sections, minimum depth of 7/8 inch.

- C. Partition Head to Structure Connections: Provide mechanical anchorage devices that accommodate deflection using slotted holes, screws and anti-friction bushings, preventing rotation of studs while maintaining structural performance of partition.
 - 1. Structural Performance: Maintain lateral load resistance and vertical movement capacity required by applicable code, when evaluated in accordance with AISI S100-12.
 - 2. Material: ASTM A653/A653M steel sheet, SS Grade 50/340, with G60/Z180 hot dipped galvanized coating.
 - 3. Provide components UL-listed for use in UL-listed fire-rated head of partition joint systems indicated on drawings.

2.03 BOARD MATERIALS

- A. Manufacturers Gypsum-Based Board:
 - 1. CertainTeed Corporation: www.certainteed.com/#sle.
 - 2. Georgia-Pacific Gypsum: www.gpgypsum.com/#sle.
 - 3. Lafarge North America Inc: www.lafargenorthamerica.com.
 - 4. National Gypsum Company: www.nationalgypsum.com/#sle.
 - 5. USG Corporation: www.usg.com/#sle.
 - 6. Substitutions: Not permitted.
- B. Gypsum Wallboard: Paper-faced gypsum panels as defined in ASTM C1396/C1396M; sizes to minimize joints in place; ends square cut.
 - 1. Application: Use for vertical surfaces and ceilings, unless otherwise indicated.
 - 2. At Assemblies Indicated with Fire-Rating: Use type required by indicated tested assembly; if no tested assembly is indicated, use Type X board, UL or WH listed.
 - 3. Thickness:
 - a. Ceilings: 5/8 inch.
 - 4. Paper-Faced Products:
 - a. American Gypsum Company; FireBloc Type X Gypsum Wallboard: www.americangypsum.com/#sle.
 - b. CertainTeed Corporation; Type X Drywall: www.certainteed.com/#sle.
 - c. Georgia-Pacific Gypsum; ToughRock Fireguard X: www.gpgypsum.com/#sle.
 - d. Gold Bond Building Products, LLC provided by National Gypsum Company; Gold Bond Fire-Shield Gypsum Board: www.goldbondbuilding.com/#sle.
 - e. USG Corporation; Sheetrock Brand Firecode X Panels.
 - f. Substitutions: See Section 01 60 00 Product Requirements.
- C. Bullet Resistant Sheathing and Wallboard: Woven roving, multi-ply, ballistic grade fiberglass cloth with thermoset polyester resin; comply with UL 752 Level 1.
 - 1. Thickness: 7/16"
 - 2. Weight: 4.8psf.
 - 3. NIJ Level: III-A
 - 4. Ammunition: .44 Magnum Lead Semi-Wadcutter Gas Checked.
 - 5. Product: ArmorCore; ballistic fiberglass panels.

2.04 GYPSUM WALLBOARD ACCESSORIES

- A. Acoustic Insulation: ASTM C665; preformed glass fiber, friction fit type, unfaced. Thickness: 3 inch.
- B. Acoustical Shielding: 1/8 inch polymer sheet membrane; applied between studs and gypsum board.
 - 1. Sound Transmission Class (STC): Minimum of 26, calculated in accordance with ASTM E413, based on tests conducted in accordance with ASTM E90.
 - 2. Products:
 - a. Acoustiblok; Acoustiblok 16: www.acoustiblok.com
 - b. Substitutions: Not permitted.
- C. Acoustic Sealant: Acrylic emulsion latex or water-based elastomeric sealant; do not use solventbased non-curing butyl sealant.
 - 1. Products:
 - a. Franklin International, Inc; Titebond Acoustical Smoke & Sound Sealant: www.titebond.com/#sle.
 - b. Liquid Nails, a brand of PPG Architectural Coatings; AS-825 Acoustical Sound Sealant: www.liquidnails.com/#sle.
 - c. Specified Technologies Inc; Smoke N Sound Acoustical Sealant: www.stifirestop.com/#sle.
 - d. Substitutions: See Section 01 60 00 Product Requirements.
- D. Beads, Joint Accessories, and Other Trim: ASTM C1047, galvanized steel or rolled zinc, unless noted otherwise.
 - 1. Corner Beads: Low profile, for 90 degree outside corners.
 - a. Products:
 - 1) Phillips Manufacturing Co; Everlast Corner Bead: www.phillipsmfg.com/#sle.
 - 2) Substitutions: See Section 01 60 00 Product Requirements.
 - 2. L-Trim with Tear-Away Strip: Sized to fit 5/8 inch thick gypsum wallboard.
 - a. Products:
 - 1) Phillips Manufacturing Co; gripSTIK L-Tear: www.phillipsmfg.com/#sle.
 - 2) Substitutions: See Section 01 60 00 Product Requirements.
 - 3. Expansion Joints:
 - a. Type: V-shaped metal with factory-installed protective tape.
 - b. Products:
 - 1) Phillips Manufacturing Co; 093 Expansion Control Joint: www.phillipsmfg.com/#sle.
 - 2) Substitutions: See Section 01 60 00 Product Requirements.
- E. Joint Materials: ASTM C475/C475M and as recommended by gypsum board manufacturer for project conditions.
 - 1. Paper Tape: 2 inch wide, creased paper tape for joints and corners, except as otherwise indicated.
 - 2. Joint Compound: Drying type, vinyl-based, field-mixed.
 - 3. Joint Compound: Setting type, field-mixed.
- F. Screws for Fastening of Gypsum Panel Products to Cold-Formed Steel Studs Less than 0.033 inch in Thickness and Wood Members: ASTM C1002; self-piercing tapping screws, corrosion resistant.

- G. Screws for Fastening of Gypsum Panel Products to Steel Members from 0.033 to 0.112 inch in Thickness: ASTM C954; steel drill screws, corrosion resistant.
- H. Anchorage to Substrate: Tie wire, nails, screws, and other metal supports, of type and size to suit application; to rigidly secure materials in place.

PART 3 EXECUTION

3.01 EXAMINATION

A. Verify that project conditions are appropriate for work of this section to commence.

3.02 TOP RUNNER INSTALLATION

- A. Install in accordance with ASTM C754 and manufacturer's instructions.
- B. Suspended Ceilings and Soffits: Space framing and furring members as indicated.
 - 1. Level ceiling system to a tolerance of 1/1200.
 - 2. Laterally brace entire suspension system.
- C. Studs: Space studs at 16 inches on center.
 - 1. Extend partition framing to structure where indicated and to ceiling in other locations.
 - 2. Partitions Terminating at Ceiling: Attach ceiling runner securely to ceiling track in accordance with manufacturer's instructions.
 - Partitions Terminating at Structure: Attach top runner to structure, maintain clearance between top of studs and structure, and connect studs to track using specified mechanical devices in accordance with manufacturer's instructions; verify free movement of top of stud connections; do not leave studs unattached to track.
- D. Blocking: Install wood blocking for support of:
 - 1. Framed openings.
 - 2. Wall mounted cabinets.
 - 3. Toilet accessories.
 - 4. Wall mounted door hardware.
 - 5. Wall mounted items requiring support.

3.03 ACOUSTIC ACCESSORIES INSTALLATION

- A. Acoustic Insulation: Place tightly within spaces, around cut openings, behind and around electrical and mechanical items within partitions, and tight to items passing through partitions.
- B. Acoustic Sealant: Install in accordance with manufacturer's instructions.
 - 1. Place two beads continuously on substrate before installation of perimeter framing members.
 - 2. Place continuous bead at perimeter of each layer of gypsum board.
 - 3. Seal around all penetrations by conduit, pipe, ducts, and rough-in boxes, except where firestopping is provided.

3.04 BOARD INSTALLATION

A. Comply with ASTM C840, GA-216, and manufacturer's instructions. Install to minimize butt end joints, especially in highly visible locations.

- B. Single-Layer Non-Rated: Install gypsum board in most economical direction, with ends and edges occurring over firm bearing.
 - 1. Exception: Tapered edges to receive joint treatment at right angles to framing.
- C. Fire-Rated Construction: Install gypsum board in strict compliance with requirements of assembly listing.
- D. Installation on Metal Framing: Use screws for attachment of gypsum board except face layer of non-rated double-layer assemblies, which may be installed by means of adhesive lamination.
- E. Bullet Resistant Sheathing and Wallboard:
 - 1. Install bullet resistant sheathing according to manufacturer's written recommendations and with manufacturer approved fasteners.
 - 2. Cover all joints between boards with a 4 inch strip of the same thickness material as the boards, centered on the joint.

3.05 INSTALLATION OF TRIM AND ACCESSORIES

- A. Control Joints: Place control joints consistent with lines of building spaces and as indicated.
 1. Not more than 30 feet apart on walls and ceilings over 50 feet long.
- B. Corner Beads: Install at external corners, using longest practical lengths.
- C. Edge Trim: Install at locations where gypsum board abuts dissimilar materials.

3.06 JOINT TREATMENT

- A. Finish gypsum board in accordance with levels defined in ASTM C840, as follows:
 - 1. Level 4: Walls and ceilings to receive paint finish or wall coverings, unless otherwise indicated.
 - 2. Level 3: Walls to receive tile finish.
 - 3. Level 1: Wall areas above finished ceilings not exposed to view, whether or not accessible in the completed construction.
- B. Tape, fill, and sand exposed joints, edges, and corners to produce smooth surface ready to receive finishes.
 - 1. Feather coats of joint compound so that camber is maximum 1/32 inch.
 - 2. Taping, filling and sanding is not required at base layer of double layer applications.
- C. Fill and finish joints and corners of cementitious backing board as recommended by manufacturer.

3.07 TOLERANCES

A. Maximum Variation of Finished Gypsum Board Surface from True Flatness: 1/8 inch in 10 feet in any direction.

SECTION 09 30 00 TILING

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Tile for floor applications.
- B. Tile for wall applications.
- C. Non-ceramic trim.

1.02 RELATED REQUIREMENTS

- A. Section 07 92 00 Joint Sealants: Sealing joints between tile work and adjacent construction and fixtures.
- B. Section 09 21 16 Gypsum Board Assemblies: Tile backer board.

1.03 REFERENCE STANDARDS

- A. ANSI A108.1a American National Standard Specifications for Installation of Ceramic Tile in the Wet-Set Method, with Portland Cement Mortar; 2017.
- B. ANSI A108.1b Installation of Ceramic Tile on a Cured Portland Cement Mortar Setting Bed with Dry-Set, Modified Dry-Set, or Improved Modified Dry-Set Cement Mortar; 2023.
- C. ANSI A108.1c Contractor's Option: Installation of Ceramic Tile in the Wet-Set Method with Portland Cement Mortar or Installation of Ceramic Tile on a Cured Portland Cement Mortar Setting Bed with Dry-Set, Modified Dry-Set, or Improved Modified Dry-Set Cement Mortar; 2023.
- D. ANSI A108.2 American National Standard General Requirements: Materials, Environmental and Workmanship; 2019.
- E. ANSI A108.4 American National Standard Specifications for Installation of Ceramic Tile with Organic Adhesive or Water Cleanable Tile-Setting Epoxy Adhesive; 2023.
- F. ANSI A108.5 Setting of Ceramic Tile with Dry-Set Cement Mortar, Modified Dry-Set Cement Mortar, EGP (Exterior Glue Plywood) Modified Dry-Set Cement Mortar, or Improved Modified Dry-Set Cement Mortar; 2023.
- G. ANSI A108.6 American National Standard Specifications for Installation of Ceramic Tile with Chemical Resistant, Water Cleanable Tile-Setting and -Grout Epoxy; 2023.
- H. ANSI A108.8 American National Standard Specifications for Installation of Ceramic Tile with Chemical Resistant Furan Resin Mortar and Grout; 1999 (Reaffirmed 2019).
- I. ANSI A108.9 American National Standard Specifications for Installation of Ceramic Tile with Modified Epoxy Emulsion Mortar/Grout; 2023.
- J. ANSI A108.10 American National Standard Specifications for Installation of Grout in Tilework; 2017 (Reaffirmed 2022).
- K. ANSI A108.11 American National Standard Specifications for Interior Installation of Cementitious Backer Units; 2018.

- L. ANSI A108.12 Installation of Ceramic Tile with EGP (Exterior Glue Plywood) Modified Dry-Set Mortar; 2023.
- M. ANSI A108.13 American National Standard for Installation of Load Bearing, Bonded, Waterproof Membranes for Thin-Set Ceramic Tile and Dimension Stone; 2005 (Reaffirmed 2021).
- N. ANSI A108.19 American National Standard Specifications for Interior Installation of Gauged Porcelain Tiles and Gauged Porcelain Tile Panels/Slabs by the Thin-Bed Method Bonded with Modified Dry-Set Cement Mortar or Improved Modified Dry-Set Cement Mortar; 2020.
- O. ANSI A108.20 American National Standard Specifications for Exterior Installation of Gauged Porcelain Tile Panels/Slabs; 2020.
- P. ANSI A118.7 American National Standard Specifications for High Performance Cement Grouts for Tile Installation; 2019.
- Q. ANSI A118.15 American National Standard Specifications for Improved Modified Dry-Set Cement Mortar; 2012.
- R. ANSI A137.1 American National Standard Specifications for Ceramic Tile; 2022.
- S. ASTM C373 Standard Test Methods for Determination of Water Absorption and Associated Properties by Vacuum Method for Pressed Ceramic Tiles and Glass Tiles and Boil Method for Extruded Ceramic Tiles and Non-tile Fired Ceramic Whiteware Products; 2018.
- T. TCNA (HB) Handbook for Ceramic, Glass, and Stone Tile Installation; 2022.

1.04 ADMINISTRATIVE REQUIREMENTS

A. Preinstallation Meeting: Convene a preinstallation meeting one week before starting work of this section; require attendance by affected installers.

1.05 SUBMITTALS

- A. See Section 01 30 00 Administrative Requirements for submittal procedures.
- B. Product Data: Provide manufacturers' data sheets on tile, mortar, grout, and accessories. Include instructions for using grouts and adhesives.
- C. Shop Drawings: Indicate tile layout, patterns, color arrangement, perimeter conditions, junctions with dissimilar materials, control and expansion joints, thresholds, ceramic accessories, setting details, and trim components.
- D. Samples for Selection: Manufacturer's color line sample boards/books.
- E. Samples for Verification: Mount selected tile and apply grout on two plywood panels, minimum 18 x 18 inches in size illustrating pattern, color variations, and grout joint size variations.
- F. Manufacturer's Certificate: Certify that products meet or exceed specified requirements.
- G. Master Grade Certificate: Submit for each type of tile, signed by the tile manufacturer and tile installer.
- H. Installer's Qualification Statement:
 - 1. Submit documentation of National Tile Contractors Association (NTCA) or Tile Contractors' Association of America (TCAA) accreditation.

- 2. Submit documentation of completion of apprenticeship and certification programs.
- I. Maintenance Data: Include recommended cleaning methods, cleaning materials, and stain removal methods.
- J. Maintenance Materials: Furnish the following for Owner's use in maintenance of project.
 - 1. See Section 01 60 00 Product Requirements, for additional provisions.
 - 2. Extra Tile: 10 square feet of each size, color, and surface finish combination.

1.06 QUALITY ASSURANCE

- A. Manufacturer Qualifications: Company specializing in manufacturing the types of products specified in this section, with minimum five years of documented experience.
- B. Installer Qualifications:
 - 1. Company specializing in performing tile installation, with minimum of five years of documented experience.
 - a. Accredited Five-Star member of the National Tile Contractors Association (NTCA) or Trowel of Excellence member of the Tile Contractors' Association of America (TCAA).
 - 2. Installer Certification:
 - a. Ceramic Tile Education Foundation (CTEF): Certified Tile Installer (CTI).
 - b. Apprenticeship Program: Installer has achieved Journeyworker status through an apprenticeship from the International Union of Bricklayers and Allied Craftworkers (IUBAC) or a U.S. Department of Labor (DOL)-recognized program.
 - c. Advanced Certifications for Tile Installers (ACT): Certification in the installation of membranes, mortar bed (mud) floors, mortar (mud) walls, shower receptors, large format tile, gauged porcelain tile/panels/slabs, and grouts.
 - d. International Masonry Training and Education Foundation (IMTEF): Supervisor Certification Program (SCP).

1.07 DELIVERY, STORAGE, AND HANDLING

A. Protect adhesives from freezing or overheating in accordance with manufacturer's instructions.

1.08 FIELD CONDITIONS

- A. Do not install solvent-based products in an unventilated environment.
- B. Maintain ambient and substrate temperature above 50 degrees F and below 100 degrees F during installation and curing of setting materials.

PART 2 PRODUCTS

2.01 TILE

- A. Manufacturers:
 - 1. Crossville, Inc: www.crossvilleinc.com.
 - 2. Substitutions: Not permitted.
- B. Porcelain Floor Tile, Type TF1: ANSI A137.1, standard grade.
 - 1. Moisture Absorption: 0 to 0.5 percent as tested in accordance with ASTM C373.
 - 2. Size: 2 by 2 inch, nominal.
 - 3. Shape: Square.

- 4. Edges: Square.
- 5. Surface Finish: Unglazed.
- 6. Color(s): As shown on drawings.
- 7. Pattern: As shown on drawings.
- 8. Mounted Sheet Size: 12 by 24 inches.
- 9. Trim Units: Matching bead, cove, and surface bullnose shapes in sizes coordinated with field tile.
- C. Porcelain Wall Tile, Type TW1: ANSI A137.1, standard grade.
 - 1. Moisture Absorption: 0 to 0.5 percent as tested in accordance with ASTM C373.
 - 2. Size: 12" by 24" inch, nominal.
 - 3. Edges: Square.
 - 4. Surface Finish: Unglazed.
 - 5. Color(s): As shown on the drawings.
 - 6. Pattern: As shown on the drawings.
 - 7. Products: As shown on the drawings.
 - a. Substitutions: Not permitted.

2.02 TRIM AND ACCESSORIES

- A. Non-Ceramic Trim: Brushed stainless steel or satin natural anodized extruded aluminum, style and dimensions to suit application, for setting using tile mortar or adhesive.
 - 1. Applications:
 - a. Open edges of floor tile.
 - b. Wall corners, outside and inside.
 - c. Floor to wall joints.
 - 2. Manufacturers:
 - a. Schluter-Systems: www.schluter.com.
 - b. Substitutions: Not permitted.

2.03 SETTING MATERIALS

- A. Provide setting and grout materials from same manufacturer.
- B. Manufacturers:
 - 1. ARDEX Engineered Cements: www.ardexamericas.com.
 - 2. Bostik Inc: www.bostik-us.com.
 - 3. Custom Building Products: www.custombuildingproducts.com.
 - 4. H.B. Fuller Construction Products, Inc: www.tecspecialty.com.
 - 5. LATICRETE International, Inc: www.laticrete.com.
 - 6. Substitutions: Not permitted.
- C. Improved Latex-Portland Cement Mortar Bond Coat: ANSI A118.15.
 - 1. Applications: Use this type of bond coat where indicated, and where no other type of bond coat is indicated.

2.04 GROUTS

- A. Manufacturers:
 - 1. Bostik Inc: www.bostik-us.com.

- 2. Custom Building Products: www.custombuildingproducts.com/#sle.
- 3. LATICRETE International, Inc; LATICRETE PERMACOLOR Grout: www.laticrete.com.
- B. High Performance Polymer Modified Grout: ANSI A118.7 polymer modified cement grout.
 - 1. Applications: Use this type of grout where indicated and where no other type of grout is indicated.
 - 2. Use sanded grout for joints 1/8 inch wide and larger; use unsanded grout for joints less than 1/8 inch wide.
 - 3. Color(s): As indicated on drawings.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify that subfloor surfaces are smooth and flat within the tolerances specified for that type of work and are ready to receive tile.
- B. Verify that wall surfaces are smooth and flat within the tolerances specified for that type of work, are dust-free, and are ready to receive tile.
- C. Verify that subfloor surfaces are dust free and free of substances that could impair bonding of setting materials to subfloor surfaces.
- D. Verify that required wall-mounted utilities are in correct location.

3.02 PREPARATION

- A. Protect surrounding work from damage.
- B. Vacuum clean surfaces and damp clean.
- C. Seal substrate surface cracks with filler. Level existing substrate surfaces to acceptable flatness tolerances.
- D. Install backer board in accordance with ANSI A108.11 and board manufacturer's instructions. Tape joints and corners, cover with skim coat of setting material to a feather edge.

3.03 INSTALLATION - GENERAL

- A. Install tile and thresholds and grout in accordance with applicable requirements of ANSI A108.1a through ANSI A108.20, manufacturer's instructions, and TCNA (HB) recommendations.
- B. Lay tile to pattern indicated. Do not interrupt tile pattern through openings.
- C. Cut and fit tile to penetrations through tile, leaving sealant joint space. Form corners and bases neatly. Align floor joints.
- D. Place tile joints uniform in width, subject to variance in tolerance allowed in tile size. Make grout joints without voids, cracks, excess mortar or excess grout, or too little grout.
- E. Form internal angles square and external angles bullnosed.
- F. Install non-ceramic trim in accordance with manufacturer's instructions.
- G. Sound tile after setting. Replace hollow sounding units.
- H. Keep control and expansion joints free of mortar, grout, and adhesive.

- I. Prior to grouting, allow installation to completely cure; minimum of 48 hours.
- J. Grout tile joints unless otherwise indicated. Use standard grout unless otherwise indicated.
- K. At changes in plane and tile-to-tile control joints, use tile sealant instead of grout, with either bond breaker tape or backer rod as appropriate to prevent three-sided bonding.
- L. Apply sealant to junction of tile and dissimilar materials and junction of dissimilar planes.

3.04 INSTALLATION - WALL TILE

A. Over gypsum wallboard on wood or metal studs install in accordance with TCNA (HB) Method W243, thin-set with dry-set or latex-Portland cement bond coat, unless otherwise indicated.

3.05 CLEANING

A. Clean tile and grout surfaces.

3.06 PROTECTION

A. Do not permit traffic over finished floor surface for 4 days after installation.

SECTION 09 51 00 ACOUSTICAL CEILINGS

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Suspended metal grid ceiling system.
- B. Acoustical units.

1.02 RELATED REQUIREMENTS

- A. Section 21 13 00 Fire Suppression Sprinklers: Sprinkler heads in ceiling system.
- B. Section 23 37 00 Air Outlets and Inlets: Air diffusion devices in ceiling.
- C. Section 26 51 00 Interior Lighting: Light fixtures in ceiling system.

1.03 REFERENCE STANDARDS

- A. ASTM C635/C635M Standard Specification for the Manufacture, Performance, and Testing of Metal Suspension Systems for Acoustical Tile and Lay-in Panel Ceilings; 2017.
- B. ASTM C636/C636M Standard Practice for Installation of Metal Ceiling Suspension Systems for Acoustical Tile and Lay-In Panels; 2013.
- C. ASTM E580/E580M Standard Practice for Installation of Ceiling Suspension Systems for Acoustical Tile and Lay-in Panels in Areas Subject to Earthquake Ground Motions; 2022.
- D. ASTM E1264 Standard Classification for Acoustical Ceiling Products; 2023.

1.04 ADMINISTRATIVE REQUIREMENTS

A. Do not install acoustical units until after interior wet work is dry.

1.05 SUBMITTALS

- A. See Section 01 30 00 Administrative Requirements, for submittal procedures.
- B. Product Data: Provide data on suspension system components and acoustical units.
- C. Samples: Submit two samples 6 x 6 inch in size illustrating material and finish of acoustical units.
- D. Manufacturer's Installation Instructions: Indicate special procedures and perimeter conditions requiring special attention.
- E. Maintenance Materials: Furnish the following for Owner's use in maintenance of project.
 - 1. See Section 01 60 00 Product Requirements, for additional provisions.
 - 2. Extra Acoustical Units: Quantity equal to 5 percent of total installed.

1.06 FIELD CONDITIONS

A. Maintain uniform temperature of minimum 60 degrees F, and maximum humidity of 40 percent prior to, during, and after acoustical unit installation.

PART 2 PRODUCTS

2.01 ACOUSTICAL UNITS

A. Manufacturers:

- 1. CertainTeed Corporation: www.certainteed.com.
- 2. Substitutions: Not permitted.
- B. Acoustical Panels Type C1/ACT1: Painted mineral fiber, ASTM E1264 Type III, with the following characteristics:
 - 1. Size: 24 by 24 inches.
 - 2. Thickness: 5/8 inches.
 - 3. Composition: Wet felted.
 - 4. Light Reflectance: 83 percent, determined as specified in ASTM E1264.
 - 5. NRC Range: 0.60 to 0.55, determined as specified in ASTM E1264.
 - 6. Ceiling Attenuation Class (CAC): 33, determined as specified in ASTM E1264.
 - 7. Edge: Reveal.
 - 8. Surface Color: White.
 - 9. Surface Pattern: Fine texture; fissured pattern.
 - 10. Products:
 - a. Performa Baroque Reveal BET-164 by Certainteed Ceilings.
 - b. Substitutions: Not permitted.
 - 11. Suspension System: Exposed grid Type SS1.

2.02 SUSPENSION SYSTEM(S)

- A. Manufacturers:
 - 1. Armstrong World Industries, Inc: www.armstrong.com.
 - 2. Chicago Metallic Corporation: www.chicagometallic.com.
 - 3. USG: www.usg.com.
 - 4. CertainTeed Corporation: www.certainteed.com.
 - 5. Substitutions: See Section 01 60 00 Product Requirements.
- B. Metal Suspension Systems General: Complying with ASTM C635/C635M; die cut and interlocking components, with perimeter moldings, hold down clips, stabilizer bars, clips, and splices as required.
- C. Exposed Steel Suspension System Type SS1: Formed steel, commercial quality cold rolled; intermediate-duty.
 - 1. Profile: Tee; 15/16 inch wide face.
 - 2. Construction: Double web.
 - 3. Finish: White painted.

2.03 ACCESSORIES

- A. Support Channels and Hangers: Galvanized steel; size and type to suit application, seismic requirements, and ceiling system flatness requirement specified.
- B. Hanger Wire: 12-gage 0.08 inch galvanized steel wire.
- C. Perimeter Moldings: Same metal and finish as grid.
 - 1. At Exposed Grid: Provide L-shaped molding for mounting at same elevation as face of grid.

D. Touch-up Paint: Type and color to match acoustical and grid units.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify existing conditions before starting work.
- B. Verify that layout of hangers will not interfere with other work.

3.02 INSTALLATION - SUSPENSION SYSTEM

- A. Install suspension system in accordance with ASTM C636/C636M, ASTM C636/C636M, and ASTM C636/C636M and as supplemented in this section.
- B. Rigidly secure system, including integral mechanical and electrical components, for maximum deflection of 1:360.
- C. Perimeter Molding: Install at intersection of ceiling and vertical surfaces and at junctions with other interruptions.
 - 1. Use longest practical lengths.
- D. Install after major above-ceiling work is complete. Coordinate the location of hangers with other work.
- E. Suspension System, Non-Seismic: Hang suspension system independent of walls, columns, ducts, pipes and conduit. Where carrying members are spliced, avoid visible displacement of face plane of adjacent members.
- F. Where ducts or other equipment prevent the regular spacing of hangers, reinforce the nearest affected hangers and related carrying channels to span the extra distance.
- G. Do not support components on main runners or cross runners if weight causes total dead load to exceed deflection capability.
- H. Support fixture loads using supplementary hangers located within 6 inches of each corner, or support components independently.
- I. Do not eccentrically load system or induce rotation of runners.
- J. Perimeter Molding: Install at intersection of ceiling and vertical surfaces and at junctions with other interruptions.
 - 1. Use longest practical lengths.
 - 2. Overlap and rivet corners.

3.03 INSTALLATION - ACOUSTICAL UNITS

- A. Install acoustical units in accordance with manufacturer's instructions.
- B. Fit acoustical units in place, free from damaged edges or other defects detrimental to appearance and function.
- C. Fit border trim neatly against abutting surfaces.
- D. Install units after above-ceiling work is complete.

- E. Install acoustical units level, in uniform plane, and free from twist, warp, and dents.
- F. Cutting Acoustical Units:
 - 1. Cut to fit irregular grid and perimeter edge trim.
 - 2. Make field cut edges of same profile as factory edges.
 - 3. Double cut and field paint exposed reveal edges.
- G. Where round obstructions occur, provide preformed closures to match perimeter molding.

3.04 TOLERANCES

- A. Maximum Variation from Flat and Level Surface: 1/8 inch in 10 feet.
- B. Maximum Variation from Plumb of Grid Members Caused by Eccentric Loads: 2 degrees.

SECTION 09 65 00 RESILIENT FLOORING

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Resilient tile flooring.
- B. Resilient base.
- C. Installation accessories.

1.02 REFERENCE STANDARDS

A. ASTM F1861 - Standard Specification for Resilient Wall Base; 2021.

1.03 SUBMITTALS

- A. See Section 01 30 00 Administrative Requirements for submittal procedures.
- B. Product Data: Provide data on specified products, describing physical and performance characteristics; including sizes, patterns and colors available; and installation instructions.
- C. Shop Drawings: Indicate seaming plans and floor patterns.
- D. Selection Samples: Submit manufacturer's complete set of color samples for Architect/Engineer's initial selection.
- E. Verification Samples: Submit two samples, 12 by 12 inch in size illustrating color and pattern for each resilient flooring product specified.
- F. Maintenance Data: Include maintenance procedures, recommended maintenance materials, and suggested schedule for cleaning, stripping, and re-waxing.
- G. Maintenance Materials: Furnish the following for Owner's use in maintenance of project.
 - 1. See Section 01 60 00 Product Requirements, for additional provisions.
 - 2. Extra Flooring Material: 100 square feet of each type and color.
 - 3. Extra Wall Base: 100 linear feet of each type and color.

1.04 QUALITY ASSURANCE

1.05 DELIVERY, STORAGE, AND HANDLING

- A. Store all materials off of the floor in an acclimatized, weather-tight space.
- B. Protect rolled sheet materials from damage by storing on end.

1.06 FIELD CONDITIONS

- A. Maintain temperature in storage area between 55 degrees F and 90 degrees F.
- B. Store materials for not less than 48 hours prior to installation in area of installation at a temperature of 70 degrees F to achieve temperature stability. Thereafter, maintain conditions above 55 degrees F.

PART 2 PRODUCTS

2.01 TILE FLOORING

- A. Luxury Vinyl Tile Type LVT1: Homogeneous, with color extending throughout thickness.
 - 1. Pattern: As indicated on drawings.
 - 2. Color: As indicated on drawings.

2.02 RESILIENT BASE

- A. Resilient Base RB1: ASTM F1861, Type TP, rubber, thermoplastic; style as scheduled.
 - 1. Height: 4 inches.
 - 2. Thickness: 0.125 inch.
 - 3. Finish: Satin.
 - 4. Length: Roll.
 - 5. Color: As indicated on drawings.

2.03 ACCESSORIES

- A. Subfloor Filler: White premix latex; type recommended by adhesive material manufacturer.
- B. Primers, Adhesives, and Seam Sealer: Waterproof; types recommended by flooring manufacturer.
- C. Moldings, Transition and Edge Strips: Metal.
- D. Filler for Coved Base: Plastic.
- E. Sealer and Wax: Types recommended by flooring manufacturer.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify that surfaces are flat to tolerances acceptable to flooring manufacturer, free of cracks that might telegraph through flooring, clean, dry, and free of curing compounds, surface hardeners, and other chemicals that might interfere with bonding of flooring to substrate.
- B. Verify that wall surfaces are smooth and flat within the tolerances specified for that type of work, are dust-free, and are ready to receive resilient base.
- C. Verify that concrete sub-floor surfaces are dry enough and ready for resilient flooring installation by testing for moisture emission rate and alkalinity in accordance with ASTM F710; obtain instructions if test results are not within limits recommended by resilient flooring manufacturer and adhesive materials manufacturer.
- D. Verify that required floor-mounted utilities are in correct location.

3.02 PREPARATION

- A. Remove subfloor ridges and bumps. Fill minor low spots, cracks, joints, holes, and other defects with subfloor filler to achieve smooth, flat, hard surface.
- B. Prohibit traffic until filler is fully cured.
- C. Clean substrate.

3.03 INSTALLATION - GENERAL

- A. Starting installation constitutes acceptance of subfloor conditions.
- B. Install in accordance with manufacturer's written instructions.
- C. Adhesive-Applied Installation:
 - 1. Spread only enough adhesive to permit installation of materials before initial set.
 - Place copper grounding strip in conductive adhesive and apply additional adhesive to top side of strip before installing static control flooring. Allow strip to extend beyond flooring in accordance with static control flooring manufacturer's instructions.
 - 3. Fit joints and butt seams tightly.
 - 4. Set flooring in place, press with heavy roller to attain full adhesion.
- D. Where type of floor finish, pattern, or color are different on opposite sides of door, terminate flooring under centerline of door.
- E. Install edge strips at unprotected or exposed edges, where flooring terminates, and where indicated.
- F. Scribe flooring to walls, columns, cabinets, floor outlets, and other appurtenances to produce tight joints.

3.04 INSTALLATION - TILE FLOORING

A. Mix tile from container to ensure shade variations are consistent when tile is placed, unless otherwise indicated in manufacturer's installation instructions.

3.05 INSTALLATION - RESILIENT BASE

- A. Fit joints tightly and make vertical. Maintain minimum dimension of 18 inches between joints.
- B. Miter internal corners. At external corners, 'V' cut back of base strip to 2/3 of its thickness and fold. At exposed ends, use premolded units.
- C. Install base on solid backing. Bond tightly to wall and floor surfaces.
- D. Scribe and fit to door frames and other interruptions.

3.06 CLEANING

- A. Remove excess adhesive from floor, base, and wall surfaces without damage.
- B. Clean in accordance with manufacturer's written instructions.

3.07 PROTECTION

A. Prohibit traffic on resilient flooring for 48 hours after installation.

SECTION 09 90 00 PAINTING AND COATING

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Surface preparation.
- B. Interior painting and coating systems.
- C. Scope:
 - 1. Finish surfaces exposed to view, unless fully factory-finished and unless otherwise indicated, including the following:
 - a. Interior:
 - 1) Masonry CMU: Concrete, split face, scored, smooth, high density, low density, and fluted.
 - 2) Metal: Door frames, miscellaneous and ornamental ferrous metal.
 - 3) Drywall: Walls, ceilings, gypsum board, and similar items.

1.02 RELATED REQUIREMENTS

A. Section 01 61 16 - Volatile Organic Compound (VOC) Content Restrictions.

1.03 REFERENCE STANDARDS

- A. SSPC-SP 1 Solvent Cleaning; 2015, with Editorial Revision (2016).
- B. SSPC-SP 6/NACE No.3 Commercial Blast Cleaning; 2006.

1.04 SUBMITTALS

- A. See Section 01 30 00 Administrative Requirements for submittal procedures.
- B. Product Data: Provide complete list of products to be used, with the following information for each:
 - 1. Product characteristics.
 - 2. Surface preparation instructions and recommendations.
 - 3. Primer requirements and finish specification.
 - 4. Storage and handling requirements and recommendations.
 - 5. Application methods.
 - 6. Clean-up information.
- C. Samples: Submit two paper draw down samples, 8-1/2 by 11 inches in size, illustrating range of colors available for each finishing product specified.
- D. Certification: By manufacturer that paints and finishes comply with VOC limits specified.

1.05 QUALITY ASSURANCE

A. Applicator Qualifications: Company specializing in performing the type of work specified with minimum 3 years experience.

1.06 DELIVERY, STORAGE, AND HANDLING

A. Deliver products to site in sealed and labeled containers; inspect to verify acceptability.

- B. Container Label: Include manufacturer's name, type of paint, product name, product code, color designation, VOC content, batch date, environmental handling, surface preparation, application, and use instructions.
- C. Paint Materials: Store at a minimum of 45 degrees F and a maximum of 90 degrees F, in ventilated area, and as required by manufacturer's instructions.
- D. Handling: Maintain a clean, dry storage area to prevent contamination or damage to materials.

1.07 FIELD CONDITIONS

- A. Do not apply materials when environmental conditions are outside the ranges required by manufacturer.
- B. Follow manufacturer's recommended procedures for producing the best results, including testing of substrates, moisture in substrates, and humidity and temperature limitations.

PART 2 PRODUCTS

2.01 MANUFACTURERS

- A. Basis of Design Products: Subject to compliance with requirements, provide Sherwin-Williams Company (The) products indicated; www.sherwin-williams.com.
- B. Comparable Products: Products of approved manufacturers will be considered in accordance with 01 60 00 Product Requirements, and the following:
 - 1. Products that meet or exceed performance and physical characteristics of basis of design products.

2.02 PAINTINGS AND COATINGS

- A. General:
 - 1. Provide factory-mixed coatings unless otherwise indicated.
 - 2. Do not reduce, thin, or dilute coatings or add materials to coatings unless specifically indicated in manufacturer's instructions.
- B. Volatile Organic Compound (VOC) Content: Comply with Section 01 61 16.
- C. Accessory Materials: Provide primers, sealers, cleaning agents, cleaning cloths, sanding materials, and clean-up materials as required for final completion of painted surfaces.

2.03 PAINT SYSTEMS - INTERIOR

- A. Masonry CMU:
 - 1. Latex Systems:
 - a. Semi-Gloss Finish High Performance (HP):
 - 1) 1st Coat: Sherwin-Williams PrepRite Block Filler, B25W25: www.sherwin-williams.com.
 a) 75 to 125 sq ft/gal.
 - 2) 2nd and 3rd Coat: Sherwin-Williams ProMar 200 HP Zero VOC Latex Semi-Gloss, B31-1950 Series: www.sherwin-williams.com/#sle.
 - a) 4 mils wet, 1.6 mils dry per coat.
- B. Metal: Door frames, miscellaneous and ornamental ferrous metal.
 - 1. Alkyd Systems, Water Based:

- a. Semi-Gloss Finish:
 - 1) 1st Coat: Sherwin-Williams Pro Industrial Pro-Cryl Universal Primer, B66-1310 Series: www.sherwin-williams.com.
 - a) 5 mils wet, 2 mils dry per coat.
 - 2) 2nd and 3rd Coat: Sherwin-Williams Pro Industrial Water Based Alkyd Urethane Enamel Semi-Gloss, B53-1150 Series: www.sherwin-williams.com.
 a) 4 to 5 mils wet, 1.4 to 1.7 mils dry per coat.
- C. Drywall: Walls, ceilings, gypsum board, and similar items.
 - 1. Latex Systems:
 - a. Eg-Shel Finish:
 - 1) 1st Coat: Sherwin-Williams ProMar 200 Zero VOC Interior Latex Primer, B28W2600: www.sherwin-williams.com.
 - a) 4 mils wet, 1.5 mils dry per coat.
 - 2) 2nd and 3rd Coat: Sherwin-Williams ProMar 200 Zero VOC Eg-Shel, B20-2600 Series: www.sherwin-williams.com.
 - a) 4 mils wet, 1.7 mils dry per coat.
 - b. Flat Finish:
 - 1) 1st Coat: Sherwin-Williams ProMar 200 Zero VOC Interior Latex Primer, B28W2600: www.sherwin-williams.com.
 - 2) 2nd and 3rd Coat: Sherwin-Williams ProMar 200 Zero VOC Latex Flat, B30-2600 Series: www.sherwin-williams.com.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify that surfaces are ready to receive work as instructed by the product manufacturer.
- B. Examine surfaces scheduled to be finished prior to commencement of work. Report any condition that may potentially effect proper application.
- C. Test shop-applied primer for compatibility with subsequent cover materials.

3.02 PREPARATION

- A. Clean surfaces thoroughly and correct defects prior to application.
- B. Prepare surfaces using the methods recommended by the manufacturer for achieving the best result for the substrate under the project conditions.
- C. Remove mildew from impervious surfaces by scrubbing with solution of water and bleach. Rinse with clean water and allow surface to dry.
- D. Masonry: Remove efflorescence and chalk.
- E. Gypsum Board: Fill minor defects with filler compound; sand smooth and remove dust prior to painting.
- F. Plaster: Fill hairline cracks, small holes, and imperfections with patching plaster. Make smooth and flush with adjacent surfaces. Treat textured, soft, porous, or powdery surfaces in accordance with manufacturer's instructions.
- G. Ferrous Metal:

- 1. Solvent clean according to SSPC-SP 1.
- 2. Shop-Primed Surfaces: Sand and scrape to remove loose primer and rust. Feather edges to make touch-up patches inconspicuous. Prime bare steel surfaces.
- 3. Remove rust, loose mill scale, and other foreign substances using methods recommended by paint manufacturer and blast cleaning in accordance with SSPC-SP 6/NACE No.3. Protect from corrosion until coated.

3.03 APPLICATION

- A. Remove unfinished louvers, grilles, covers, and access panels on mechanical and electrical components and paint separately.
- B. Apply products in accordance with manufacturer's written instructions.
- C. Apply coatings at spread rate required to achieve manufacturer's recommended dry film thickness.
- D. Regardless of number of coats specified, apply additional coats until complete hide is achieved.

3.04 PRIMING

- A. Apply primer to all surfaces unless specifically not required by coating manufacturer. Apply in accordance with coating manufacturer's instructions.
- B. Primers specified in painting schedules may be omitted on items that are factory primed or factory finished if acceptable to top coat manufacturers.

3.05 CLEANING

- A. Collect waste material that could constitute a fire hazard, place in closed metal containers, and remove daily from site.
- B. Clean surfaces immediately of overspray, splatter, and excess material.
- C. After coating has cured, clean and replace finish hardware, fixtures, and fittings previously removed.

3.06 PROTECTION

- A. Protect finished coatings from damage until completion of project.
- B. Touch-up damaged finishes after Substantial Completion.

SECTION 10 26 01 WALL AND CORNER GUARDS

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Corner guards.
- B. Wall protection.

1.02 RELATED REQUIREMENTS

- A. Section 06 10 00 Rough Carpentry: Blocking and supports.
- B. Section 12 36 00 Countertops: Solid surfacing as wall protection.

1.03 REFERENCE STANDARDS

- A. ADA Standards 2010 ADA Standards for Accessible Design; 2010.
- B. ICC A117.1 Accessible and Usable Buildings and Facilities; 2009.
- C. ASTM E84 Standard Test Method for Surface Burning Characteristics of Building Materials; 2023d.
- D. ASTM E119 Standard Test Methods for Fire Tests of Building Construction and Materials; 2022.

1.04 SUBMITTALS

- A. See Section 01 30 00 Administrative Requirements, for submittal procedures.
- B. Product Data: Indicate physical dimensions, features, anchorage details, and rough-in measurements.
- C. Samples: Submit two sections of corner guard, 24 inch long, illustrating component design, configuration, color and finish.
- D. Manufacturer's Instructions: Indicate special procedures, perimeter conditions requiring special attention.

PART 2 PRODUCTS

2.01 MANUFACTURERS

- A. Wall and Corner Guards:
 - 1. Koroseal: www.koroseal.com.
 - 2. Substitutions: Not permitted.

2.02 COMPONENTS

- A. Corner Guards (Type CG1) Extruded Surface Mounted:
 - 1. Material: High impact vinyl.
 - 2. Performance: Resist lateral impact force of 100 lbs at any point without damage or permanent set.
 - 3. Fire Resistance: Where fire rating is specified for the wall in which the guard is mounted, provide assemblies that have been tested in accordance with ASTM E119 for the same rating

as the wall.

- 4. Surface Burning Characteristics: Provide assemblies with flame spread index of 25 or less and smoke developed index of 450 or less, when tested in accordance with ASTM E84.
- 5. Width of Wings: 1-1/2 inches.
- 6. Corner: Square.
- 7. Color: As indicated on Drawings.
- 8. Length: One piece: 48 inches high.
- 9. Basis of Design Product: G815 Extruded Corner Guard; Koroseal Korogard.
- 10. Mounting: Continuous self adhesive tape.
- B. Wall Protection (Type WP1) Surface Mounted:
 - 1. Material: High impact vinyl.
 - 2. Installation: Surface applied with adhesive.
 - 3. Vinyl Thickness: 0.060 inch minimum.
 - 4. Sheet Size: 4 feet x 8 feet.
 - 5. Texture: Mesa-S.
 - 6. Accessories: Formed inside and outside corner trim, expansion joint strips, J-molding caps and edge trim. Adhesive: As recommended for substrate by Manufacturer.
 - 7. Surface Burning Characteristics: Provide assemblies with flame spread index of 25 or less and smoke developed index of 450 or less, when tested in accordance with ASTM E84.
 - 8. Color: As scheduled.
 - 9. Basis of Design Product: Traffic Patterns STP3K721281; Koroseal Korogard.

2.03 FABRICATION

- A. Fabricate components with tight joints, corners and seams.
- B. Form end trim closure by capping and finishing smooth.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify that rough openings, concealed blocking, and anchors are correctly sized and located.
- B. Verify that field measurements are as indicated on Drawings.

3.02 INSTALLATION

A. Install components in accordance with manufacturer's instructions, level and plumb, secured rigidly in position to wall framing members only.

Β.

3.03 TOLERANCES

- A. Maximum Variation From Required Height: 1/4 inch.
- B. Maximum Variation From Level or Plane For Visible Length: 1/4 inch.

3.04 SCHEDULE

A. Locations as indicated on drawings.

SECTION 10 28 00 TOILET, BATH, AND LAUNDRY ACCESSORIES

PART 1 GENERAL

1.01 SECTION INCLUDES

A. Commercial toilet accessories.

1.02 RELATED REQUIREMENTS

A. Section 06 10 00 - Rough Carpentry: Concealed supports for accessories, including in wall framing and plates.

1.03 REFERENCE STANDARDS

- A. ASTM A123/A123M Standard Specification for Zinc (Hot-Dip Galvanized) Coatings on Iron and Steel Products; 2017.
- B. ASTM A269/A269M Standard Specification for Seamless and Welded Austenitic Stainless Steel Tubing for General Service; 2022.
- C. ASTM A653/A653M Standard Specification for Steel Sheet, Zinc-Coated (Galvanized) or Zinc-Iron Alloy-Coated (Galvannealed) by the Hot-Dip Process; 2023.
- D. ASTM A666 Standard Specification for Annealed or Cold-Worked Austenitic Stainless Steel Sheet, Strip, Plate, and Flat Bar; 2015.
- E. ASTM B456 Standard Specification for Electrodeposited Coatings of Copper Plus Nickel Plus Chromium and Nickel Plus Chromium; 2017 (Reapproved 2022).
- F. ASTM C1036 Standard Specification for Flat Glass; 2011.

1.04 ADMINISTRATIVE REQUIREMENTS

A. Coordinate the work with the placement of internal wall reinforcement, concealed ceiling supports, and reinforcement of toilet partitions to receive anchor attachments.

1.05 SUBMITTALS

A. See Section 01 30 00 - Administrative Requirements, for submittal procedures.

PART 2 PRODUCTS

2.01 MANUFACTURERS

- A. Commercial Toilet, Shower, and Bath Accessories:
 - 1. American Specialties, Inc: www.americanspecialties.com/#sle.
 - 2. Bobrick Washroom Equipment Inc.: www.bobrick.com.
 - 3. Substitutions: Section 01 60 00 Product Requirements.
- B. All items to be made by the same manufacturer.

2.02 MATERIALS

A. Accessories - General: Shop assembled, free of dents and scratches and packaged complete with anchors and fittings, steel anchor plates, adapters, and anchor components for installation.

- 1. Grind welded joints smooth.
- 2. Fabricate units made of metal sheet of seamless sheets with flat surfaces.
- B. Keys: Provide 2 keys for each accessory to Owner; master key lockable accessories.
- C. Stainless Steel Sheet: ASTM A666, Type 304.
- D. Stainless Steel Tubing: ASTM A269/A269M, Grade TP304 or TP316.
- E. Galvanized Sheet Steel: Hot-dipped galvanized steel sheet, ASTM A653/A653M, with G90/Z275 coating.
- F. Mirror Glass: Annealed float glass, ASTM C1036 Type I, Class 1, Quality Q2, with silvering, protective and physical characteristics complying with ASTM C1503.
- G. Adhesive: Two component epoxy type, waterproof.
- H. Fasteners, Screws, and Bolts: Hot dip galvanized; tamper-proof; security type.
- I. Expansion Shields: Fiber, lead, or rubber as recommended by accessory manufacturer for component and substrate.

2.03 FINISHES

- A. Stainless Steel: Satin finish, unless otherwise noted.
- B. Chrome/Nickel Plating: ASTM B456, SC 2, polished finish, unless otherwise noted.
- C. Galvanizing for Items Other than Sheet: Comply with ASTM A123/A123M; galvanize ferrous metal and fastening devices.
- D. Shop Primed Ferrous Metals: Pretreat and clean, spray apply one coat primer and bake.
- E. Back paint components where contact is made with building finishes to prevent electrolysis.

2.04 COMMERCIAL TOILET ACCESSORIES

A. As indicated on the Drawings.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify existing conditions before starting work.
- B. Verify exact location of accessories for installation.
- C. See Section 06 10 00 for installation of blocking in walls.

3.02 PREPARATION

- A. Deliver inserts and rough-in frames to site for timely installation.
- B. Provide templates and rough-in measurements as required.

3.03 INSTALLATION

A. Install accessories in accordance with manufacturers' instructions in locations indicated on drawings.

- B. Install plumb and level, securely and rigidly anchored to substrate.
- C. Mounting Heights: As required by accessibility regulations, unless otherwise indicated. 1. Grab Bars: As indicated on drawings.
- D. Mounting Heights and Locations: As required by accessibility regulations and as indicated on drawings.

3.04 PROTECTION

A. Protect installed accessories from damage due to subsequent construction operations.

3.05 SCHEDULE

A. Refer to Sheet A800 for schedule of toilet accessories and interior elevations of restrooms

SECTION 12 24 00 WINDOW SHADES - MECHOSHADE SYSTEMS

PART 1 GENERAL

1.01 SECTION INCLUDES

A. Manual roller shades and accessories.

1.02 RELATED REQUIREMENTS

A. Section 06 10 00 - Rough Carpentry: Concealed wood blocking for attachment of shade brackets and accessories.

1.03 REFERENCE STANDARDS

- A. ASTM G21 Standard Practice for Determining Resistance of Synthetic Polymeric Materials to Fungi; 2015, with Editorial Revision (2021).
- B. NFPA 701 Standard Methods of Fire Tests for Flame Propagation of Textiles and Films; 2015.
- C. UL 325 Standard for Door, Drapery, Gate, Louver, and Window Operators and Systems; Current Edition, Including All Revisions.
- D. WCMA A100.1 Safety of Window Covering Products; 2018.

1.04 SUBMITTALS

- A. See Section 01 30 00 Administrative Requirements, for submittal procedures.
- B. Product Data: Provide manufacturer's standard catalog pages and data sheets for each product to be used including materials, finishes, fabrication details, dimensions, profiles, mounting requirements, and accessories.
- C. Shop Drawings: Include shade schedule indicating size, location and keys to details.
- D. Selection Samples: Include fabric samples in full range of available colors and patterns.
- E. Manufacturer's Instructions: Include instructions for storage, handling, protection, examination, preparation, and installation of product.
- F. Warranty: Submit sample of manufacturer's warranty and documentation of final executed warranty completed in Owner's name and registered with manufacturer.

1.05 QUALITY ASSURANCE

- A. Manufacturer Qualifications: Company specializing in manufacturing products specified in this section, with not less than ten years of documented experience.
- B. Installer Qualifications: Company specializing in performing work of this type with minimum ten years of documented experience with shading systems of similar size, type, and complexity; manufacturer's authorized representative.

1.06 DELIVERY, STORAGE, AND HANDLING

A. Deliver shades in manufacturer's unopened packaging, labeled to identify each shade for each opening.

B. Handle and store shades in accordance with manufacturer's recommendations.

1.07 FIELD CONDITIONS

A. Do not install products under environmental conditions outside manufacturer's absolute limits.

1.08 WARRANTY

- A. See Section 01 78 00 Closeout Submittals, for additional warranty requirements.
- B. Provide manufacturer's standard, non-depreciating warranty, for interior shading only, covering the following:
 - 1. Shade Hardware: 10 years unless otherwise indicated.
 - 2. Shade Fabric: 10 years unless otherwise indicated.

PART 2 PRODUCTS

2.01 MANUFACTURERS

- A. Basis of Design: MechoShade Systems LLC; Mecho/5; www.mechoshade.com/#sle.
- B. Other Acceptable Manufacturers:
 - 1. Draper Inc.; Clutch Operated FlexShade: www.draperinc.com.
 - 2. Products by listed manufacturers are subject to compliance with specified requirements.
- C. Substitutions: See Section 01 60 00 Product Requirements.

2.02 ROLLER SHADES

- A. General:
 - 1. Provide shade system components that are capable of being removed or adjusted without removing mounted shade brackets or cassette support channel.
 - 2. Provide shade system that operates smoothly when shades are raised or lowered.
- B. Roller Shades Type SP1 Basis of Design: MechoShade Systems LLC; Mecho/5 System; www.mechoshade.com/#sle.
 - 1. Description: Single roller, manually operated fabric window shades.
 - 2. Brackets and Mounting Hardware: As recommended by manufacturer for mounting indicated and to accommodate shade fabric roll-up size and weight.
 - 3. Roller Tubes:
 - a. Material: Extruded aluminum.
 - b. Size: As recommended by manufacturer; selected for suitability for installation conditions, span, and weight of shades.
 - c. Fabric Attachment: Utilize extruded channel in tube to accept vinyl spline welded to fabric edge. Shade band to be removable and replaceable without removing roller tube from brackets or inserting spline from the side of the roller tube.
 - d. Roller tubes to be capable of being removed and reinstalled without affecting roller shade limit adjustments.
 - 4. Hembars: Designed to maintain bottom of shade straight and flat.
 - a. Style: Full wrap fabric covered bottom bar, flat profile with heat sealed closed ends.
 - 5. Clutch Operator: Manufacturer's standard material and design integrated with bracket/brake assembly.

- a. Provide a permanently lubricated brake assembly mounted on an oil-impregnated hub with wrapped spring clutch.
- b. Brake must withstand minimum pull force of 50 pounds in the stopped position.
- c. Mount clutch/brake assembly on the support brackets, fully independent of the roller tube components.
- 6. Drive Chain: Continuous loop stainless steel beaded ball chain, 95 pound minimum breaking strength. Provide upper and lower limit stops.
 - a. Chain Retainer: Chain tensioning device complying with WCMA A100.1.
- 7. Accessories:
 - a. Fascia: Removable extruded aluminum fascia, size as required to conceal shade mounting, attachable to brackets without exposed fasteners; clear anodized finish.
 - 1) Fascia to be capable of installation across two or more shade bands in one piece.
 - 2) Provide single fascia to accommodate regular roll shades.
 - 3) Provide front and rear double fascia.
 - 4) Color: Black.

2.03 SHADE FABRIC

- A. Fabric: Non-flammable, color-fast, impervious to heat and moisture, and able to retain its shape under normal operation.
 - 1. Material Composition:
 - a. 100 percent polyester.
 - 2. Performance Requirements:
 - a. Flammability: Pass NFPA 701 large or small scale test.
 - 3. Color: As selected by Architect/Engineer from manufacturer's full range of colors.
 - 4. Fabrication:
 - a. Fabric Orientation: Railroaded, fabric is turned 90 degrees off the roll.
 - 1) Battens: Manufacturer's standard material, full width of shade, and enclosed in welded shade fabric pocket; locate as indicated on drawings.
 - 2) Seams for Railroaded Fabric: Manufacturer's standard sewn seam; locate as indicated on drawings.
 - 5. Products:
 - a. MechoShade Systems LLC Inc; Soho 1600 Series (3% open): www.mechoshade.com.
 - b. Substitutions: See Section 01 60 00 Product Requirements.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Examine finished openings for deficiencies that may preclude satisfactory installation.
- B. Start of installation shall be considered acceptance of substrates.

3.02 PREPARATION

- A. Prepare surfaces using methods recommended by manufacturer for achieving best result for substrate under the project conditions.
- B. Coordinate with window installation and placement of concealed blocking to support shades.

3.03 INSTALLATION

- A. Install in accordance with manufacturer's instructions and approved shop drawings, using mounting devices as indicated.
- B. Adjust level, projection, and shade centering from mounting bracket. Verify there is no telescoping of shade fabric. Ensure smooth shade operation.

3.04 CLEANING

- A. Clean soiled shades and exposed components as recommended by manufacturer.
- B. Replace shades that cannot be cleaned to "like new" condition.

3.05 CLOSEOUT ACTIVITIES

- A. See Section 01 78 00 Closeout Submittals, for closeout submittals.
- B. Demonstration: Demonstrate operation and maintenance of window shade system to Owner's personnel.

3.06 PROTECTION

- A. Protect installed products from subsequent construction operations.
- B. Touch-up, repair or replace damaged products before Substantial Completion.
SECTION 12 36 00 COUNTERTOPS

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Countertops for architectural cabinet work.
- B. Wall-hung counters.

1.02 RELATED REQUIREMENTS

A. Section 06 41 00 - Custom Casework.

1.03 REFERENCE STANDARDS

- A. ASTM E84 Standard Test Method for Surface Burning Characteristics of Building Materials; 2023d.
- B. AWI/AWMAC/WI (AWS) Architectural Woodwork Standards; 2014, with Errata (2018).
- C. AWMAC/WI (NAAWS) North American Architectural Woodwork Standards, U.S. Version 3.1; 2016, with Errata (2018).
- D. ISFA 2-01 Classification and Standards for Solid Surfacing Material; 2013.
- E. NEMA LD 3 High-Pressure Decorative Laminates; 2005.
- F. PS 1 Structural Plywood; 2023.

1.04 SUBMITTALS

- A. See Section 01 30 00 Administrative Requirements, for submittal procedures.
- B. Product Data: Manufacturer's data sheets on each product to be used, including:
 - 1. Preparation instructions and recommendations.
 - 2. Storage and handling requirements and recommendations.
 - 3. Specimen warranty.
- C. Shop Drawings: Complete details of materials and installation; combine with shop drawings of cabinets and casework specified in other sections.
- D. Verification Samples: For each finish product specified, minimum size 6 inches square, representing actual product, color, and patterns.
- E. Test Reports: Chemical resistance testing, showing compliance with specified requirements.
- F. Installation Instructions: Manufacturer's installation instructions and recommendations.
- G. Maintenance Data: Manufacturer's instructions and recommendations for maintenance and repair of countertop surfaces.

1.05 QUALITY ASSURANCE

A. Installer Qualifications: Company specializing in performing work of the type specified in this section, with not less than three years of experience.

1.06 DELIVERY, STORAGE, AND HANDLING

- A. Store products in manufacturer's unopened packaging until ready for installation.
- B. Store and dispose of solvent-based materials, and materials used with solvent-based materials, in accordance with requirements of local authorities having jurisdiction.

1.07 FIELD CONDITIONS

A. Maintain environmental conditions (temperature, humidity, and ventilation) within limits recommended by manufacturer for optimum results. Do not install products under environmental conditions outside manufacturer's absolute limits.

PART 2 PRODUCTS

2.01 COUNTERTOPS

- A. Quality Standard: Premium Grade, in accordance with AWI/AWMAC/WI (AWS) or AWMAC/WI (NAAWS), unless noted otherwise.
- B. Solid Surfacing Countertops (Type SSM1): Solid surfacing sheet or plastic resin casting over continuous substrate.
 - 1. Flat Sheet Thickness: 1/2 inch, minimum.
 - Solid Surfacing Sheet and Plastic Resin Castings: Complying with ISFA 2-01 and NEMA LD 3; acrylic or polyester resin, mineral filler, and pigments; homogenous, non-porous and capable of being worked and repaired using standard woodworking tools; no surface coating; color and pattern consistent throughout thickness.
 - a. Surface Burning Characteristics: Flame spread index of 25, maximum; smoke developed index of 450, maximum; when tested in accordance with ASTM E84.
 - b. NSF approved for food contact.
 - c. Finish on Exposed Surfaces: Matte, gloss rating of 5 to 20.
 - d. Product:
 - 1) Wilsonart Solid Surface: www.wilsonart.com.
 - 2) Colors: As indicated on the drawings
 - 3) Substitutions: Not permitted.
 - 3. Other Components Thickness: 1/2 inch, minimum.
 - 4. Exposed Edge Treatment: Built up to minimum 1-1/4 inch thick; edge profile as indicated on drawings.
 - 5. Exposed Edge Treatment: Built up to minimum 2-1/2 inch thick; edge profile as indicated on drawings.
 - 6. Back and End Splashes: Same sheet material, square top; minimum 4 inches high x 1/2 inch thick.
 - 7. Skirts: Where indicated on drawings.
 - 8. Fabricate in accordance with AWI/AWMAC/WI (AWS) standards, Section 11 Premium Grade.

2.02 MATERIALS

- A. Plywood for Supporting Substrate: PS 1 Exterior Grade, A-C veneer grade, minimum 5-ply; minimum 3/4 inch thick; join lengths using metal splines.
- B. Adhesives: Chemical resistant waterproof adhesive as recommended by manufacturer of materials being joined.

- C. Joint Sealant: Mildew-resistant silicone sealant, clear.
- D. Grommets for Holes in Countertops: As specified in Section 06 41 00.
- E. Support Brackets: 2 x 2 1/4 inch thick painted steel construction.
 - 1. Application: Provide where no other support (e.g. fabricated plastic laminate support brackets) is indicated on Drawings.
 - 2. Manufacturers:
 - a. A&M Hardware, Inc.: www.aandmhardware.com.
 - b. Rakks/Rangine Corporation: www.rakks.com.
 - 3. Products:
 - a. Counters Up To 18 Inches Deep:
 - 1) A&M #C-12.
 - 2) Rakks #EH-1212.
 - b. Counters 19 To 24 Inches Deep:
 - 1) A&M #C-18.
 - 2) Rakks #EH-1818.
 - c. Counters 25 To 30 Inches Deep:
 - 1) A&M #C-24.
 - 2) Rakks #EH-2424.
 - 4. Use A&M brackets or Rakks "Flush Mount" configuration (vertical leg concealed in wall) at all drywall locations and where indicated on Drawings.

2.03 FABRICATION

- A. Fabricate tops and splashes in the largest sections practicable, with top surface of joints flush.
 - 1. Join lengths of tops using best method recommended by manufacturer.
 - 2. Fabricate to overhang fronts and ends of cabinets 1 inch except where top butts against cabinet or wall.
 - 3. Prepare all cutouts accurately to size; replace tops having improperly dimensioned or unnecessary cutouts or fixture holes.
- B. Provide back/end splash wherever counter edge abuts vertical surface unless otherwise indicated.
 - 1. Secure to countertop with concealed fasteners and with contact surfaces set in waterproof glue.
 - 2. Height: 4 inches, unless otherwise indicated.
- C. Solid Surfacing: Fabricate tops up to 144 inches long in one piece; join pieces with adhesive sealant in accordance with manufacturer's recommendations and instructions.
- D. Wall-Mounted Counters: Provide skirts, aprons, and brackets as indicated on Drawings.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Do not begin installation until substrates have been properly prepared.
- B. If substrate preparation is the responsibility of another installer, notify Architect/Engineer of unsatisfactory preparation before proceeding.
- C. Verify that wall surfaces have been finished and mechanical and electrical services and outlets are installed in proper locations.

3.02 PREPARATION

- A. Clean surfaces thoroughly prior to installation.
- B. Prepare surfaces using the methods recommended by the manufacturer for achieving the best result for the substrate under the project conditions.

3.03 INSTALLATION

- A. Securely attach countertops to cabinets using concealed fasteners. Make flat surfaces level; shim where required.
- B. Seal joints between back/end splashes and vertical surfaces.

3.04 TOLERANCES

- A. Variation From Horizontal: 1/8 inch in 10 feet, maximum.
- B. Offset From Wall, Countertops: 1/8 inch maximum; 1/16 inch minimum.
- C. Field Joints: 1/16 inch wide, maximum.

3.05 CLEANING

A. Clean countertops surfaces thoroughly.

3.06 PROTECTION

- A. Protect installed products until completion of project.
- B. Touch-up, repair or replace damaged products before Date of Substantial Completion.

SECTION 21 05 00 COMMON WORK RESULTS FOR FIRE SUPPRESSION

PART 1 GENERAL

1.01 SECTION INCLUDES

A. Pipe, fittings, sleeves, escutcheons, seals, and connections for sprinkler systems.

1.02 RELATED REQUIREMENTS

A. Section 21 13 00 - Fire Suppression Sprinklers: Sprinkler systems design.

1.03 REFERENCE STANDARDS

- A. ASME A112.18.1 Plumbing Supply Fittings; 2018, with Errata.
- B. ASME BPVC-IX Boiler and Pressure Vessel Code, Section IX Welding, Brazing, and Fusing Qualifications; 2015.
- C. ASME B16.1 Gray Iron Pipe Flanges and Flanged Fittings: Classes 25, 125, and 250; 2010.
- D. ASME B16.3 Malleable Iron Threaded Fittings: Classes 150 and 300; 2021.
- E. ASME B16.4 Gray Iron Threaded Fittings: Classes 125 and 250; 2021.
- F. ASME B16.11 Forged Fittings, Socket-welding and Threaded; 2011.
- G. ASTM A47/A47M Standard Specification for Ferritic Malleable Iron Castings; 1999, with Editorial Revision (2022).
- H. NFPA 13 Standard for the Installation of Sprinkler Systems; 2016.

1.04 SUBMITTALS

- A. See Section 01 30 00 Administrative Requirements, for submittal procedures.
- B. Product Data: Provide manufacturers catalogue information. Indicate valve data and ratings.
- C. Shop Drawings: Indicate pipe materials used, jointing methods, supports, floor and wall penetration seals. Indicate installation, layout, weights, mounting and support details, and piping connections.
- D. Project Record Documents: Record actual locations of components and tag numbering.
- E. Operation and Maintenance Data: Include installation instructions and spare parts lists.

1.05 QUALITY ASSURANCE

- A. Manufacturer Qualifications: Company specializing in manufacturing the Products specified in this section with minimum three years documented experience.
- B. Installer Qualifications: Company specializing in performing work of the type specified in this section.
 - 1. Minimum three years experience.
- C. Conform to UL and FM requirements.

1.06 DELIVERY, STORAGE, AND HANDLING

- A. Deliver and store valves in shipping containers, with labeling in place.
- B. Provide temporary protective coating on cast iron and steel valves.
- C. Provide temporary end caps and closures on piping and fittings. Maintain in place until installation.

PART 2 PRODUCTS

2.01 FIRE PROTECTION SYSTEMS

- A. Sprinkler Systems: Conform to NFPA 13.
- B. Welding Materials and Procedures: Conform to ASME BPVC-IX.

2.02 ABOVE GROUND PIPING

- A. Steel Pipe: Schedule 40, black.
 - 1. Steel Fittings: ASME B16.11, forged steel socket welded and threaded.
 - 2. Cast Iron Fittings: ASME B16.1, flanges and flanged fittings and ASME B16.4, threaded fittings.
 - 3. Malleable Iron Fittings: ASME B16.3, threaded fittings and ASTM A47/A47M.
 - 4. Mechanical Grooved Couplings: Malleable iron housing clamps to engage and lock, "C" shaped elastomeric sealing gasket, steel bolts, nuts, and washers; galvanized for galvanized pipe.

2.03 ESCUTCHEONS

- A. Material:
 - 1. Metals and Finish: Comply with ASME A112.18.
- B. Construction:
 - 1. One-piece for mounting on chrome-plated tubing or pipe and one-piece or split-pattern type elsewhere.
 - 2. Internal spring tension devices or setscrews to maintain a fixed position against a surface.

2.04 PIPE HANGERS AND SUPPORTS

- A. Hangers for Pipe Sizes 1/2 to 1-1/2 inch: Malleable iron, adjustable swivel, split ring.
- B. Hangers for Pipe Sizes 2 inches and Over: Carbon steel, adjustable, clevis.

PART 3 EXECUTION

3.01 PREPARATION

- A. Ream pipe and tube ends. Remove burrs. Bevel plain end ferrous pipe.
- B. Remove scale and foreign material, from inside and outside, before assembly.
- C. Prepare piping connections to equipment with flanges or unions.

3.02 INSTALLATION

A. Install sprinkler system and service main piping, hangers, and supports in accordance with NFPA 13.

- B. Route piping in orderly manner, plumb and parallel to building structure. Maintain gradient.
- C. Install piping to conserve building space, to not interfere with use of space and other work.
- D. Group piping whenever practical at common elevations.
- E. Install piping to allow for expansion and contraction without stressing pipe, joints, or connected equipment.
- F. Pipe Hangers and Supports:
 - 1. Install hangers to provide minimum 1/2 inch space between finished covering and adjacent work.
 - 2. Place hangers within 12 inches of each horizontal elbow.
 - 3. Use hangers with 1-1/2 inch minimum vertical adjustment. Design hangers for pipe movement without disengagement of supported pipe.
 - 4. Where several pipes can be installed in parallel and at same elevation, provide multiple or trapeze hangers.
- G. Slope piping and arrange systems to drain at low points. Use eccentric reducers to maintain top of pipe level.
- H. Prepare pipe, fittings, supports, and accessories for finish painting. Where pipe support members are welded to structural building framing, scrape, brush clean, and apply one coat of zinc rich primer to welding.
- I. Do not penetrate building structural members unless indicated.
- J. Escutcheons:
 - 1. Install and firmly attach escutcheons at piping penetrations into finished spaces.
 - 2. Provide escutcheons on both sides of partitions separating finished areas through which piping passes.
 - 3. Use chrome plated escutcheons in occupied spaces and to conceal openings in construction.
- K. When installing more than one piping system material, ensure system components are compatible and joined to ensure the integrity of the system. Provide necessary joining fittings. Ensure flanges, union, and couplings for servicing are consistently provided.

SECTION 21 13 00 FIRE SUPPRESSION SPRINKLERS

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Wet-pipe sprinkler system.
- B. System design, installation, and certification.

1.02 RELATED REQUIREMENTS

A. Section 21 05 00 - COMMON WORK RESULTS FOR FIRE SUPPRESSION: Pipe, fittings, and valves.

1.03 REFERENCE STANDARDS

- A. FM Approval Guide; Factory Mutual Global; current edition.
- B. NFPA 13 Standard for the Installation of Sprinkler Systems; 2016.
- C. UL (DIR) Online Certifications Directory; Current Edition.

1.04 SUBMITTALS

- A. See Section 01 30 00 Administrative Requirements, for submittal procedures.
- B. Product Data: Provide data on sprinklers, valves, and specialties, including manufacturers catalog information. Submit performance ratings, rough-in details, weights, support requirements, and piping connections.
- C. Shop Drawings:
 - 1. Indicate hydraulic calculations, detailed pipe layout, hangers and supports, sprinklers, components and accessories. Indicate system controls.
 - 2. Submit shop drawings to Authority Having Jurisdiction for approval. Submit proof of approval to Architect/Engineer.
- D. Project Record Documents: Record actual locations of sprinklers and deviations of piping from drawings. Indicate drain and test locations.
- E. Maintenance Materials: Furnish the following for Owner's use in maintenance of project.
 - 1. See Section 01 60 00 Product Requirements, for additional provisions.
 - 2. Extra Sprinklers: Type and size matching those installed, in quantity required by referenced NFPA design and installation standard.
 - 3. Sprinkler Wrenches: For each sprinkler type.
- F. Project Record Documents: Record actual locations of sprinklers and deviations of piping from drawings. Indicate drain and test locations.

1.05 QUALITY ASSURANCE

- A. Conform to UL (DIR) requirements.
- B. Designer Qualifications: Design system under direct supervision of a Professional Engineer experienced in design of this type of work and licensed in the State in which the Project is located.

Or a holder of a valid NICET level III or IV Sprinkler Technician.

- C. Manufacturer Qualifications: Company specializing in manufacturing the Products specified in this section with minimum three years documented experience.
- D. Installer Qualifications: Company specializing in performing the work of this section with minimum 3 years experience approved by manufacturer.
- E. Equipment and Components: Provide products that bear UL (DIR) label or marking.

1.06 DELIVERY, STORAGE, AND HANDLING

A. Store products in shipping containers and maintain in place until installation. Provide temporary inlet and outlet caps. Maintain caps in place until installation.

PART 2 PRODUCTS

2.01 SPRINKLER SYSTEM

- A. Sprinkler System: Provide coverage for building areas noted.
- B. Occupancy: Light hazard; comply with NFPA 13.
- C. Water Supply: Determine volume and pressure from water flow test data.
- D. Storage Cabinet for Spare Sprinklers and Tools: Steel, in location designated.

2.02 SPRINKLERS

- A. Suspended Ceiling Type: Concealed pendant type with matching push on escutcheon plate.
 - 1. Response Type: Standard.
 - 2. Coverage Type: Standard.
 - 3. Finish: Enamel color white .
 - 4. Escutcheon Plate Finish: Enamel, color white .
 - 5. Fusible Link: Glass bulb type temperature rated for specific area hazard.

2.03 STAINLESS STEEL FLEXIBLE DROPS

- A. Manufacturers:
 - 1. Flex Head Industries, Inc.
 - 2. Aqua Flex.
 - 3. Victaulic Company.
- B. In lieu of rigid pipe offsets or return bends. Braided type 304 stainless steel flexible tube with male threaded pipe nipple for connection to branchline piping, and a zinc plated steel reducer with a 1/2" or 3/4" NPT female thread for connection to a sprinkler head. The hoses shall be factory-pressure tested to 400 psi.
- C. Flexible drop shall attach to the ceiling grid with open gate bracket and can be installed without the use of special tools.
- D. The braided drop shall be FM approved for sprinkler services to 200 psi.

PART 3 EXECUTION

3.01 INSTALLATION

- A. Install in accordance with referenced NFPA design and installation standard.
- B. Install equipment in accordance with manufacturer's instructions.
- C. Place pipe runs to minimize obstruction to other work.
- D. Place piping in concealed spaces above finished ceilings.
- E. Center sprinklers in two directions in ceiling tile and provide piping offsets as required.
- F. Apply masking tape or paper cover to ensure concealed sprinklers, cover plates, and sprinkler escutcheons do not receive field paint finish. Remove after painting. Replace painted sprinklers.
- G. Flush installed sections of piping system of foreign matter.
- H. Hydrostatically test entire system.
- I. Require test be witnessed by Authority Having Jurisdiction.

3.02 INTERFACE WITH OTHER PRODUCTS

A. Ensure required devices are installed and connected as required to fire alarm system.

3.03 SCHEDULES

- A. System Hazard Areas:
 - 1. Offices: Light Hazard.
 - 2. Equipment and Storage Rooms: Ordinary Hazard, Group 2.
 - 3. Other Areas: In accordance with NFPA 13.

SECTION 22 07 19 PLUMBING PIPING INSULATION

PART 1 GENERAL

1.01 SECTION INCLUDES

A. Glass fiber insulation.

1.02 RELATED REQUIREMENTS

- A. Section 07 84 00 Firestopping.
- B. Section 22 10 05 Plumbing Piping: Placement of hangers and hanger inserts.

1.03 REFERENCE STANDARDS

- A. ASTM C177 Standard Test Method for Steady-State Heat Flux Measurements and Thermal Transmission Properties by Means of the Guarded-Hot-Plate Apparatus; 2019, with Editorial Revision (2023).
- B. ASTM C547 Standard Specification for Mineral Fiber Pipe Insulation; 2022a.
- C. ASTM C795 Standard Specification for Thermal Insulation for Use in Contact with Austenitic Stainless Steel; 2008 (Reapproved 2018).
- D. ASTM E84 Standard Test Method for Surface Burning Characteristics of Building Materials; 2023d.
- E. ASTM E96/E96M Standard Test Methods for Gravimetric Determination of Water Vapor Transmission Rate of Materials; 2023.
- F. UL 723 Standard for Test for Surface Burning Characteristics of Building Materials; Current Edition, Including All Revisions.

1.04 QUALITY ASSURANCE

A. Manufacturer Qualifications: Company specializing in manufacturing the Products specified in this section with not less than three years of documented experience.

1.05 DELIVERY, STORAGE, AND HANDLING

A. Accept materials on site, labeled with manufacturer's identification, product density, and thickness.

1.06 FIELD CONDITIONS

- A. Maintain ambient conditions required by manufacturers of each product.
- B. Maintain temperature before, during, and after installation for minimum of 24 hours.

PART 2 PRODUCTS

2.01 REGULATORY REQUIREMENTS

A. Surface Burning Characteristics: Flame spread index/Smoke developed index of 25/50, maximum, when tested in accordance with ASTM E84 or UL 723.

2.02 GLASS FIBER INSULATION

- A. Manufacturers:
 - 1. CertainTeed Corporation.
 - 2. Johns Manville Corporation.
 - 3. Knauf Insulation.
 - 4. Owens Corning Corporation.
- B. Insulation: ASTM C547 and ASTM C795; rigid molded, noncombustible.
 - 1. K Value: ASTM C177, 0.24 at 75 degrees F.
 - 2. Maximum Service Temperature: 850 degrees F.
 - 3. Maximum Moisture Absorption: 0.2 percent by volume.
- C. Vapor Barrier Jacket: White Kraft paper with glass fiber yarn, bonded to aluminized film; moisture vapor transmission when tested in accordance with ASTM E96/E96M of 0.02 perm.
- D. Vapor Barrier Lap Adhesive: Compatible with insulation.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify that piping has been tested before applying insulation materials.
- B. Verify that surfaces are clean and dry, with foreign material removed.

3.02 INSTALLATION

- A. Install in accordance with manufacturer's instructions.
- B. Install in accordance with North American Insulation Manufacturers Association (NAIMA) National Insulation Standards.
- C. Glass fiber insulated pipes conveying fluids below ambient temperature:
 - 1. Provide vapor barrier jackets, factory-applied or field-applied. Secure with self-sealing longitudinal laps and butt strips with pressure-sensitive adhesive. Secure with outward clinch expanding staples and vapor barrier mastic.
 - 2. Insulate fittings, joints, and valves with molded insulation of like material and thickness as adjacent pipe. Finish with glass cloth and vapor barrier adhesive or PVC fitting covers.
- D. For hot piping conveying fluids 140 degrees F or less, do not insulate flanges and unions at equipment, but bevel and seal ends of insulation.
- E. Glass fiber insulated pipes conveying fluids above ambient temperature:
 - 1. Provide standard jackets, with or without vapor barrier, factory-applied or field-applied. Secure with self-sealing longitudinal laps and butt strips with pressure-sensitive adhesive. Secure with outward clinch expanding staples.
 - 2. Insulate fittings, joints, and valves with insulation of like material and thickness as adjoining pipe. Finish with glass cloth and adhesive or PVC fitting covers.
- F. Inserts and Shields:
 - 1. Shields: Galvanized steel between pipe hangers or pipe hanger rolls and inserts.

G. Continue insulation through walls, sleeves, pipe hangers, and other pipe penetrations. Finish at supports, protrusions, and interruptions. At fire separations, see Section 07 84 00.

3.03 SCHEDULES

- A. Plumbing Systems:
 - 1. Domestic Hot Water Supply:
 - a. Glass Fiber Insulation:
 - 1) Pipe Size Range: Up to and including 1-1/4 inch.
 - 2) Thickness: 1 inch.
 - 2. Domestic Cold Water Supply:
 - a. Glass Fiber Insulation:
 - 1) Pipe Size Range: All sizes.
 - 2) Thickness: 1 inch.

SECTION 22 10 05 PLUMBING PIPING

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Sanitary waste piping, above grade.
- B. Domestic water piping, above grade.
- C. Pipe flanges, unions, and couplings.
- D. Pipe hangers and supports.
- E. Ball valves.

1.02 RELATED REQUIREMENTS

A. Section 22 07 19 - Plumbing Piping Insulation.

1.03 REFERENCE STANDARDS

- A. ASME B16.18 Cast Copper Alloy Solder Joint Pressure Fittings; 2021.
- B. ASME B16.22 Wrought Copper and Copper Alloy Solder-Joint Pressure Fittings; 2018.
- C. ASME B31.9 Building Services Piping; 2020.
- D. ASTM B32 Standard Specification for Solder Metal; 2020.
- E. ASTM B88 Standard Specification for Seamless Copper Water Tube; 2016.
- F. ASTM B88M Standard Specification for Seamless Copper Water Tube (Metric); 2016.
- G. ASTM B813 Standard Specification for Liquid and Paste Fluxes for Soldering of Copper and Copper Alloy Tube; 2016.
- H. ASTM B828 Standard Practice for Making Capillary Joints by Soldering of Copper and Copper Alloy Tube and Fittings; 2016.
- I. ASTM D2564 Standard Specification for Solvent Cements for Poly(Vinyl Chloride) (PVC) Plastic Piping Systems; 2020.
- J. ASTM D2665 Standard Specification for Poly(Vinyl Chloride) (PVC) Plastic Drain, Waste, and Vent Pipe and Fittings; 2020.
- K. ASTM D2855 Standard Practice for the Two-Step (Primer and Solvent Cement) Method of Joining Poly (Vinyl Chloride) (PVC) or Chlorinated Poly (Vinyl Chloride) (CPVC) Pipe and Piping Components with Tapered Sockets; 2020.
- L. MSS SP-58 Pipe Hangers and Supports Materials, Design, Manufacture, Selection, Application, and Installation; 2009.
- M. MSS SP-110 Ball Valves Threaded, Socket-Welding, Solder Joint, Grooved and Flared Ends; 2010, with Errata .
- N. NSF 61 Drinking Water System Components Health Effects; 2019.

O. NSF 372 - Drinking Water System Components - Lead Content; 2022.

1.04 QUALITY ASSURANCE

- A. Perform work in accordance with applicable codes.
- B. Valves: Manufacturer's name and pressure rating marked on valve body.

1.05 DELIVERY, STORAGE, AND HANDLING

- A. Accept valves on site in shipping containers with labeling in place. Inspect for damage.
- B. Provide temporary end caps and closures on piping and fittings. Maintain in place until installation.
- C. Protect piping systems from entry of foreign materials by temporary covers, completing sections of the work, and isolating parts of completed system.

PART 2 PRODUCTS

2.01 GENERAL REQUIREMENTS

A. Potable Water Supply Systems: Provide piping, pipe fittings, and solder and flux (if used), that comply with NSF 61 and NSF 372 for maximum lead content; label pipe and fittings.

2.02 SANITARY WASTE PIPING, ABOVE GRADE

- A. PVC Pipe: ASTM D2665.
 - 1. Fittings: PVC.
 - 2. Joints: Solvent welded, with ASTM D2564 solvent cement.

2.03 DOMESTIC WATER PIPING, ABOVE GRADE

- A. Copper Pipe: ASTM B88 (ASTM B88M), Type L (B), Drawn (H).
 - 1. Fittings: ASME B16.18, cast copper alloy or ASME B16.22, wrought copper and bronze.
 - 2. Joints: ASTM B32, alloy Sn95 solder.
 - 3. Mechanical Press Sealed Fittings: Double-pressed type, NSF 61 and NSF 372 approved or certified, utilizing EPDM, nontoxic, synthetic rubber sealing elements.

2.04 PIPE FLANGES, UNIONS, AND COUPLINGS

- A. Unions for Pipe Sizes 3 inch and Under:
 - 1. Copper Tube and Pipe: Class 150 bronze unions with soldered joints.

2.05 PIPE HANGERS AND SUPPORTS

- A. Provide hangers and supports that comply with MSS SP-58.
 - 1. If type of hanger or support for a particular situation is not indicated, select appropriate type using MSS SP-58 recommendations.
 - 2. Overhead Supports: Individual steel rod hangers attached to structure or to trapeze hangers.
 - 3. Trapeze Hangers: Welded steel channel frames attached to structure.
 - 4. Vertical Pipe Support: Steel riser clamp.
- B. Plumbing Piping Drain, Waste, and Vent:
 - 1. Hangers for Pipe Sizes 1/2 to 1-1/2 inch: Malleable iron, adjustable swivel, split ring.
 - 2. Hangers for Pipe Sizes 2 inch and Over: Carbon steel, adjustable, clevis.

- C. Plumbing Piping Water:
 - 1. Hangers for Pipe Sizes 1/2 to 1-1/2 inch: Malleable iron, adjustable swivel, split ring.
 - 2. Hangers for Cold Pipe Sizes 2 inch and Over: Carbon steel, adjustable, clevis.

2.06 BALL VALVES

- A. Manufacturers:
 - 1. Nibco, Inc; T/S-585-66-LF.
 - 2. Apollo Valves.
 - 3. Watts.
- B. Construction, 4 inch and Smaller: MSS SP-110, Class 150, 400 psi CWP, bronze or ductile iron body, 304 stainless steel ball, regular port, teflon seats and stuffing box ring, blow-out proof stem, lever handle, solder ends.

PART 3 EXECUTION

3.01 PREPARATION

- A. Ream pipe and tube ends. Remove burrs. Bevel plain end ferrous pipe.
- B. Remove scale and dirt, on inside and outside, before assembly.
- C. Prepare piping connections to equipment with flanges or unions.

3.02 INSTALLATION

- A. Install in accordance with manufacturer's instructions.
- B. Provide non-conducting dielectric connections wherever jointing dissimilar metals.
- C. Route piping in orderly manner and maintain gradient. Route parallel and perpendicular to walls.
- D. Install piping to maintain headroom, conserve space, and not interfere with use of space.
- E. Provide clearance in hangers and from structure and other equipment for installation of insulation and access to valves and fittings.
- F. Copper Pipe and Tube: Make soldered joints in accordance with ASTM B828, using specified solder, and flux meeting ASTM B813; in potable water systems use flux also complying with NSF 61 and NSF 372.
- G. PVC Pipe: Make solvent-welded joints in accordance with ASTM D2855.
- H. Pipe Hangers and Supports:
 - 1. Install in accordance with ASME B31.9.
 - 2. Support horizontal piping as indicated.
 - 3. Install hangers to provide minimum 1/2 inch space between finished covering and adjacent work.
 - 4. Place hangers within 12 inches of each horizontal elbow.

3.03 APPLICATION

A. Install ball valves for shut-off and to isolate equipment, part of systems, or vertical risers.

3.04 TOLERANCES

- A. Drainage Piping: Establish invert elevations within 1/2 inch vertically of location indicated and slope to drain at minimum of 1/4 inch per foot slope.
- B. Water Piping: Slope at minimum of 1/32 inch per foot and arrange to drain at low points.

3.05 FIELD TESTS AND INSPECTIONS

- A. Verify and inspect systems according to requirements by the Authority Having Jurisdiction. In the absence of specific test and inspection procedures proceed as indicated below.
- B. Domestic Water Systems:
 - 1. Perform hydrostatic testing for leakage prior to system disinfection.
 - 2. Test Preparation: Close each fixture valve or disconnect and cap each connected fixture.
 - 3. General:
 - a. Fill the system with water and raise static head to 10 psi above service pressure. Minimum static head of 50 to 150 psi. As an exception, certain codes allow a maximum static pressure of 80 psi.
- C. Test Results: Document and certify successful results, otherwise repair, document, and retest.

3.06 DISINFECTION OF DOMESTIC WATER PIPING SYSTEM

- A. Prior to starting work, verify system is complete, flushed, and clean.
- B. Ensure acidity (pH) of water to be treated is between 7.4 and 7.6 by adding alkali (caustic soda or soda ash) or acid (hydrochloric).
- C. Inject disinfectant, free chlorine in liquid, powder, tablet, or gas form throughout system to obtain 50 to 80 mg/L residual.
- D. Bleed water from outlets to ensure distribution and test for disinfectant residual at minimum 15 percent of outlets.
- E. Maintain disinfectant in system for 24 hours.
- F. If final disinfectant residual tests less than 25 mg/L, repeat treatment.
- G. Flush disinfectant from system until residual equal to that of incoming water or 1.0 mg/L.

3.07 SCHEDULES

- A. Pipe Hanger Spacing:
 - 1. Metal Piping:
 - a. Pipe Size: 1/2 inch to 1-1/4 inch:
 - 1) Maximum Hanger Spacing: 6.5 ft.
 - 2) Hanger Rod Diameter: 3/8 inches.
 - b. Pipe Size: 1-1/2 inch to 2 inch:
 - 1) Maximum Hanger Spacing: 10 ft.
 - 2) Hanger Rod Diameter: 3/8 inch.
 - 2. Plastic Piping:
 - a. All Sizes:
 - 1) Maximum Hanger Spacing: 6 ft.

2) Hanger Rod Diameter: 3/8 inch.

SECTION 22 10 06 PLUMBING PIPING SPECIALTIES

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Drains.
- B. Cleanouts.
- C. Water hammer arrestors.
- D. Air vents.

1.02 RELATED REQUIREMENTS

- A. Section 22 10 05 Plumbing Piping.
- B. Section 22 40 00 Plumbing Fixtures.

1.03 REFERENCE STANDARDS

- A. ASME A112.6.3 Floor and Trench Drains; 2019.
- B. NSF 61 Drinking Water System Components Health Effects; 2019.
- C. NSF 372 Drinking Water System Components Lead Content; 2022.
- D. PDI-WH 201 Water Hammer Arresters; 2017.

1.04 SUBMITTALS

- A. See Section 01 30 00 Administrative Requirements for submittal procedures.
- B. Product Data: Provide component sizes, rough-in requirements, service sizes, and finishes.

1.05 QUALITY ASSURANCE

A. Manufacturer Qualifications: Company specializing in manufacturing the Products specified in this section with not less than three years documented experience.

1.06 DELIVERY, STORAGE, AND HANDLING

A. Accept specialties on site in original factory packaging. Inspect for damage.

PART 2 PRODUCTS

2.01 GENERAL REQUIREMENTS

A. Specialties in Potable Water Supply Systems: Provide products that comply with NSF 61 and NSF 372 for maximum lead content.

2.02 DRAINS

- A. Manufacturers:
 - 1. Jay R. Smith Manufacturing Company.
 - 2. MIFAB, Inc.
 - 3. Zurn Industries, LLC.

- B. Floor Drains:
- C. Floor Drain FD:
 - 1. ASME A112.6.3; lacquered cast iron or stainless steel, two piece body with double drainage flange, weep holes, reversible clamping collar, and round, adjustable nickel-bronze strainer.
 - 2. J.R. Smith; Model 2005.

2.03 CLEANOUTS

- A. Cleanouts at Interior Finished Wall Areas:
 - 1. Line type with lacquered cast iron body and round epoxy coated gasketed cover, and round stainless steel access cover secured with machine screw.
- B. Cleanouts at Interior Unfinished Accessible Areas: Calked or threaded type.

2.04 WATER HAMMER ARRESTORS

- A. Manufacturers:
 - 1. Jay R. Smith Manufacturing Company.
 - 2. Watts Regulator Company, a part of Watts Water Technologies.
 - 3. Sioux Chief.
- B. Water Hammer Arrestors:
 - Copper or stainless steel construction, bellows type sized in accordance with PDI-WH 201, precharged suitable for operation in temperature range minus 100 to 300 degrees F and maximum 250 psi working pressure.

2.05 AIR VENTS

A. Manual Type: Short vertical sections of 2 inch diameter pipe to form air chamber, with 1/8 inch brass needle valve at top of chamber.

PART 3 EXECUTION

3.01 INSTALLATION

- A. Install in accordance with manufacturer's instructions.
- B. Extend cleanouts to finished floor or wall surface. Lubricate threaded cleanout plugs with mixture of graphite and linseed oil. Ensure clearance at cleanout for rodding of drainage system.
- C. Install floor cleanouts at elevation to accommodate finished floor.
- D. Install water hammer arrestors complete with accessible isolation valve on hot and cold water supply piping to plumbing fixtures.

SECTION 22 30 00 PLUMBING EQUIPMENT

PART 1 GENERAL

1.01 SECTION INCLUDES

A. Tankless electric water heaters.

1.02 RELATED REQUIREMENTS

A. Section 26 05 83 - Wiring Connections: Electrical characteristics and wiring connections.

1.03 REFERENCE STANDARDS

A. NFPA 70 - National Electrical Code; Most Recent Edition Adopted by Authority Having Jurisdiction, Including All Applicable Amendments and Supplements.

1.04 SUBMITTALS

- A. See Section 01 30 00 Administrative Requirements for submittals procedures.
- B. Product Data:
 - 1. Provide dimension drawings of water heaters indicating components and connections to other equipment and piping.
 - 2. Provide electrical characteristics and connection requirements.
- C. Operation and Maintenance Data: Include operation, maintenance, and inspection data, replacement part numbers and availability, and service depot location and telephone number.

1.05 QUALITY ASSURANCE

- A. Certifications:
 - 1. Water Heaters: NSF approved.
 - 2. Products Requiring Electrical Connection: Listed and classified by Underwriters Laboratories Inc., as suitable for the purpose specified and indicated.

1.06 DELIVERY, STORAGE, AND HANDLING

A. Provide temporary inlet and outlet caps. Maintain caps in place until installation.

PART 2 PRODUCTS

2.01 WATER HEATERS

A. COMMERCIAL INSTANTANEOUS ELECTRIC HEATERS

- 1. Manufacturers;
 - a. Eemax.
 - b. Chronomite.
- 2. IWH Eemax; Lav Advantage.
 - a. Unit shall have ABS-UL 94 5VA rated cover. Unit shall have 0.2 GPM turn on. Unit shall allow mounting in any direction. Element shall be replaceable cartridge insert. Unit shall have replaceable filter in the inlet connector. Element shall be iron free, Nickel Chrome material. Tankless water heater to utilize complex algorithm, actively managing power application to real time system demand. Integrated flow meter, along with inlet and outlet

temperature sensors provide data which allows the unit to instantly adapt to variations in input parameters. Heater shall be fitted with 3/8" compression fittings to eliminate need for soldering.

- b. Maximum operating pressure of 150 psi.
- c. Tankless water heater user interface shall have the following capabilities;
 - 1) Field serviceable elements.
 - 2) Selectable display including celcius/fhrenheit, setpoint, flow rate, intel temperature, outlet temperature, and power factor.
 - 3) Capable of displaying flow rate in gpm and lpm.
 - 4) Diagnostic features to include error/fault display.

PART 3 EXECUTION

3.01 INSTALLATION

- A. Install plumbing equipment in accordance with manufacturer's instructions, as required by code, and complying with conditions of certification, if any.
- B. Coordinate with plumbing piping and related electrical work to achieve operating system.

SECTION 22 40 00 PLUMBING FIXTURES

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Flush valve water closets.
- B. Lavatories.
- C. Sinks.

1.02 RELATED REQUIREMENTS

- A. Section 22 10 05 Plumbing Piping.
- B. Section 22 30 00 Plumbing Equipment.

1.03 REFERENCE STANDARDS

- A. ADA Standards 2010 ADA Standards for Accessible Design; 2010.
- B. ASME A112.6.1M Floor-Affixed Supports for Off-the-Floor Plumbing Fixtures for Public Use; 1997 (Reaffirmed 2017).
- C. ASME A112.18.1 Plumbing Supply Fittings; 2018, with Errata.
- D. ASME A112.19.2 Ceramic Plumbing Fixtures; 2018, with Errata.
- E. ASME A112.19.3 Stainless Steel Plumbing Fixtures; 2022.
- F. ASME A112.19.5 Flush Valves and Spuds for Water Closets, Urinals, and Tanks; 2022.
- G. ASSE 1070 Performance Requirements for Water Temperature Limiting Devices; 2020.
- H. NSF 61 Drinking Water System Components Health Effects; 2019.
- I. NSF 372 Drinking Water System Components Lead Content; 2022.
- J. UL (DIR) Online Certifications Directory; Current Edition.

1.04 SUBMITTALS

- A. See Section 01 30 00 Administrative Requirements for submittal procedures.
- B. Product Data: Provide catalog illustrations of fixtures, sizes, rough-in dimensions, utility sizes, trim, and finishes.

1.05 QUALITY ASSURANCE

A. Manufacturer Qualifications: Company specializing in manufacturing the type of products specified in this section, with minimum three years of documented experience.

1.06 DELIVERY, STORAGE, AND HANDLING

- A. Accept fixtures on-site in factory packaging. Inspect for damage.
- B. Protect installed fixtures from damage by securing areas and by leaving factory packaging in place to protect fixtures and prevent use.

PART 2 PRODUCTS

2.01 GENERAL REQUIREMENTS

A. Potable Water Systems: Provide plumbing fittings and faucets that comply with NSF 61 and NSF 372 for maximum lead content; label pipe and fittings.

2.02 REGULATORY REQUIREMENTS

- A. Comply with applicable codes for installation of plumbing systems.
- B. Comply with UL (DIR) requirements.

2.03 FLUSH VALVE WATER CLOSETS (WC), ADAAG COMPLIANT

- A. Water Closets:
 - 1. Vitreous china, ASME A112.19.2, wall hung, siphon jet flush action.
 - 2. Bowl: ASME A112.19.2; 18 inches high with elongated rim.
 - 3. Flush Valve: Exposed (top spud), dual flush.
 - 4. Flush Operation: Sensor operated.
 - 5. Color: White.
 - 6. Manufacturers:
 - a. Sloan Valve Company; Model ST-2459.
 - b. American Standard, Inc:.
 - c. Zurn Industries, LLC.

B. Flush Valves:

- 1. Valve Supply Size: 1 inch.
- 2. Manufacturers:
 - a. Sloan Valve Company; Model 8111-1.6/1.1.
 - b. Zurn Industries, LLC.
 - c. Substitutions: See Section 01 60 00 Product Requirements.
- 3. Sensor-Operated:
 - a. Type: ASME A112.19.5; chloramine-resistant clog-resistant dual-seat diaphragm valve complete with vacuum breaker, stops and accessories.
 - b. Mechanism: Solenoid-operated piston or electronic motor-actuated operator with battery powered infrared sensor, and override push button.
 - c. Supplied Volume Capacity: 1.6/1.1 gal per flush.
- 4. Exposed Type: Chrome-plated, escutcheon, integral screwdriver stop.
- C. Toilet Seats:
 - 1. Manufacturers:
 - a. Bemis Manufacturing Company; Model 2155SSC.
 - b. Olsonite.
 - c. Church.
 - 2. Plastic: White finish, open front, extended back, self-sustaining hinge, brass bolts, without cover.
- D. Water Closet Carriers:

1. ASME A112.6.1M; adjustable cast iron frame, integral drain hub and vent, adjustable spud, lugs for floor and wall attachment, threaded fixture studs with nuts and washers.

2.04 LAVATORIES (LAV), ADAAG COMPLIANT

- A. Manufacturers:
 - 1. Sloan Valve Company; Model SS-3003.
 - 2. American Standard, Inc.
 - 3. Zurn Industries, LLC.
- B. Wall-Hung Basin:
 - 1. Vitreous China: ASME A112.19.2; white, rectangular basin with splash lip, front overflow, and carrier. Size 20 by 18 inches with 4-inch centerset spacing.
 - 2. Carrier:
 - a. ASME A112.6.1M; cast iron and steel frame with tubular legs, lugs for floor and wall attachment, threaded studs for fixture hanger, bearing plate and studs.
- C. Supply Faucet:
 - 1. Deck Mounted Faucet Manufacturers:
 - a. Sloan Valve Company; Model EBF-650.
 - b. T&S Brass.
 - c. Chicago Faucet
 - d. Zurn Industries, LLC.
 - 2. ASME A112.18.1; chrome plated combination supply fitting with open grid strainer, water economy aerator with maximum flow of 0.5 gpm, sensor.
 - 3. Sensor Operated Faucet:
 - a. Cast brass, chrome plated, deck mounted with sensor located on neck of spout.
 - b. Spout Style: Standard.
 - c. Power Supply:
 - 1) Wireless:
 - a) Battery: Replaceable alkaline or lithium type with 200,000 cycles, minimum.
 - b) Mini-Turbine: Sensor-operated hydro-powered micro-turbine that charges battery and powers mechanism using water flow energy.
 - c) Low Battery Warning: Provide red or yellow colored indicator to light periodically at 30 days of remaining capacity and continuously 2 weeks prior to get fully discharged.
 - d. Mixing Valve: External lever operated.
 - e. Water Supply: 3/8 inch compression connections.
 - f. Aerator: Vandal resistant, 0.5 gpm, laminar flow device.
 - g. Automatic Shut-off: 30 seconds.
 - h. Sensor Range: Factory set at 4" 5".
 - i. Finish: Polished chrome.
- D. Thermostatic Mixing Valve:
 - 1. ASSE 1070 listed with combination stop, strainer, and check valves, and flexible stainless steel connectors.
- E. Lavatory Carrier:
 - 1. ASME A112.6.1M; cast iron and steel frame with tubular legs, lugs for floor and wall attachment, threaded studs for fixture hanger, bearing plate and studs.

- F. Accessories:
 - 1. Offset waste with perforated open strainer.
 - 2. Wheel handle stops.
 - 3. Flexible supplies.
 - 4. Under Lavatory pipe insulation.
 - a. Manufacturer:
 - 1) Plumberex.
 - 2) Brocar.
 - 3) Truebro.
 - 4) Dearborn.
 - 5. Insulation: Fully molded closed cell vinyl or ethylene vinyl acetate foam, fit to lavatory P-trap, tailpiece and angle valve stop assemblies. Vinyl shall be antimicrobial with UV inhibitors and utilize reusable fasteners.

2.05 SINKS (SK), ADAAG COMPLIANT

- A. Manufacturers:
 - 1. Elkay; Model LRAD252160.
 - 2. Just.
 - 3. Substitutions: See Section 01 60 00 Product Requirements.
- B. Single Compartment Bowl
 - 1. ASME A112.19.3; 25 by 21 by 6 inch outside dimensions 18 gauge, Type 304 stainless steel, self rimming and undercoated, with ledge back drilled for trim.
 - 2. Drain: 3-1/2 inch crumb cup and tailpiece.
- C. Faucets:
 - 1. Manufacturers:
 - a. T&S Brass.
 - b. Chicago Faucet; Model 1100-369ABCP.
 - c. Zurn.
 - 2. Two-Handle Faucet:
 - a. Type: 8" deck-mount with chrome plated brass body, 8" swing nozzle with 1.5 gpm stream regulator, compression spindles, lever handles, removable brass seats and chrome plated escutcheon.
 - b. ASME A112.18.1, ADA Standards, and NSF 61 compliant assembly.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify that walls and floor finishes are prepared and ready for installation of fixtures.
- B. Confirm that millwork is constructed with adequate provision for the installation of counter top lavatories and sinks.

3.02 PREPARATION

A. Rough-in fixture piping connections in accordance with minimum sizes indicated in fixture rough-in schedule for particular fixtures.

3.03 INSTALLATION

- A. Install each fixture with trap, easily removable for servicing and cleaning.
- B. Install components level and plumb.

3.04 ADJUSTING

A. Adjust stops or valves for intended water flow rate to fixtures without splashing, noise, or overflow.

3.05 CLEANING

A. Clean plumbing fixtures and equipment.

3.06 PROTECTION

- A. Protect installed products from damage due to subsequent construction operations.
- B. Do not permit use of fixtures by construction personnel.
- C. Repair or replace damaged products before Date of Substantial Completion.

SECTION 23 05 93 TESTING, ADJUSTING, AND BALANCING FOR HVAC

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Testing, adjustment, and balancing of air systems.
- B. Measurement of final operating condition of HVAC systems.

1.02 REFERENCE STANDARDS

- A. AABC MN-1 AABC National Standards for Total System Balance; Associated Air Balance Council; 2002.
- B. ASHRAE Std 111 Measurement, Testing, Adjusting, and Balancing of Building HVAC Systems; 2008.
- C. NEBB (TAB) Procedural Standard for Testing Adjusting and Balancing of Environmental Systems; 2019.
- D. SMACNA (TAB) HVAC Systems Testing, Adjusting and Balancing; 2002.

1.03 SUBMITTALS

- A. Final Report: Indicate deficiencies in systems that would prevent proper testing, adjusting, and balancing of systems and equipment to achieve specified performance.
 - 1. Revise TAB plan to reflect actual procedures and submit as part of final report.
 - 2. Submit draft copies of report for review prior to final acceptance of Project. Provide final copies for Architect/Engineer and for inclusion in operating and maintenance manuals.
 - 3. Include actual instrument list, with manufacturer name, serial number, and date of calibration.
 - 4. Form of Test Reports: Where the TAB standard being followed recommends a report format use that; otherwise, follow ASHRAE Std 111.
 - 5. Units of Measure: Report data in both I-P (inch-pound) and SI (metric) units.
 - 6. Include the following on the title page of each report:
 - a. Name of Testing, Adjusting, and Balancing Agency.
 - b. Address of Testing, Adjusting, and Balancing Agency.
 - c. Telephone number of Testing, Adjusting, and Balancing Agency.
 - d. Project name.
 - e. Project location.
 - f. Project Engineer.
 - g. Report date.

PART 2 PRODUCTS - NOT USED

PART 3 EXECUTION

3.01 GENERAL REQUIREMENTS

- A. Perform total system balance in accordance with one of the following:
 - 1. AABC MN-1, AABC National Standards for Total System Balance.
 - 2. ASHRAE Std 111, Practices for Measurement, Testing, Adjusting and Balancing of Building Heating, Ventilation, Air-Conditioning, and Refrigeration Systems.

- 3. NEBB Procedural Standards for Testing Adjusting Balancing of Environmental Systems.
- 4. SMACNA (TAB).
- B. Begin work after completion of systems to be tested, adjusted, or balanced and complete work prior to Substantial Completion of the project.
- C. Where HVAC systems and/or components interface with life safety systems, including fire and smoke detection, alarm, and control, coordinate scheduling and testing and inspection procedures with the authorities having jurisdiction.
- D. TAB Agency Qualifications:
 - 1. Company specializing in the testing, adjusting, and balancing of systems specified in this section.
 - 2. Certified by one of the following:
 - a. AABC, Associated Air Balance Council: www.aabchq.com; upon completion submit AABC National Performance Guaranty.
 - b. NEBB, National Environmental Balancing Bureau: www.nebb.org/#sle.
 - c. TABB, The Testing, Adjusting, and Balancing Bureau of National Energy Management Institute: www.tabbcertified.org/#sle.
- E. TAB Supervisor Qualifications: Certified by same organization as TAB agency.

3.02 EXAMINATION

- A. Verify that systems are complete and operable before commencing work. Ensure the following conditions:
 - 1. Systems are started and operating in a safe and normal condition.
 - 2. Temperature control systems are installed complete and operable.
 - 3. Duct systems are clean of debris.
 - 4. Access doors are closed and duct end caps are in place.
 - 5. Air outlets are installed and connected.
 - 6. Duct system leakage is minimized.

3.03 ADJUSTMENT TOLERANCES

A. Air Outlets and Inlets: Adjust total to within plus 10 percent and minus 5 percent of design to space. Adjust outlets and inlets in space to within plus or minus 10 percent of design.

3.04 RECORDING AND ADJUSTING

- A. Ensure recorded data represents actual measured or observed conditions.
- B. Permanently mark settings of valves, dampers, and other adjustment devices allowing settings to be restored. Set and lock memory stops.
- C. After adjustment, take measurements to verify balance has not been disrupted or that such disruption has been rectified.
- D. Leave systems in proper working order, replacing belt guards, closing access doors, closing doors to electrical switch boxes, and restoring thermostats to specified settings.

3.05 AIR SYSTEM PROCEDURE

- A. Adjust air handling and distribution systems to provide required or design supply, return, and exhaust air quantities at site altitude.
- B. Measure air quantities at air inlets and outlets.
- C. Adjust distribution system to obtain uniform space temperatures free from objectionable drafts and noise.
- D. Use volume control devices to regulate air quantities only to extend that adjustments do not create objectionable air motion or sound levels. Effect volume control by duct internal devices such as dampers and splitters.

3.06 SCOPE

- A. Test, adjust, and balance the following:
 - 1. Air Terminal Units.
 - 2. Air Inlets and Outlets

SECTION 23 07 13 DUCT INSULATION

PART 1 GENERAL

1.01 SECTION INCLUDES

A. Duct insulation.

1.02 REFERENCE STANDARDS

- A. ASTM C553 Standard Specification for Mineral Fiber Blanket Thermal Insulation for Commercial and Industrial Applications; 2013 (Reapproved 2019).
- B. ASTM E84 Standard Test Method for Surface Burning Characteristics of Building Materials; 2023d.
- C. ASTM E96/E96M Standard Test Methods for Gravimetric Determination of Water Vapor Transmission Rate of Materials; 2023.
- D. UL 723 Standard for Test for Surface Burning Characteristics of Building Materials; Current Edition, Including All Revisions.

1.03 QUALITY ASSURANCE

A. Applicator Qualifications: Company specializing in performing the type of work specified in this section, with minimum three years of experience and approved by manufacturer.

1.04 DELIVERY, STORAGE, AND HANDLING

- A. Accept materials on site in original factory packaging, labelled with manufacturer's identification, including product density and thickness.
- B. Protect insulation from weather and construction traffic, dirt, water, chemical, and mechanical damage, by storing in original wrapping.

1.05 FIELD CONDITIONS

- A. Maintain ambient temperatures and conditions required by manufacturers of adhesives, mastics, and insulation cements.
- B. Maintain temperature during and after installation for minimum period of 24 hours.

PART 2 PRODUCTS

2.01 REGULATORY REQUIREMENTS

A. Surface Burning Characteristics: Flame spread index/Smoke developed index of 25/50, maximum, when tested in accordance with ASTM E84 or ASTM E84.

2.02 GLASS FIBER, FLEXIBLE

- A. Manufacturers:
 - 1. Knauf Fiber Glass.
 - 2. Johns Manville Corporation.
 - 3. Owens Corning Corp.

- 4. CertainTeed Corporation.
- B. Insulation: ASTM C553; flexible, noncombustible blanket.
 - 1. 'K' value: 0.25 at 75 degrees F, when tested in accordance with ASTM C518.
 - 2. Maximum Service Temperature: 850 degrees F.
 - 3. Maximum Water Vapor Absorption: 5.0 percent by weight.
- C. Vapor Barrier Jacket:
 - 1. Kraft paper with glass fiber yarn and bonded to aluminized film.
 - 2. Moisture Vapor Permeability: 0.04 perm inch 0.04 perm inch, when tested in accordance with ASTM E96/E96M.
 - 3. Secure with pressure sensitive tape.
- D. Vapor Barrier Tape:
 - 1. Kraft paper reinforced with glass fiber yarn and bonded to aluminized film, with pressure sensitive rubber based adhesive.
- E. Tie Wire: Annealed steel, 16 gage, 0.0508 inch diameter.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify that ducts have been tested before applying insulation materials.
- B. Verify that surfaces are clean, foreign material removed, and dry.

3.02 INSTALLATION

- A. Install in accordance with manufacturer's instructions.
- B. Install in accordance with NAIMA National Insulation Standards.
- C. Insulated ducts conveying air below ambient temperature:
 - 1. Provide insulation with vapor barrier jackets.
 - 2. Finish with tape and vapor barrier jacket.
 - 3. Continue insulation through walls, sleeves, hangers, and other duct penetrations.
 - 4. Insulate entire system including fittings, joints, flanges, fire dampers, flexible connections, and expansion joints.
- D. Insulated ducts conveying air above ambient temperature:
 - 1. Insulate fittings and joints. Where service access is required, bevel and seal ends of insulation.
- E. External Duct Insulation Application:
 - 1. Secure insulation with vapor barrier with wires and seal jacket joints with vapor barrier adhesive or tape to match jacket.
 - 2. Secure insulation without vapor barrier with staples, tape, or wires.
 - 3. Install without sag on underside of duct. Use adhesive or mechanical fasteners where necessary to prevent sagging. Lift duct off trapeze hangers and insert spacers.
 - 4. Seal vapor barrier penetrations by mechanical fasteners with vapor barrier adhesive.
 - 5. Stop and point insulation around access doors and damper operators to allow operation without disturbing wrapping.

3.03 SCHEDULES

- A. Supply Ducts:1. Flexible Glass Fiber Duct Insulation: 2 inches thick.
- B. Return Ducts:
 - 1. Flexible Glass Fiber Duct Insulation: 2 inches thick.

SECTION 23 31 00 HVAC DUCTS AND CASINGS

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Metal ductwork.
- B. Nonmetal ductwork.

1.02 RELATED REQUIREMENTS

- A. Section 23 07 13 Duct Insulation: External insulation.
- B. Section 23 33 00 Air Duct Accessories.
- C. Section 23 37 00 Air Outlets and Inlets.

1.03 REFERENCE STANDARDS

- A. ASHRAE (FUND) ASHRAE Handbook Fundamentals; Most Recent Edition Cited by Referring Code or Reference Standard.
- B. ASTM A36/A36M Standard Specification for Carbon Structural Steel; 2019.
- C. ASTM A653/A653M Standard Specification for Steel Sheet, Zinc-Coated (Galvanized) or Zinc-Iron Alloy-Coated (Galvannealed) by the Hot-Dip Process; 2023.
- D. ASTM E84 Standard Test Method for Surface Burning Characteristics of Building Materials; 2023d.
- E. NFPA 90A Standard for the Installation of Air-Conditioning and Ventilating Systems; 2018.
- F. SMACNA (DCS) HVAC Duct Construction Standards Metal and Flexible; 2020.

1.04 REGULATORY REQUIREMENTS

A. Construct ductwork to NFPA 90A standards.

1.05 FIELD CONDITIONS

- A. Do not install duct sealants when temperatures are less than those recommended by sealant manufacturers.
- B. Maintain temperatures within acceptable range during and after installation of duct sealants.

PART 2 PRODUCTS

2.01 MATERIALS

- A. Galvanized Steel for Ducts: Hot-dipped galvanized steel sheet, ASTM A653/A653M FS Type B, with G90/Z275 coating.
- B. Joint Sealers and Sealants: Non-hardening, water resistant, mildew and mold resistant.
 - 1. Type: Heavy mastic or liquid used alone or with tape, suitable for joint configuration and compatible with substrates, and recommended by manufacturer for pressure class of ducts.
 - 2. VOC Content: Not more than 250 g/L, excluding water.

- 3. Surface Burning Characteristics: Flame spread index of zero and smoke developed index of zero, when tested in accordance with ASTM E84.
- C. Hanger Rod: ASTM A36/A36M; steel, galvanized; threaded both ends, threaded one end, or continuously threaded.
- D. Hanger Cable & Fastener:

1. Cable: Galvanized high tensile steel cable to EN12385. Standard lengths from 5 ft - 30 ft.

	<u>No. 1</u>	<u>No. 2</u>	No. 3 <u>(Standard)</u>	No. 3 <u>(Trapeze)</u>	<u>No. 4</u>	<u>No. 5</u>
Cable Dia. (in.)	1/16	5/64	1/8	1/8	3/16	1/4
Strand configuration	7x7	7x7	7x7	1x19	7x19	7x19
Min. breaking load (lbs)	125	500	1,000	600	2,475	3,575
Max. safe working load (lbs)	25	100	200	200	495	715
Tensile strength (lbs/sq. in.)	256,700	256,700	256,700	256,700	256,700	256,700

2. Fastener:

- a. Housing: Type ZA2 Zinc.
- b. Wedge: Sintered steel hardened to minimum 56 Rockwell C.
- c. Spring: Stainless steel, Type 302.
- d. End Cap: No. 1-4 = UV stabilized homopolymer polypropylene; No. 5 = Type ZA2 zinc.
- e. Screws: No. 5 only = Stainless steel, Type 304
- 3. Load Rating: All products 5:1 safety factor.
- 4. <u>Size</u> <u>Maximum Safe Working Load</u>
 - No. 1 25 lbs
 - No. 2 100 lbs
 - No. 3 200 lbs
 - No. 4 495 lbs
 - No. 5 715 lbs
- 5. Manufacturers:
 - a. Gripple Inc.: Air Flow Company, Inc., Tom Class 630-400-3344.
 - b. Substitutions: See Section 01 60 00 Product Requirements.
- E. Ducts: Galvanized steel, unless otherwise indicated.
- F. Low Pressure Supply (System with Cooling Coils): 2 inch w.g. pressure class, galvanized steel.
- G. Medium and High Pressure Supply: 4 inch w.g. pressure class, galvanized steel.
- H. General Exhaust: 1 inch w.g. pressure class, galvanized steel.
- I. Ductmate or WDCI duct connection systems are acceptable. Ductwork constructed using these systems shall refer to manufacturer's recommendations for sheet metal gage intermediate and joint

reinforcement.

2.02 DUCTWORK FABRICATION

- A. Fabricate and support in accordance with SMACNA (DCS) and as indicated.
- B. No variation of duct configuration or size permitted except by written permission. Size round duct installed in place of rectangular ducts in accordance with ASHRAE Handbook Fundamentals.
- C. Provide duct material, gages, reinforcing, and sealing for operating pressures indicated.
- D. Construct T's, bends, and elbows with radius of not less than 1-1/2 times width of duct on centerline. Where not possible and where rectangular elbows must be used, provide air foil turning vanes of perforated metal with glass fiber insulation.
- E. Increase duct sizes gradually, not exceeding 15 degrees divergence wherever possible; maximum 30 degrees divergence upstream of equipment and 45 degrees convergence downstream.
- F. Fabricate continuously welded round and oval duct fittings in accordance with SMACNA (DCS).
- G. Where ducts are connected to exterior wall louvers and duct outlet is smaller than louver frame, provide blank-out panels sealing louver area around duct. Use same material as duct, painted black on exterior side; seal to louver frame and duct.

2.03 MANUFACTURED DUCTWORK AND FITTINGS

- A. Flexible Ducts: Multiple layers of aluminum laminate supported by helically wound spring steel wire.
 - 1. Insulation: Fiberglass insulation with aluminized vapor barrier film.
 - 2. Pressure Rating: 10 inches WG positive and 1.0 inches WG negative.
 - 3. Maximum Velocity: 4000 fpm.
 - 4. Temperature Range: Minus 20 degrees F to 210 degrees F.
- B. Transverse Duct Connection System: SMACNA "E" rated rigidly class connection, interlocking angle and duct edge connection system with sealant, gasket, cleats, and corner clips in accordance with SMACNA (DCS).

PART 3 EXECUTION

3.01 INSTALLATION

- A. Install, support, and seal ducts in accordance with SMACNA (DCS).
- B. Install in accordance with manufacturer's instructions.
- C. During construction provide temporary closures of metal or taped polyethylene on open ductwork to prevent construction dust from entering ductwork system.
- D. Duct sizes indicated are inside clear dimensions. For lined ducts, maintain sizes inside lining.
- E. Duct sizes indicated shall be of sizes indicated. However, necessary changes in shape offsets or crossovers to clear piping, lighting, building construction obstructions, etc. shall be made without additional cost.
- F. Locate ducts with sufficient space around equipment to allow normal operating and maintenance activities.
- G. Use double nuts and lock washers on threaded rod supports.
- H. Connect diffusers or light troffer boots to low pressure ducts directly or with 5 feet maximum length of flexible duct held in place with strap or clamp.

SECTION 23 33 00 AIR DUCT ACCESSORIES

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Volume control dampers.
- B. Ductwork accessories.

1.02 RELATED REQUIREMENTS

A. Section 23 31 00 - HVAC Ducts and Casings.

1.03 REFERENCE STANDARDS

- A. NFPA 90A Standard for the Installation of Air-Conditioning and Ventilating Systems; 2018.
- B. SMACNA (DCS) HVAC Duct Construction Standards Metal and Flexible; 2020.

1.04 DELIVERY, STORAGE, AND HANDLING

A. Protect dampers from damage to operating linkages and blades.

PART 2 PRODUCTS

2.01 FLEXIBLE DUCTS FORMING BRACE

- A. Manufacturers:
 - 1. Titus; Model FlexRight.
 - 2. Substitutions: See Section 01 60 00 Product Requirements.
- B. UL Listed. Radius forming brace to hold flexible duct into a 90 degree elbow. Fits flexible duct sizes and diffuser inlets from 4 inches to 16 inches in diameter. Manufactured from copolymer polyproylene.

2.02 VOLUME CONTROL DAMPERS

- A. Manufacturers:
 - 1. Ruskin Company.
 - 2. Greenheck.
 - 3. Air Balance.
- B. Fabricate in accordance with SMACNA (DCS) and as indicated.
- C. Single Blade Dampers: Fabricate for duct sizes up to 6 by 30 inch.
 - 1. Fabricate for duct sizes up to 6 by 30 inch.
 - 2. Blade: 24 gage, 0.0239 inch, minimum.
- D. End Bearings: Except in round ducts 12 inches and smaller, provide end bearings. On multiple blade dampers, provide oil-impregnated nylon, thermoplastic elastomer, or sintered bronze bearings.
- E. Quadrants:
 - 1. Provide locking, indicating quadrant regulators on single and multi-blade dampers.

2. On insulated ducts mount quadrant regulators on stand-off mounting brackets, bases, or adapters.

2.03 MISCELLANEOUS PRODUCTS

- A. Duct Opening Closure Film: Mold-resistant, self-adhesive film to keep debris out of ducts during construction.
 - 1. Thickness: 2 mils.
 - 2. High tack water based adhesive.
 - 3. UV stable light blue color.
 - 4. Elongation Before Break: 325 percent, minimum.

PART 3 EXECUTION

3.01 INSTALLATION

- A. Install accessories in accordance with manufacturer's instructions, NFPA 90A, and follow SMACNA (DCS). Refer to Section 23 31 00 for duct construction and pressure class.
- B. Provide balancing dampers at points on supply, return, and exhaust systems where branches are taken from larger ducts as required for air balancing. Install minimum 2 duct widths from duct take-off.
- C. Provide balancing dampers on duct take-off to diffusers, grilles, and registers, regardless of whether dampers are specified as part of the diffuser, grille, or register assembly.

SECTION 23 37 00 AIR OUTLETS AND INLETS

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Diffusers.
- B. Registers/grilles.
 - 1. Ceiling-mounted, perforated return grilles.
 - 2. Ceiling-mounted, exhaust and return register/grilles.

1.02 RELATED REQUIREMENTS

1.03 REFERENCE STANDARDS

A. ASHRAE Std 70 - Method of Testing the Performance of Air Outlets and Inlets; 2006 (Reaffirmed 2011).

1.04 SUBMITTALS

- A. See Section 01 30 00 Administrative Requirements for submittal procedures.
- B. Product Data: Provide data for equipment required for this project. Review outlets and inlets as to size, finish, and type of mounting prior to submission. Submit schedule of outlets and inlets showing type, size, location, application, and noise level.

1.05 QUALITY ASSURANCE

- A. Test and rate air outlet and inlet performance in accordance with ASHRAE Std 70.
- B. Manufacturer Qualifications: Company specializing in manufacturing the type of products specified in this section, with minimum three years of documented experience.

PART 2 PRODUCTS

2.01 MANUFACTURERS

- A. Price Industries.
- B. Titus.
- C. Tuttle & Bailey.
- D. Nailor.

2.02 SQUARE PLAQUE FACE CEILING DIFFUSERS

- A. Manufacturers:
 - 1. Titus; Model OMNI.
 - 2. Price Industries; Model SPD.
 - 3. Nailor Industries; Model UNI.
- B. Type: Provide square diffuser with steel backpan and inner placque assembly with discharge air in 360 degree pattern. The diffuser back pan shall be externally insulated with a molded heavy duty foil/scrim vapor barrier with an R-value = 6. Insulation shall meet the requirements of UL 181 and

NFPA 90A..

- C. Connections: Round.
- D. Frame: Provide inverted T-bar type.
- E. Fabrication: Steel with baked enamel finish.
- F. Color: As selected by Architect/Engineer from manufacturer's standard range.
- G. Accessories: Provide radial opposed blade volume control damper; removable inner plaque assembly with damper adjustable from diffuser face.

2.03 PERFORATED FACE CEILING RETURN REGISTERS/GRILLES

- A. Type: Perforated face.
- B. Frame: Inverted T-bar type.
- C. Fabrication: Steel with steel frame and baked enamel white finish.
- D. Color: As selected by Architect with manufacturer's standard range.
- E. Titus Model PAR.

2.04 CEILING EXHAUST AND RETURN REGISTERS/GRILLES

- A. Type: Streamlined blades, 3/4 inch minimum depth, 3/4 inch maximum spacing, with spring or other device to set blades, horizontal face.
- B. Frame: 1-1/4 inch margin with countersunk screw mounting.
- C. Fabrication: Steel frames and blades, with factory baked enamel finish.
- D. Color: White.
- E. Damper: Integral, gang-operated, opposed blade type with removable key operator, operable from face.
- F. Titus Model 350RL.

PART 3 EXECUTION

3.01 INSTALLATION

- A. Install in accordance with manufacturer's instructions.
- B. Check location of outlets and inlets and make necessary adjustments in position to conform with architectural features, symmetry, and lighting arrangement.
- C. Install diffusers to ductwork with air tight connection.
- D. Provide balancing dampers on duct take-off to diffusers, and grilles and registers, despite whether dampers are specified as part of the diffuser, or grille and register assembly.

SECTION 23 82 00 CONVECTION HEATING AND COOLING UNITS

PART 1 GENERAL

1.01 SECTION INCLUDES

A. Electric wall heaters.

1.02 RELATED REQUIREMENTS

A. Section 26 05 83 - Wiring Connections: Electrical characteristics and wiring connections. Installation of room thermostats. Electrical supply to units.

1.03 REFERENCE STANDARDS

1.04 SUBMITTALS

- A. See Section 01 30 00 Administrative Requirements for submittal procedures.
- B. Product Data: Provide typical catalog of information including arrangements.

1.05 QUALITY ASSURANCE

- A. Manufacturer Qualifications: Company specializing in manufacturing the Products specified in this section with minimum three years documented experience.
- B. Products Requiring Electrical Connection: Listed and classified by Underwriters Laboratories Inc. as suitable for the purpose specified and indicated.

PART 2 PRODUCTS

2.01 ELECTRIC WALL HEATERS

- A. Manufacturers:
 - 1. Brasch..
 - 2. INDEECO (Industrial Engineering and Equipment Company).
 - 3. Marley Engineered Products; Model CWH1208DSF.
- B. Heating Element: Sealed tubular type with large parallel steel fins for quick heat transfer.
- C. Cabinet: 18 gauge steel housing and louvered grille with an extruded aluminum frame.
- D. Fan: Vane axial blower with down flow air discharge.
- E. Motor: Permanently lubricated, 4-pole motor.
- F. Control: Built-in tamperproof thermostat calibrated to provide a range of 55 degrees F to 85 degrees F, fan delay switch, thermal overload cut-off, and manual disconnect switch.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify that surfaces are suitable for installation.
- B. Verify that field measurements are as indicated on drawings.

3.02 INSTALLATION

- A. Install in accordance with manufacturer's recommendations.
- B. Install equipment exposed to finished areas after walls and ceilings are finished and painted.
- C. Do not damage equipment or finishes.
- D. Units with Electric Heating Elements:
 - 1. Install as indicated including electrical devices furnished by manufacturer but not factory installed.
 - 2. Install wiring in accordance with the manufacturer's wiring diagram submittal and Section 26 05 83.

SECTION 26 05 00 BASIC ELECTRICAL REQUIREMENTS

PART 1 GENERAL

1.01 RELATED DOCUMENTS

A. Drawings and general provisions of Contract, including General and Supplementary Conditions and Division 1 Specification Sections, apply to this Section.

1.02 SECTION INCLUDES

- A. Basic Electrical Requirements and materials specifically applicable to Division 26 Sections, in addition to Division 1 General Requirements. Section includes:
 - 1. Electrical Identification.
 - 2. Conductors.
 - 3. Raceways and Boxes.
 - 4. Supporting Devices.

1.03 REGULATORY REQUIREMENTS

- A. Conform to NFPA 70 National Electrical Code, 2014 edition with amendments as adopted by the City of Aurora, IL.
- B. Conform to building codes as adopted by the City of Aurora, IL.
- C. Install electrical Work in accordance with the NECA Standard of Installation.

1.04 DELIVERY, STORAGE AND HANDLING

- A. Store and protect all materials as specified under the provisions of Section 01 60 00 and as specified herein.
- B. Deliver products to the project properly identified with names, model numbers, types, grades, compliance labels, and other information needed for identification.
- C. Ship products to the job site in their original packaging. Receive and store products in a suitable manner to prevent damage or deterioration. Keep equipment upright at all times.
- D. Investigate the spaces through which equipment must pass to reach its final destination. Coordinate with the manufacturer to arrange delivery at the proper stage of construction and to provide shipping splits where necessary.

1.05 PROJECT/SITE CONDITIONS

- A. Install work in locations shown on Drawings, unless prevented by Project conditions. Drawings have omitted certain branch circuitry in areas for ease of reading. All branch circuitry is to be provided by Contractor.
- B. Prepare drawings showing proposed rearrangement of Work to meet Project conditions, including changes to Work specified in other Sections. Obtain permission from Architect/Engineer before proceeding as specified under modification procedures.

1.06 QUALITY ASSURANCE

A. Provide Work as required for a complete and operational electrical installation.

- B. All products shall be designed, manufactured, and tested in accordance with industry standards. Standards, organizations, and their abbreviations as used hereafter, include the following:
 - 1. American National Standards Institute, Inc (ANSI).
 - 2. American Society for Testing and Materials (ASTM).
 - 3. National Electrical Manufacturers Association (NEMA).
 - 4. Underwriters Laboratories, Inc. (UL).
- C. Install all Work in accordance with the NECA Standard of Installation.

1.07 SUBMITTALS

A. Submit all requested items in Division 26 Sections under provisions of Section 01 30 00.

1.08 SUBSTITUTIONS

A. Substitutions will be considered only as allowed within the provisions of Section 01 60 00.

1.09 PROJECT RECORD DOCUMENTS

A. Cooperate and assist in the preparation of project record documents under the provisions of Section 01 78 00.

1.10 TEMPORARY UTILITIES

A. Arrange with utility company and provide temporary lighting and power necessary for building construction and temporary structures.

1.11 PROJECT MANAGEMENT AND COORDINATION

A. Proper project management and coordination is critical for a successful project. Manage and coordinate the Work with all other trades in accordance with Section 01 30 00 requirements. Reliance on the Drawings and Specifications only for exact project requirements is insufficient for proper coordination.

PART 2 PRODUCTS

2.01 WIRING METHODS

- A. All locations: Building wire in raceway.
- B. Use no wire smaller than 12 AWG for power and lighting circuits, and no smaller than 14 AWG for control wiring.
 - Use 10 AWG conductor for 20 ampere, 120 volt branch circuit home runs longer than 100 feet. Use minimum #10 AWG conductor wire in all the following locations:
 a. All emergency lighting and exit branch circuits.

2.02 WIRE AND CABLE

- A. Manufacturers:
 - 1. Okonite.
 - 2. Southwire.
 - 3. Collyer.
- B. Building Wire:

- 1. Feeders and Branch Circuits Larger Than 6 AWG: Copper, stranded conductor, 600 volt insulation.
- 2. Feeders and Branch Circuits 6 AWG and Smaller: Copper conductor, 600 volt insulation. 6 and 8 AWG, stranded conductor; smaller than 8 AWG, stranded conductor (solid for device terminations).
- 3. Control Circuits: Copper, stranded conductor, 600 volt insulation.
- 4. Use 10 AWG conductors for 20 ampere, 120 volt branch circuits longer than 75 feet.
- 5. Use 10 AWG conductors for 20 ampere, 277 volt branch circuits longer than 200 feet.
- 6. Use conductor not smaller than 12 AWG for power and lighting circuits.
- 7. Use conductor not smaller than 16 AWG for control circuits.
- C. Locations:
 - 1. Concealed Dry Interior Locations: Use only building wire with Type THHN insulation in raceway.
 - 2. Exposed Dry Interior Locations: Use only building wire with Type THHN insulation in raceway.
 - 3. Above Accessible Ceilings: Use only building wire with Type THHN insulation in raceway.
 - 4. Wet or Damp Interior Locations: Use only building wire with Type THWN insulation in raceway.
 - 5. Exterior Locations: Use only building wire with Type XHHW insulation in raceway.

2.03 RACEWAY REQUIREMENTS

- A. Use only specified raceway in the following locations:
 - 1. Branch Circuits and Feeders:
 - a. Concealed Dry Interior Locations: Electrical metallic tubing.
 - b. Exposed Dry Interior Finished Locations: Electrical metallic tubing.
 - c. Exposed Dry Interior Unfinished Locations: Electrical metallic tubing.
 - d. All other locations: Galvanized Rigid Metallic Conduit.
- B. Size raceways for conductor type installed.
 - 1. Minimum Size Conduit Homerun to Panelboard: 3/4-inch.

2.04 METALLIC CONDUIT AND FITTINGS

- A. Conduit:
 - 1. Rigid Steel Conduit: ANSI C80.1.
 - 2. Electrical metallic tubing: ANSI C80.3.
 - 3. Flexible Conduit: UL 1, zinc-coated steel.
 - a. Liquidtight Flexible Conduit: UL360. Fittings shall be specifically approved for use with this raceway.
- B. Conduit Fittings:
 - 1. Metal Fittings and Conduit Bodies: NEMA FB 1.
 - a. EMT fittings: Use set-screw indentor-type fittings.

2.05 CONDUIT HANGERS

- A. Manufacturers:
 - 1. Minerrallac Electric Company.
 - 2. Substitutions: Or Approved Equal.
- B. Description:
 - 1. Standard conduit hanger, zinc-plated steel with bolts.

2. Threaded rod and hardware: Plated finish, size and length as required for loading and conditions.

2.06 BEAM CLAMPS

- A. Manufacturers:
 - 1. Appleton.
 - 2. Midwest.
 - 3. Raco.
- B. Description: Malleable beam clamp, zinc plated steel.

2.07 ELECTRICAL BOXES

- A. Manufacturers:
 - 1. Raco.
 - 2. Steel City.
 - 3. Appleton.
 - 4. Substitutions: Or Approved Equal.
- B. Sheet Metal Outlet Boxes: ANSI/NEMA OS 1, galvanized steel, suitable for installation in masonry:
- C. Equipment Support Boxes: Rated for weight of equipment supported; include 2 inch male fixture studs where required.
- D. Wet Location Outlet Boxes: Cast aluminum: Cast alloy, deep type, gasket cover, threaded hubs.

2.08 PENETRATION SEALANTS

- A. Fire-rated assemblies: Provide firestopping of all penetrations made by Work under this Contract in accordance with provisions of Section 07 84 00 requirements.
- B. Thermal and Moisture Protection: Provide thermal and moisture protection made by Work under this Contract of all exterior wall, floor and roof penetrations in accordance with Division 7 requirements.

2.09 NAMEPLATES AND LABELS

- A. Nameplates: Engraved three-layer laminated plastic, black letters on white background.
- B. Locations:
 - 1. Each electrical distribution and control equipment enclosure.
- C. Letter Size:
 - 1. Use 1/8 inch letters for identifying individual equipment and loads.
 - 2. Use 1/4 inch letters for identifying grouped equipment and loads.
- D. Labels: Embossed adhesive tape, with 3/16 inch white letters on a black background. Use only for identification of individual wall switches and receptacles and control device stations.

2.10 WIRE AND CABLE MARKERS

- A. Manufacturers:
 - 1. Brady Model PCPS.
 - 2. Panduit Model PCM.
 - 3. T & B Model WM.

- B. Description: Cloth type wire markers.
- C. Locations: Each conductor at panelboard gutters, pull boxes, and each load connection.
- D. Legend:
 - 1. Power and Lighting Circuits: Branch circuit or feeder number indicated on drawings.

2.11 CONDUIT MARKERS

- A. Location: Furnish markers for each conduit longer than 6 feet.
- B. Spacing: 20 feet on center.
- C. Color:
 - 1. 480 Volt System: Orange
 - 2. 208 Volt System: Black
 - 3. Fire Alarm System: Red.

PART 3 EXECUTION

3.01 EXAMINATION AND PREPARATION

- A. Verify that supporting surfaces are ready to receive work.
- B. Electrical boxes are shown on Drawings, in approximate locations, unless dimensioned.
 1. Obtain verification from Architect/Engineer for locations of outlets throughout prior to rough-in.
- C. Degrease and clean surfaces to receive wire markers.
- D. Verify that mechanical work which is likely to injure conductors has been completed.
- E. Completely and thoroughly swab raceway system before installing conductors.

3.02 APPLICATION

- A. Install nameplate and label parallel to equipment lines.
- B. Secure nameplate to equipment front using screws.
- C. Secure nameplates to inside surface of door on panelboard that is recessed in finished locations.
- D. Identify underground conduits using underground warning tape. Install one tape per trench at 3 inches below finished grade.
- E. Neatly train and secure wiring inside boxes, equipment, and panelboards.
- F. Use wire pulling lubricant for pulling 4 AWG and larger wires.
- G. Route wire and cable as required to meet project conditions.
 - 1. Wire and cable routing indicated is approximate unless dimensioned.
 - 2. Where wire and cable destination is indicated and routing is not shown, determine exact routing and lengths required.
- H. Pull all conductors into raceway at same time.
- I. Protect exposed cable from damage.
- J. Neatly train and lace wiring inside boxes, equipment and panelboards.

- K. Support cables above accessible ceilings to keep them from resting on ceiling tiles.
- L. Make splices, taps, and terminations to carry full ampacity of conductors without perceptible temperature rise.
- M. Use split bolt connectors for copper conductor splices and taps, 6 AWG and larger. Tape uninsulated conductors and connector with electrical tape to 150 percent of insulation rating of conductor.
- N. Provide anchors, fasteners, and supports in accordance with NECA "Standard of Installation".
- O. Do not fasten supports to pipes, ducts, mechanical equipment, and conduit.
- P. Do not use powder-actuated anchors.
- Q. Do not drill or cut structural members.
- R. Fabricate supports from structural steel or steel channel. Rigidly weld members or use hexagon head bolts to present neat appearance with adequate strength and rigidity. Use spring lock washers under all nuts.
- S. Install surface-mounted cabinets and panelboards with minimum of four anchors.
- T. In wet and damp locations use steel channel supports to stand cabinets and panelboards one inch off wall.
- U. Use sheet metal channel to bridge studs above and below cabinets and panelboards recessed in hollow partitions.
- V. Terminate spare conductors with electrical tape.
- W. Do not share neutral conductor on load side of dimmers.

SECTION 26 05 05 SELECTIVE DEMOLITION FOR ELECTRICAL

PART 1 GENERAL

1.01 SECTION INCLUDES

A. Electrical demolition.

PART 2 PRODUCTS

2.01 MATERIALS AND EQUIPMENT

A. Materials and equipment for patching and extending work: As specified in individual sections.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify field measurements and circuiting arrangements are as indicated.
- B. Verify that abandoned wiring and equipment serve only abandoned facilities.
- C. Demolition drawings are based on casual field observation.
- D. Report discrepancies to Architect/Engineer before disturbing existing installation.
- E. Beginning of demolition means installer accepts existing conditions.

3.02 PREPARATION

- A. Disconnect electrical systems in walls, floors, and ceilings to be removed.
- B. Provide temporary wiring and connections to maintain existing systems in service during construction. When work must be performed on energized equipment or circuits, use personnel experienced in such operations.
- C. Existing Electrical Service: Maintain existing system in service . Disable system only to make switchovers and connections. Minimize outage duration.
 - 1. Obtain permission from Owner at least 24 hours before partially or completely disabling system.
 - 2. Make temporary connections to maintain service in areas adjacent to work area.
- D. Existing Fire Alarm System: Maintain existing system in service. Disable system only to make switchovers and connections. Minimize outage duration.
 - 1. Notify Owner before partially or completely disabling system.
 - 2. Notify local fire service.
 - 3. Make notifications at least 24 hours in advance.

3.03 DEMOLITION AND EXTENSION OF EXISTING ELECTRICAL WORK

- A. Remove, relocate, and extend existing installations to accommodate new construction.
- B. Remove abandoned wiring to source of supply.
- C. Remove exposed abandoned conduit, including abandoned conduit above accessible ceiling finishes. Cut conduit flush with walls and floors, and patch surfaces.

- D. Disconnect abandoned outlets and remove devices. Remove abandoned outlets if conduit servicing them is abandoned and removed. Provide blank cover for abandoned outlets that are not removed.
- E. Disconnect and remove abandoned panelboards and distribution equipment.
- F. Disconnect and remove electrical devices and equipment serving utilization equipment that has been removed.
- G. Disconnect and remove abandoned luminaires. Remove brackets, stems, hangers, and other accessories.
- H. Repair adjacent construction and finishes damaged during demolition and extension work.
- I. Maintain access to existing electrical installations that remain active. Modify installation or provide access panel as appropriate.
- J. Extend existing installations using materials and methods compatible with existing electrical installations, or as specified.

3.04 CLEANING AND REPAIR

- A. Clean and repair existing materials and equipment that remain or that are to be reused.
- B. Panelboards: Clean exposed surfaces and check tightness of electrical connections. Replace damaged circuit breakers and provide closure plates for vacant positions. Provide typed circuit directory showing revised circuiting arrangement.

SECTION 26 05 83 WIRING CONNECTIONS

PART 1 GENERAL

1.01 SECTION INCLUDES

A. Electrical connections to equipment and devices not and integral part of the electrical distribution system.

1.02 REFERENCE STANDARDS

- A. NEMA WD 1 General Color Requirements for Wiring Devices; 1999 (Reaffirmed 2020).
- B. NEMA WD 6 Wiring Devices Dimensional Specifications; 2021.
- C. NFPA 70 National Electrical Code; Most Recent Edition Adopted by Authority Having Jurisdiction, Including All Applicable Amendments and Supplements.

1.03 ADMINISTRATIVE REQUIREMENTS

- A. Provide conduit rough-in and electrical connection to powered equipment and devices identified in the Project Manual and on the Drawings. Refer specifically, but not limited to, these Specification Sections for further information:
 - 1. Section 22 30 00 Plumbing Equipment.
 - 2. Section 23 82 00 Convection Heating and Cooling Units.
- B. Coordination: Determine connection locations and requirements for furniture, equipment and devices furnished or provided under other sections.
 - 1. Do not rely solely on the Drawings and Project Manual for execution of the Work of this Section.
 - 2. Obtain and review shop drawings, product data, manufacturer's wiring diagrams, and manufacturer's instructions.
 - 3. Include necessary field evaluation time to inspect connection requirements.
 - 4. Coordinate with other trades to determine exact rough-in requirements.

C. Sequencing:

- 1. Install rough-in of electrical connections before installation of furniture and equipment is required.
- 2. Make electrical connections before required start-up of equipment.

1.04 SUBMITTALS

- A. See Section 01 30 00 Administrative Requirements, for submittal procedures.
- B. Product Data: Provide wiring device manufacturer's catalog information showing dimensions, configurations, and construction.
- C. Manufacturer's Instructions: Indicate application conditions and limitations of use stipulated by product testing agency. Include instructions for storage, handling, protection, examination, preparation, and installation of product.

1.05 QUALITY ASSURANCE

- A. Comply with requirements of NFPA 70.
- B. Products: Listed, classified, and labeled as suitable for the purpose intended.

PART 2 PRODUCTS

2.01 MATERIALS

- A. Cords and Caps: NEMA WD 6; match receptacle configuration at outlet provided for equipment.
 - 1. Colors: Comply with NEMA WD 1.
 - 2. Cord Construction: NFPA 70, Type SO, multiconductor flexible cord with identified equipment grounding conductor, suitable for use in damp locations.
 - 3. Size: Suitable for connected load of equipment, length of cord, and rating of branch circuit overcurrent protection.
 - 4. Product: Carol.
 - 5. Substitutions: See Section 01 60 00 Product Requirements.
- B. Wiring Devices: As specified in Section 26 27 26.
- C. Flexible Conduit: As specified in Section 26 05 00.
- D. Wire and Cable: As specified in Section 26 05 00.
- E. Boxes: As specified in Section 26 05 00.

PART 3 EXECUTION

3.01 EXAMINATION

A. Verify that equipment is ready for electrical connection, wiring, and energization.

3.02 ELECTRICAL CONNECTIONS

- A. Make electrical connections in accordance with equipment manufacturer's instructions.
- B. Make conduit connections to equipment using flexible conduit. Use liquidtight flexible conduit with watertight connectors in damp or wet locations.
- C. Connect heat producing equipment using wire and cable with insulation suitable for temperatures encountered.
- D. Provide receptacle outlet to accommodate connection with attachment plug.
- E. Provide cord and cap where field-supplied attachment plug is required.
- F. Install suitable strain-relief clamps and fittings for cord connections at outlet boxes and equipment connection boxes.
- G. Install disconnect switches, controllers, control stations, and control devices to complete equipment wiring requirements.
- H. Install terminal block jumpers to complete equipment wiring requirements.
- I. Install interconnecting conduit and wiring between devices and equipment to complete equipment wiring requirements.

SECTION 26 24 16 PANELBOARDS

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Lighting and appliance panelboard.
- B. Overcurrent protective devices for panelboards.

1.02 REFERENCE STANDARDS

- A. FS W-C-375 Circuit Breakers, Molded Case; Branch Circuit and Service; 2013e, with Amendments (2022).
- B. NECA 1 Standard for Good Workmanship in Electrical Construction; 2015.
- C. NECA 407 Standard for Installing and Maintaining Panelboards; 2009.
- D. NEMA 250 Enclosures for Electrical Equipment (1000 Volts Maximum); 2014.
- E. NEMA PB 1 Panelboards; 2011.
- F. NEMA PB 1.1 General Instructions for Proper Installation, Operation and Maintenance of Panelboards Rated 1000 Volts or Less; 2023.
- G. UL 67 Panelboards; Current Edition, Including All Revisions.
- H. UL 489 Molded-Case Circuit Breakers, Molded-Case Switches and Circuit Breaker Enclosures; Current Edition, Including All Revisions.
- I. UL 943 Ground-Fault Circuit-Interrupters; Current Edition, Including All Revisions.

1.03 ADMINISTRATIVE REQUIREMENTS

- A. Coordination:
 - 1. Coordinate the work with other trades to avoid placement of ductwork, piping, equipment, or other potential obstructions within the dedicated equipment spaces and working clearances for electrical equipment required by NFPA 70.
 - 2. Coordinate arrangement of electrical equipment with the dimensions and clearance requirements of the actual equipment to be installed.
 - 3. Coordinate the work with other trades to provide walls suitable for installation of flush-mounted panelboards where indicated.
 - 4. Verify with manufacturer that conductor terminations are suitable for use with the conductors to be installed.
 - 5. Notify Architect/Engineer of any conflicts with or deviations from Contract Documents. Obtain direction before proceeding with work.

1.04 SUBMITTALS

- A. See Section 01 30 00 Administrative Requirements, for submittal procedures.
- B. Product Data: Provide manufacturer's standard catalog pages and data sheets for panelboards, enclosures, overcurrent protective devices, and other installed components and accessories.

- 1. Include characteristic trip curves for each type and rating of overcurrent protective device upon request.
- C. Shop Drawings: Indicate outline and support point dimensions, voltage, main bus ampacity, overcurrent protective device arrangement and sizes, short circuit current ratings, conduit entry locations, conductor terminal information, and installed features and accessories.
- D. Manufacturer's Installation Instructions: Indicate application conditions and limitations of use stipulated by product testing agency. Include instructions for storage, handling, protection, examination, preparation, and installation of product.
- E. Project Record Documents: Record actual installed locations of panelboards and actual installed circuiting arrangements.

1.05 QUALITY ASSURANCE

- A. Conform to requirements of NFPA 70.
- B. Manufacturer Qualifications: Company specializing in manufacturing the products specified in this section with minimum three years documented experience.

1.06 DELIVERY, STORAGE, AND HANDLING

- A. Receive, inspect, handle, and store panelboards in accordance with manufacturer's instructions and NECA 407.
- B. Store in a clean, dry space. Maintain factory wrapping or provide an additional heavy canvas or heavy plastic cover to protect units from dirt, water, construction debris, and traffic.
- C. Handle carefully in accordance with manufacturer's written instructions to avoid damage to panelboard internal components, enclosure, and finish.

PART 2 PRODUCTS

2.01 MANUFACTURERS

- A. Siemens Industry, Inc: www.usa.siemens.com.
- B. Eaton Corporation: www.eaton.com.
- C. General Electric Company: www.geindustrial.com.
- D. Schneider Electric; Square D Products: www.schneider-electric.us.
- E. Substitutions: See Section 01 60 00 Product Requirements.
- F. Source Limitations: Furnish panelboards and associated components produced by a single manufacturer and obtained from a single supplier.

2.02 PANELBOARDS - GENERAL REQUIREMENTS

- A. Provide products listed, classified, and labeled as suitable for the purpose intended.
- B. Unless otherwise indicated, provide products suitable for continuous operation under the following service conditions:
 - 1. Ambient Temperature:
 - a. Panelboards Containing Circuit Breakers: Between 23 degrees F and 104 degrees F.

- C. Short Circuit Current Rating:
 - 1. Provide panelboards with listed short circuit current rating as indicated on the drawings.
- D. Mains: Configure for top or bottom incoming feed as indicated or as required for the installation.
- E. Branch Overcurrent Protective Devices: Replaceable without disturbing adjacent devices.
- F. Bussing: Sized in accordance with UL 67 temperature rise requirements.
 - 1. Provide fully rated neutral bus unless otherwise indicated, with a suitable lug for each feeder or branch circuit requiring a neutral connection.
 - 2. Provide solidly bonded equipment ground bus in each panelboard, with a suitable lug for each feeder and branch circuit equipment grounding conductor.
- G. Conductor Terminations: Suitable for use with the conductors to be installed.
- H. Enclosures: Comply with NEMA 250, and list and label as complying with UL 50 and UL 50E.
 - 1. Environment Type per NEMA 250: Unless otherwise indicated, as specified for the following installation locations:
 - a. Indoor Clean, Dry Locations: Type 1.
 - 2. Boxes: Galvanized steel unless otherwise indicated.
 - a. Provide wiring gutters sized to accommodate the conductors to be installed.
 - 3. Fronts:
 - a. Fronts for Surface-Mounted Enclosures: Same dimensions as boxes.
 - b. Fronts for Flush-Mounted Enclosures: Overlap boxes on all sides to conceal rough opening.
 - c. Finish for Painted Steel Fronts: Manufacturer's standard grey unless otherwise indicated.
 - 4. Lockable Doors: All locks keyed alike unless otherwise indicated.
- I. Future Provisions: Prepare all unused spaces for future installation of devices including bussing, connectors, mounting hardware and all other required provisions.
- J. Load centers are not acceptable.
- K. Provide terminals rated and U.L. listed for use with 75 degrees C temperature rated conductors.

2.03 LIGHTING AND APPLIANCE PANELBOARDS

- A. Description: Panelboards complying with NEMA PB 1, lighting and appliance branch circuit type, circuit breaker type, and listed and labeled as complying with UL 67; ratings, configurations and features as indicated on the drawings.
- B. Conductor Terminations:
 - 1. Main and Neutral Lug Material: Copper suitable for terminating copper conductors only.
 - 2. Main and Neutral Lug Type: Mechanical.
- C. Bussing:
 - 1. Phase Bus Connections: Arranged for sequential phasing of overcurrent protective devices.
 - 2. Phase and Neutral Bus Material: Copper.
 - 3. Ground Bus Material: Copper.
- D. Circuit Breakers: Thermal magnetic bolt-on type unless otherwise indicated.
 - 1. UL listed for intended branch circuits:
 - a. Lighting SWD.
 - b. Heating, Ventilating and Air Conditioning: HACR rated.

- c. Shunt Trip Device: 120 volts, AC.
- d. Undervoltage Trip Device: 120 volts, AC.
- e. Auxiliary Switch: 120 volts, AC.
- f. Alarm Switch: 120 volts, AC.
- g. Electrical Operator: 120 volts, AC.
- h. Handle Lock: Include provisions for sealing.
- i. Provide mechanical trip device.
- j. Provide insulated ground lug in each enclosure.
- k. Provide products suitable for use as service entrance equipment where so applied.
- E. Enclosures:
 - 1. Provide flush-mounted enclosures as indicated.
 - 2. Fronts: Provide door-in-door trim with hinged cover for access to load terminals and wiring gutters, and separate lockable hinged door with concealed hinges for access to overcurrent protective device handles without exposing live parts.
 - 3. Provide clear plastic circuit directory holder mounted on inside of door.

2.04 OVERCURRENT PROTECTIVE DEVICES

- A. Molded Case Circuit Breakers:
 - 1. Description: Quick-make, quick-break, over center toggle, trip-free, trip-indicating circuit breakers listed and labeled as complying with UL 489, and complying with FS W-C-375 where applicable; ratings, configurations, and features as indicated on the drawings.
 - 2. Interrupting Capacity:
 - a. Provide circuit breakers with interrupting capacity as required to provide the short circuit current rating indicated, but not less than:
 - 1) 10,000 rms symmetrical amperes at 240 VAC or 208 VAC.
 - b. Fully Rated Systems: Provide circuit breakers with interrupting capacity not less than the short circuit current rating indicated.
 - 3. Conductor Terminations:
 - a. Lug Material: Aluminum, suitable for terminating aluminum or copper conductors.
 - 4. Thermal Magnetic Circuit Breakers: For each pole, furnish thermal inverse time tripping element for overload protection and magnetic instantaneous tripping element for short circuit protection.
 - 5. Multi-Pole Circuit Breakers: Furnish with common trip for all poles.
 - 6. Provide the following circuit breaker types where indicated:
 - a. Ground Fault Circuit Interrupter (GFCI) Circuit Breakers: Listed as complying with UL 943, class A for protection of personnel.
 - 7. Do not use tandem circuit breakers.
 - 8. Do not use handle ties in lieu of multi-pole circuit breakers.
 - 9. Provide multi-pole circuit breakers for multi-wire branch circuits as required by NFPA 70.

2.05 SOURCE QUALITY CONTROL

A. Factory test panelboards according to NEMA PB 1.

PART 3 EXECUTION

3.01 EXAMINATION

A. Verify that field measurements are as shown on the drawings.

- B. Verify that the ratings and configurations of the panelboards and associated components are consistent with the indicated requirements.
- C. Verify that mounting surfaces are ready to receive panelboards.
- D. Verify that conditions are satisfactory for installation prior to starting work.

3.02 INSTALLATION

- A. Install products in accordance with manufacturer's instructions.
- B. Install panelboards securely, in a neat and workmanlike manner in accordance with NECA 1 (general workmanship), NECA 1 (general workmanship), and NECA 1 (general workmanship).
- C. Arrange equipment to provide minimum clearances in accordance with manufacturer's instructions and NFPA 70.
- D. Provide required supports in accordance with Section 26 05 00.
- E. Install panelboards plumb.
- F. Install flush-mounted panelboards so that trims fit completely flush to wall with no gaps and rough opening completely covered.
- G. Mount panelboards such that the highest position of any operating handle for circuit breakers or switches does not exceed 79 inches above the floor or working platform.
- H. Provide minimum of six spare 1 inch trade size conduits out of each flush-mounted panelboard stubbed into accessible space above ceiling and below floor.
- I. Install all field-installed branch devices, components, and accessories.
- J. Provide filler plates to cover unused spaces in panelboards.
- K. Use sheet metal channel to bridge studs above and below cabinets and panelboards recessed in hollow partitions.
- L. Provide typed or neatly handwritten circuit directory for each branch circuit panelboard. Revise directory to reflect circuiting changes required to balance phase loads.
- M. Provide engraved plastic nameplates.
- N. Measure steady state load currents at each panelboard feeder; rearrange circuits in the panelboard to balance the phase loads to within 20 percent of each other. Maintain proper phasing for multiwire branch circuits.

3.03 FIELD QUALITY CONTROL

- A. Perform inspection, testing, and adjusting in accordance with Section 01 40 00.
- B. Inspect and test in accordance with NETA ATS, except Section 4.
- C. Test GFCI circuit breakers to verify proper operation.
- D. Correct deficiencies and replace damaged or defective panelboards or associated components.

3.04 ADJUSTING

- A. Adjust tightness of mechanical and electrical connections to manufacturer's recommended torque settings.
- B. Adjust alignment of panelboard fronts.
- C. Load Balancing: For each panelboard, rearrange circuits such that the difference between each measured steady state phase load does not exceed 20 percent and adjust circuit directories accordingly. Maintain proper phasing for multi-wire branch circuits.

3.05 CLEANING

- A. Clean dirt and debris from panelboard enclosures and components according to manufacturer's instructions.
- B. Repair scratched or marred exterior surfaces to match original factory finish.

SECTION 26 27 26 WIRING DEVICES

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Wall switches.
- B. Wall dimmers.
- C. Receptacles.
- D. Wall plates.
- E. Poke-through assemblies.
- F. Motion Sensors.

1.02 REFERENCE STANDARDS

- A. FS W-C-596 Connector, Electrical, Power, General Specification for; 2014h (Validated 2022).
- B. FS W-S-896 Switches, Toggle (Toggle and Lock), Flush Mounted (General Specification); 2017g, with Amendment.
- C. NECA 1 Standard for Good Workmanship in Electrical Construction; 2015.
- D. NECA 130 Standard for Installing and Maintaining Wiring Devices; 2016.
- E. NEMA WD 1 General Color Requirements for Wiring Devices; 1999 (Reaffirmed 2020).
- F. NEMA WD 6 Wiring Devices Dimensional Specifications; 2021.
- G. NFPA 70 National Electrical Code; Most Recent Edition Adopted by Authority Having Jurisdiction, Including All Applicable Amendments and Supplements.
- H. UL 20 General-Use Snap Switches; Current Edition, Including All Revisions.
- I. UL 498 Attachment Plugs and Receptacles; Current Edition, Including All Revisions.
- J. UL 514D Cover Plates for Flush-Mounted Wiring Devices; Current Edition, Including All Revisions.
- K. UL 943 Ground-Fault Circuit-Interrupters; Current Edition, Including All Revisions.
- L. UL 1472 Solid-State Dimming Controls; Current Edition, Including All Revisions.

1.03 ADMINISTRATIVE REQUIREMENTS

- A. Coordination:
 - 1. Coordinate the placement of outlet boxes with millwork, furniture, equipment, etc. installed under other sections or by others.
 - 2. Coordinate wiring device ratings and configurations with the electrical requirements of actual equipment to be installed.
 - 3. Coordinate the placement of outlet boxes for wall switches with actual installed door swings.
 - 4. Coordinate the installation and preparation of uneven surfaces, such as split face block, to provide suitable surface for installation of wiring devices.

- 5. Coordinate the core drilling of holes for poke-through assemblies with the work covered under other sections.
- 6. Notify Architect/Engineer of any conflicts or deviations from Contract Documents to obtain direction prior to proceeding with work.
- B. Sequencing:
 - 1. Do not install wiring devices until final surface finishes and painting are complete.

1.04 SUBMITTALS

- A. See Section 01 30 00 Administrative Requirements, for submittal procedures.
- B. Product Data: Provide manufacturer's catalog information showing dimensions, colors, and configurations.
- C. Manufacturer's Installation Instructions: Indicate application conditions and limitations of use stipulated by product testing agency. Include instructions for storage, handling, protection, examination, preparation, and installation of product.
- D. Operation and Maintenance Data:
 - 1. Wall Dimmers: Include information on operation and setting of presets.
 - 2. GFCI Receptacles: Include information on status indicators.
- E. Project Record Documents: Record actual installed locations of wiring devices.

1.05 QUALITY ASSURANCE

- A. Comply with requirements of NFPA 70.
- B. Manufacturer Qualifications: Company specializing in manufacturing the products specified in this section with minimum three years documented experience.
- C. Products: Listed, classified, and labeled as suitable for the purpose intended.
- D. Product Listing Organization Qualifications: An organization recognized by OSHA as a Nationally Recognized Testing Laboratory (NRTL) and acceptable to authorities having jurisdiction.

1.06 DELIVERY, STORAGE, AND PROTECTION

A. Store in a clean, dry space in original manufacturer's packaging until ready for installation.

PART 2 PRODUCTS

2.01 APPLICATIONS

- A. Provide wiring devices suitable for intended use and with ratings adequate for load served.
- B. For single receptacles installed on an individual branch circuit, provide receptacle with ampere rating not less than that of the branch circuit.
- C. Provide tamper resistant receptacles for receptacles installed in dwelling units.
- D. Provide GFCI protection for receptacles installed within 6 feet of sinks.
- E. Provide GFCI protection for receptacles installed in kitchens.
- F. Provide GFCI protection for receptacles serving electric drinking fountains.

- G. Unless noted otherwise, do not use combination switch/receptacle devices.
- H. For flush floor service fittings, use carpet flanges for installations in carpeted floors.

2.02 ALL WIRING DEVICES

- A. Provide products listed and classified by Underwriters Laboratories Inc. as suitable for the purpose specified and indicated.
- B. Finishes:
 - 1. All Wiring Devices: White with stainless steel wall plate unless otherwise indicated.
 - 2. Wiring Devices Installed in Finished Spaces: White with stainless steel wall plate unless otherwise indicated.
 - 3. Wiring Devices Installed in Wet or Damp Locations: White with specified weatherproof cover unless otherwise indicated.
 - 4. Wiring Devices Connected to Emergency Power: Redwith red aluminum wall plate.

2.03 WALL SWITCHES

- A. Manufacturers:
 - 1. Hubbell Incorporated: www.hubbell.com/#sle.
 - 2. Leviton Manufacturing Company, Inc: www.leviton.com/#sle.
 - 3. Pass & Seymour, a brand of Legrand North America, Inc: www.legrand.us/#sle.
 - 4. Substitutions: See Section 01 60 00 Product Requirements.
- B. Wall Switches General Requirements: AC only, quiet operating, general-use snap switches with silver alloy contacts, complying with NEMA WD 1 and NEMA WD 6, and listed as complying with UL 20 and where applicable, FS W-S-896; types as indicated on the drawings.
 - 1. Wiring Provisions: Terminal screws for side wiring and screw actuated binding clamp for back wiring with separate ground terminal screw.
- C. Standard Wall Switches: Industrial specification grade, 20 A, 120/277 V with standard toggle type switch actuator and maintained contacts; single pole single throw, double pole single throw, three way, or four way as indicated on the drawings.

2.04 WALL DIMMERS

- A. Manufacturers:
 - 1. Leviton Manufacturing Company, Inc: www.leviton.com/#sle.
 - 2. Lutron Electronics Company, Inc: www.lutron.com/#sle.
 - 3. Pass & Seymour, a brand of Legrand North America, Inc: www.legrand.us/#sle.
 - 4. Substitutions: See Section 01 60 00 Product Requirements.
- B. Wall Dimmers General Requirements: Solid-state with continuous full-range even control following square law dimming curve, integral radio frequency interference filtering, power failure preset memory, air gap switch accessible without removing wall plate, complying with NEMA WD 1 and NEMA WD 6, and listed as complying with UL 1472; types and ratings suitable for load controlled as indicated on the drawings.

2.05 RECEPTACLES

A. Manufacturers:

- 1. Hubbell Incorporated: www.hubbell.com/#sle.
- 2. Leviton Manufacturing Company, Inc: www.leviton.com/#sle.
- 3. Lutron Electronics Company, Inc; Designer Style: www.lutron.com/#sle.
- 4. Pass & Seymour, a brand of Legrand North America, Inc: www.legrand.us/#sle.
- 5. Substitutions: See Section 01 60 00 Product Requirements.
- B. Receptacles General Requirements: Self-grounding, complying with NEMA WD 1 and NEMA WD 6, and listed as complying with UL 498, and where applicable, FS W-C-596; types as indicated on the drawings.
 - 1. Wiring Provisions: Terminal screws for side wiring or screw actuated binding clamp for back wiring with separate ground terminal screw.
 - 2. NEMA configurations specified are according to NEMA WD 6.
- C. Convenience Receptacles:
 - 1. Standard Convenience Receptacles: Industrial specification grade, 20A, 125V, NEMA 5-20R; single or duplex as indicated on the drawings.
 - Automatically Controlled Convenience Receptacles: Industrial specification grade, 20A, 125V, NEMA 5-20R; controlled receptacle marking on device face per NFPA 70; single or duplex as indicated on the drawings.
- D. GFCI Receptacles:
 - GFCI Receptacles General Requirements: Self-testing, with feed-through protection and light to indicate ground fault tripped condition and loss of protection; listed as complying with UL 943, class A.
 - a. Provide test and reset buttons of same color as device.
 - 2. Standard GFCI Receptacles: Industrial specification grade, duplex, 20A, 125V, NEMA 5-20R, rectangular decorator style.

2.06 WALL PLATES

- A. Manufacturers:
 - 1. Hubbell Incorporated: www.hubbell-wiring.com/#sle.
 - 2. Leviton Manufacturing Company, Inc: www.leviton.com/#sle.
 - 3. Lutron Electronics Company, Inc: www.lutron.com/#sle.
 - 4. Pass & Seymour, a brand of Legrand North America, Inc: www.legrand.us/#sle.
- B. Wall Plates: Comply with UL 514D.
 - 1. Configuration: One piece cover as required for quantity and types of corresponding wiring devices.
 - 2. Size: Standard.
 - 3. Screws: Metal with slotted heads finished to match wall plate finish.
- C. Stainless Steel Wall Plates: Brushed satin finish, Type 302 stainless steel.

2.07 MOTION SENSORS

- A. Manufacturers:
 - 1. Leviton
 - 2. Hubbell
 - 3. Lutron
 - 4. Approved Equal

- B. Combination Wall Switch/Occupancy Sensor
 - 1. Dual technology (passive infrared and ultrasonic), 277V sensor with 180degree field-of-view and maximum coverage of 2400 square feet.
 - 2. Manual push button for ON/OFF light switching.
 - 3. Time delay settings: 30 seconds, 10, 20 or 30 minutes).
 - 4. Adjustable Integral blinders.
 - 5. Sensor shall continuously monitor space to identify usage patterns. Unit shall automatically adjust time delay and sensitivity settings for optimal performance and energy efficiency.

C. Ceiling Mounted.

- 1. Dual technology (passive infrared and ultrasonic), 24VDC sensor with unobtrusive appearance and 360 degrees of coverage.
 - a. Provide type/quantity of motion sensors to meet square foot coverage requirements.
- 2. Provide power pack for 24VDC controls and switching of 120/277V circuits. Minimum quantity of sensors per power pack: 2.
- 3. Sensor shall continuously monitor space to identify usage patterns. Unit shall automatically adjust time delay and sensitivity settings for optimal performance and energy efficiency.
- 4. Time delay settings: Auto, fixed (5,10,15,20 or 30 minutes).
- 5. Sensitivity settings: Auto, reduced sensitivity (passive infrared) variable (ultrasonic).
- 6. (1) N/O and (1) N/C output.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify that field measurements are as indicated.
- B. Verify that outlet boxes are installed in proper locations and at proper mounting heights and are properly sized to accommodate devices and conductors in accordance with NFPA 70.
- C. Verify that wall openings are neatly cut and will be completely covered by wall plates.
- D. Verify that final surface finishes are complete, including painting.
- E. Verify that floor boxes are adjusted properly.
- F. Verify that branch circuit wiring installation is completed, tested, and ready for connection to wiring devices.
- G. Verify that core drilled holes for poke-through assemblies are in proper locations.
- H. Verify that conditions are satisfactory for installation prior to starting work.

3.02 PREPARATION

- A. Provide extension rings to bring outlet boxes flush with finished surface.
- B. Clean dirt, debris, plaster, and other foreign materials from outlet boxes.

3.03 INSTALLATION

A. Perform work in accordance with NECA 1 (general workmanship) and, where applicable, NECA 130, including mounting heights specified in those standards unless otherwise indicated.

- B. Coordinate locations of outlet boxes provided under Section 26 05 00 as required for installation of wiring devices provided under this section.
 - 1. Mounting Heights: Unless otherwise indicated, as follows:
 - a. Wall Switches: 48 inches above finished floor.
 - b. Wall Dimmers: 48 inches above finished floor.
 - c. Receptacles: 18 inches above finished floor or 6 inches above counter.
 - 2. Orient outlet boxes for vertical installation of wiring devices unless otherwise indicated.
 - 3. Where multiple receptacles, wall switches, or wall dimmers are installed at the same location and at the same mounting height, gang devices together under a common wall plate.
 - Locate wall switches on strike side of door with edge of wall plate 3 inches from edge of door frame. Where locations are indicated otherwise, notify Architect/Engineer to obtain direction prior to proceeding with work.
 - 5. Locate receptacles for electric drinking fountains concealed behind drinking fountain according to manufacturer's instructions.
- C. Install wiring devices in accordance with manufacturer's instructions.
- D. Install permanent barrier between ganged wiring devices when voltage between adjacent devices exceeds 300 V.
- E. Where required, connect wiring devices using pigtails not less than 6 inches long. Do not connect more than one conductor to wiring device terminals.
- F. Connect wiring devices by wrapping conductor clockwise 3/4 turn around screw terminal and tightening to proper torque specified by the manufacturer. Where present, do not use push-in pressure terminals that do not rely on screw-actuated binding.
- G. Unless otherwise indicated, connect wiring device grounding terminal to branch circuit equipment grounding conductor and to outlet box with bonding jumper.
- H. Unless otherwise indicated, GFCI receptacles may be connected to provide feed-through protection to downstream devices. Label such devices to indicate they are protected by upstream GFCI protection.
- I. Install wiring devices plumb and level with mounting yoke held rigidly in place.
- J. Install wall switches with OFF position down.
- K. Install wall dimmers to achieve full rating specified and indicated after derating for ganging as instructed by manufacturer.
- L. Do not share neutral conductor on branch circuits utilizing wall dimmers.
- M. Install vertically mounted receptacles with grounding pole on top and horizontally mounted receptacles with grounding pole on left.
- N. Install wall plates to fit completely flush to wall with no gaps and rough opening completely covered without strain on wall plate. Repair or reinstall improperly installed outlet boxes or improperly sized rough openings. Do not use oversized wall plates in lieu of meeting this requirement.
- O. Install blank wall plates on junction boxes and on outlet boxes with no wiring devices installed or designated for future use.

P. Install poke-through closure plugs in each unused core holes to maintain fire rating of floor.

3.04 FIELD QUALITY CONTROL

- A. See Section 01 40 00 Quality Requirements, for additional requirements.
- B. Inspect each wiring device for damage and defects.
- C. Operate each wall switch and wall dimmer with circuit energized to verify proper operation.
- D. Test each receptacle to verify operation and proper polarity.
- E. Test each GFCI receptacle for proper tripping operation according to manufacturer's instructions.
- F. Correct wiring deficiencies and replace damaged or defective wiring devices.

3.05 ADJUSTING

- A. Adjust devices and wall plates to be flush and level.
- B. Adjust presets for wall dimmers according to manufacturer's instructions as directed by Architect/Engineer.

3.06 CLEANING

A. Clean exposed surfaces to remove dirt, paint, or other foreign material and restore to match original factory finish.

SECTION 26 51 00 INTERIOR LUMINAIRES

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Interior luminaires.
- B. Emergency lighting units.
- C. Exit signs.
- D. Accessories.

1.02 RELATED REQUIREMENTS

A. Section 26 27 26 - Wiring Devices: Manual wall switches and wall dimmers.

1.03 REFERENCE STANDARDS

- A. 47 CFR 15 Radio Frequency Devices; current edition.
- B. IESNA LM-63 ANSI Approved Standard File Format for Electronic Transfer of Photometric Data and Related Information; 2002 (Reaffirmed 2008).
- C. IES LM-79 Approved Method: Optical and Electrical Measurements of Solid-State Lighting Products; 2019.
- D. IES LM-80 Approved Method: Measuring Maintenance of Light Output Characteristics of Solid-State Light Sources; 2021.
- E. NECA 1 Standard for Good Workmanship in Electrical Construction; 2015.
- F. NECA/IESNA 500 Standard for Installing Indoor Lighting Systems; 2006.
- G. NECA/IESNA 502 Standard for Installing Industrial Lighting Systems; 2006.
- H. NEMA LE 4 Recessed Luminaires, Ceiling Compatibility; 2012 (Reaffirmed 2018).
- I. NFPA 70 National Electrical Code; Most Recent Edition Adopted by Authority Having Jurisdiction, Including All Applicable Amendments and Supplements.
- J. NFPA 101 Life Safety Code; 2015.
- K. UL 924 Emergency Lighting and Power Equipment; Current Edition, Including All Revisions.
- L. UL 1598 Luminaires; Current Edition, Including All Revisions.
- M. UL 8750 Light Emitting Diode (LED) Equipment for Use in Lighting Products; Current Edition, Including All Revisions.

1.04 ADMINISTRATIVE REQUIREMENTS

- A. Coordination:
 - 1. Coordinate the installation of luminaires with mounting surfaces installed under other sections or by others. Coordinate the work with placement of supports, anchors, etc. required for mounting. Coordinate compatibility of luminaires and associated trims with mounting surfaces at

installed locations.

- 2. Coordinate the placement of luminaires with structural members, ductwork, piping, equipment, diffusers, fire suppression system components, and other potential conflicts installed under other sections or by others.
- 3. Coordinate the placement of exit signs with furniture, equipment, signage or other potential obstructions to visibility installed under other sections or by others.
- 4. Notify Architect/Engineer of any conflicts or deviations from Contract Documents to obtain direction prior to proceeding with work.

1.05 SUBMITTALS

- A. See Section 01 30 00 Administrative Requirements, for submittal procedures.
- B. Shop Drawings:
 - 1. Provide photometric calculations where luminaires are proposed for substitution upon request.
 - 2. Indicate construction, installation and mounting details for products.
 - 3. Wiring Diagrams: Submit wiring diagrams for all exit sign, night light, self-contained back-up battery lighting, battery ballasts and associated circuit breakers, programmable circuit breakers and/or emergency circuit breakers.
- C. Product Data: Provide manufacturer's standard catalog pages and data sheets including detailed information on luminaire construction, dimensions, ratings, finishes, mounting requirements, listings, service conditions, photometric performance, installed accessories, and ceiling compatibility; include model number nomenclature clearly marked with all proposed features.
 - 1. LED Luminaires:
 - a. Include estimated useful life, calculated based on IES LM-80 test data.
 - 2. Lamps: Include rated life, color temperature, color rendering index (CRI), and initial and mean lumen output.
 - 3. Wiring diagrams: Provide wiring diagrams for dimmable ballasts and dimmable switches.
- D. Manufacturer's Installation Instructions: Indicate application conditions and limitations of use stipulated by product testing agency. Include instructions for storage, handling, protection, examination, preparation, and installation of product.
- E. Operation and Maintenance Data: Instructions for each product including information on replacement parts.
- F. Maintenance Materials: Furnish the following for Owner's use in maintenance of project.1. See Section 01 60 00 Product Requirements, for additional provisions.
- G. Project Record Documents: Record actual connections and locations of luminaires and any associated remote components.

1.06 QUALITY ASSURANCE

- A. Comply with requirements of NFPA 70.
- B. Manufacturer Qualifications: Company specializing in manufacturing the products specified in this section with minimum three years documented experience.
- C. Product Listing Organization Qualifications: An organization recognized by OSHA as a Nationally Recognized Testing Laboratory (NRTL) and acceptable to authorities having jurisdiction.

1.07 DELIVERY, STORAGE, AND PROTECTION

- A. Receive, handle, and store products according to NECA/IESNA 500 (commercial lighting), NECA/IESNA 502 (industrial lighting), and manufacturer's written instructions.
- B. Keep products in original manufacturer's packaging and protect from damage until ready for installation.

1.08 FIELD CONDITIONS

A. Maintain field conditions within manufacturer's required service conditions during and after installation.

1.09 WARRANTY

- A. See Section 01 78 00 Closeout Submittals, for additional warranty requirements.
- B. Provide three year manufacturer warranty for LED luminaires, including drivers.

PART 2 PRODUCTS

2.01 LUMINAIRE TYPES

- A. Furnish products as indicated in luminaire schedule included on the drawings.
- B. Substitutions: See Section 01 60 00 Product Requirements except where individual luminaire types are designated with substitutions not permitted.

2.02 LUMINAIRES

- A. Manufacturers:
 - 1. Acuity Brands, Inc: www.acuitybrands.com/#sle.
 - 2. Hubbell Lighting, Inc: www.hubbelllighting.com/#sle.
 - 3. Signify , Inc.: https://www.signify.com/
- B. Provide products that comply with requirements of NFPA 70.
- C. Provide products that are listed and labeled as complying with UL 1598, where applicable.
- D. Provide products listed, classified, and labeled as suitable for the purpose intended.
- E. Provide products complying with Federal Energy Management Program (FEMP) requirements.
- F. Unless otherwise indicated, provide complete luminaires including lamp(s) and all sockets, ballasts, reflectors, lenses, housings and other components required to position, energize and protect the lamp and distribute the light.
- G. Unless specifically indicated to be excluded, provide all required conduit, boxes, wiring, connectors, hardware, supports, trims, accessories, etc. as necessary for a complete operating system.
- H. Provide products suitable to withstand normal handling, installation, and service without any damage, distortion, corrosion, fading, discoloring, etc.
- I. Recessed Luminaires:
 - 1. Ceiling Compatibility: Comply with NEMA LE 4.

- 2. Luminaires Recessed in Insulated Ceilings: Listed and labeled as IC-rated, suitable for direct contact with insulation and combustible materials.
- 3. Luminaires Recessed in Sloped Ceilings: Provide suitable sloped ceiling adapters.
- J. LED Luminaires:
 - 1. Components: UL 8750 recognized or listed as applicable.
 - 2. Tested in accordance with IES LM-79 and IES LM-80.
 - 3. LED Estimated Useful Life: Minimum of 50,000 hours at 70 percent lumen maintenance, calculated based on IES LM-80 test data.

2.03 EMERGENCY LIGHTING UNITS

- A. Description: Emergency lighting units complying with NFPA 101 and all applicable state and local codes, and listed and labeled as complying with UL 924.
- B. Operation: Upon interruption of normal power source or brownout condition exceeding 20 percent voltage drop from nominal, solid-state control automatically switches connected lamps to integral battery power for minimum of 90 minutes of rated emergency illumination, and automatically recharges battery upon restoration of normal power source.
- C. Battery:
 - 1. Sealed maintenance-free lead calcium unless otherwise indicated.
 - 2. Size battery to supply all connected lamps, including emergency remote heads where indicated.
- D. Diagnostics: Provide power status indicator light and accessible integral test switch to manually activate emergency operation.
- E. Provide low-voltage disconnect to prevent battery damage from deep discharge.
- F. Accessories:
 - 1. Provide compatible accessory mounting brackets where indicated or required to complete installation.
 - 2. Provide compatible accessory high impact polycarbonate vandal shields where indicated.
 - 3. Where indicated, provide emergency remote heads that are compatible with the emergency lighting unit they are connected to and suitable for the installed location.

2.04 EXIT SIGNS

- A. Description: Exit signs complying with NFPA 101 and applicable state and local codes, and listed and labeled as complying with UL 924.
 - 1. Number of Faces: Single- or double-face as indicated or as required for installed location.
 - 2. Directional Arrows: As indicated or as required for installed location.
- B. Powered Exit Signs: Internally illuminated with LEDs unless otherwise indicated.
 - 1. Self-Powered Exit Signs:
 - a. Operation: Upon interruption of normal power source or brownout condition exceeding 20 percent voltage drop from nominal, solid-state control automatically switches connected lamps to integral battery power for minimum of 90 minutes of rated emergency illumination, and automatically recharges battery upon restoration of normal power source.
 - b. Battery: Sealed, maintenance-free, nickel cadmium unless otherwise indicated.
 - c. Diagnostics: Provide power status indicator light and accessible integral test switch to manually activate emergency operation.

d. Provide low-voltage disconnect to prevent battery damage from deep discharge.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify that field measurements are as indicated.
- B. Verify that outlet boxes are installed in proper locations and at proper mounting heights and are properly sized to accommodate conductors in accordance with NFPA 70.
- C. Verify that suitable support frames are installed where required.
- D. Verify that branch circuit wiring installation is completed, tested, and ready for connection to luminaires.
- E. Verify that conditions are satisfactory for installation prior to starting work.
- F. Examine substrate and supporting grids for luminaires.
- G. Examine each fixture to determine suitability for lamps specified.

3.02 PREPARATION

- A. Provide extension rings to bring outlet boxes flush with finished surface.
- B. Clean dirt, debris, plaster, and other foreign materials from outlet boxes.

3.03 INSTALLATION

- A. Coordinate locations of outlet boxes provided under Section 26 05 00 as required for installation of luminaires provided under this section.
- B. Perform work in accordance with NECA 1 (general workmanship).
- C. Install products in accordance with manufacturer's instructions.
- D. Install luminaires securely, in a neat and workmanlike manner, as specified in NECA 500 (commercial lighting) and NECA 502 (industrial lighting).
- E. Install luminaires plumb and square and aligned with building lines and with adjacent luminaires.
- F. Locate recessed ceiling luminaires as indicated on reflected ceiling plan.
- G. Install wall mounted luminaires, emergency units and exit signs at height as indicated on Drawings and directed in the field by Architect. Obtain final approval from Architect prior to commencement of this portion of work.
- H. Install accessories furnished with each luminaire.
- I. Make wiring connections to branch circuit using building wire with insulation suitable for temperature conditions within luminaire.
- J. Suspended Ceiling Mounted Luminaires:
 - 1. Do not use ceiling tiles to bear weight of luminaires.
 - 2. Support luminaires larger than 2 foot by 4 foot size independent of ceiling framing.
 - 3. Secure lay-in luminaires to ceiling support channels using listed safety clips at four corners.

- 4. See appropriate Division 9 section where suspended grid ceiling is specified for additional requirements.
- K. Recessed Luminaires:
 - 1. Install trims tight to mounting surface with no visible light leakage.
 - 2. Install recessed luminaires to permit removal from below.
 - 3. Install recessed luminaires using accessories and firestopping materials to meet regulatory requirements for fire rating.
 - 4. Install clips to secure recessed grid-supported luminaires in place.
- L. Install accessories furnished with each luminaire.
- M. Bond products and metal accessories to branch circuit equipment grounding conductor.
- N. Emergency Lighting Units:
 - 1. Unless otherwise indicated, connect unit to unswitched power from circuit indicated. Bypass local switches, contactors, or other lighting controls.
- O. Exit Signs:
 - 1. Unless otherwise indicated, connect unit to unswitched power from circuit indicated. Bypass local switches, contactors, or other lighting controls.

3.04 FIELD QUALITY CONTROL

- A. See Section 01 40 00 Quality Requirements, for additional requirements.
- B. Inspect each product for damage and defects.
- C. Operate each luminaire after installation and connection to verify proper operation.
- D. Test self-powered exit signs, emergency lighting units, and fluorescent emergency power supply units to verify proper operation upon loss of normal power supply.
- E. Correct wiring deficiencies and repair or replace damaged or defective products. Repair or replace excessively noisy ballasts as determined by Architect/Engineer.
- F. Energy Code Commissioning: The electrical contractor shall program, test, calibrate and confirm the proper operation and placement of all lighting controls in accordance with the International Energy Code, 2021 Edition Paragraph C408.3 "Functional testing of lighting controls".

3.05 ADJUSTING

- A. Aim and position adjustable luminaires to achieve desired illumination as indicated or as directed by Architect/Engineer. Secure locking fittings in place.
- B. Aim and position adjustable emergency lighting unit lamps to achieve optimum illumination of egress path as required or as directed by Architect/Engineer or authority having jurisdiction.
- C. Exit Signs with Field-Selectable Directional Arrows: Set as indicated or as required to properly designate egress path as directed by Architect/Engineer or authority having jurisdiction.
- D. Relamp luminaires which have failed lamps at completion of work.
3.06 CLEANING

A. Clean surfaces according to NECA 500 (commercial lighting), NECA 502 (industrial lighting), and manufacturer's instructions to remove dirt, fingerprints, paint, or other foreign material and restore finishes to match original factory finish.

3.07 CLOSEOUT ACTIVITIES

- A. See Section 01 78 00 Closeout Submittals, for closeout submittals.
- B. Demonstration: Demonstrate proper operation of luminaires to Architect/Engineer, and correct deficiencies or make adjustments as directed.
- C. Just prior to Substantial Completion, replace all lamps that have failed.
- D. Project record documents: Accurately record location of each luminaire.

3.08 PROTECTION

A. Protect installed luminaires from subsequent construction operations.

END OF SECTION

SECTION 28 46 00 FIRE DETECTION AND ALARM

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Modifications to existing fire alarm system, including all components, wiring, and conduit.
- B. Replacement and removal of existing fire alarm system components, wiring, and conduit indicated.

1.02 RELATED REQUIREMENTS

- A. Section 07 84 00 Firestopping: Materials and methods for work to be performed by this installer.
- B. Section 08 71 00 Door Hardware: Electrically operated locks and door holder devices to be monitored and released by fire alarm system.
- C. Section 21 13 00 Fire Suppression Sprinklers: Supervisory, alarm, and actuating devices installed in sprinkler system.

1.03 REFERENCE STANDARDS

- A. 36 CFR 1191 Americans with Disabilities Act (ADA) Accessibility Guidelines for Buildings and Facilities; Architectural Barriers Act (ABA) Accessibility Guidelines; current edition.
- B. ADA Standards 2010 ADA Standards for Accessible Design; 2010.

1.04 SUBMITTALS

- A. See Section 01 30 00 Administrative Requirements, for submittal procedures.
- B. Evidence of designer qualifications.
- C. Shop Drawings: Submit all information required for plan review and permitting by authorities having jurisdiction, including but not limited to floor plans, riser diagrams, and description of operation:
 - 1. Shop drawing submitted to Architect/Engineer shall be approved and signed by the authority having jurisdiction.
 - 2. Submit point-to-point and single line wiring diagrams showing the point of connection and terminals used for all field connections.
 - 3. Submit diagrams showing all connections from field devices to control panel.
 - a. Include a detailed description of the control panel as it shall operate for this specific installation.
 - 4. Submit field wiring color-coding legend.
 - 5. Submit control panel interior wiring diagram.
 - 6. Indicate existing wiring arrangements and locations of devices and wiring routing.
 - 7. Copy (if any) of list of data required by authority having jurisdiction.
 - 8. NFPA 72 "Record of Completion", filled out to the extent known at the time.
 - 9. Location of all components, circuits, and raceways; mark components with identifiers used in control unit programming.
 - 10. Manufacturer's detailed data sheet for each component, including wiring diagrams, installation instructions, circuit length limitations, dimensions, ratings, layouts and complete catalog numbers.

- a. Submit UL listings with cross-listing substantiation for each system component clearly marked.
- 11. Description of power supplies; if secondary power is by battery include calculations demonstrating adequate battery power.
- 12. Certification by either the manufacturer of the control unit or by the manufacturer of each other component that the components are compatible with the control unit.
- 13. Certification by the manufacturer of the control unit that the system design complies with Contract Documents.
- 14. Certification by Contractor that the system design complies with Contract Documents.
- 15. Do not show existing components to be removed.
- D. Evidence of installer qualifications.
- E. Evidence of instructor qualifications; training lesson plan outline.
- F. Evidence of maintenance contractor qualifications, if different from installer.
- G. Inspection and Test Reports:
 - 1. Submit inspection and test plan prior to closeout demonstration.
 - 2. Submit documentation of satisfactory inspections and tests.
 - 3. Submit NFPA 72 "Inspection and Test Form," filled out.
- H. Project Record Documents: See Section 01 78 00 for additional requirements; have one set available during closeout demonstration:
 - 1. Complete set of floor plans showing actual installed locations of components, conduit, and zones.
 - 2. "As installed" wiring and schematic diagrams, with final terminal identifications.
 - 3. "As programmed" operating sequences, including control events by device, updated input/output chart, and voice messages by event.
- I. Closeout Documents:
 - 1. Certification by manufacturer that the system has been installed in compliance with manufacturer's installation requirements, is complete, and is in satisfactory operating condition.
 - 2. NFPA 72 "Record of Completion", filled out completely and signed by installer and authorized representative of authority having jurisdiction.

1.05 QUALITY ASSURANCE

- A. Designer: Qualified employee of fire alarm control panel manufacturer, Contractor, or installer, with experience designing fire alarm systems in the jurisdictional area of the authorities having jurisdiction.
 - 1. Delegated Engineering Responsibility: Provide design services necessary to modify initiating device circuits, notification circuits and affected control panels and power supplies. Provide all necessary drawings and specification to local authority having jurisdiction for approval to modify this existing system as intended.
- B. Manufacturer: Qualified company specializing in smoke detection and fire alarm systems with five years documented experience.
- C. Installer: Qualified firm with minimum 5 years documented experience installing fire alarm systems of the specified type and providing contract maintenance service as a regular part of their business.

- 1. Authorized representative of control unit manufacturer; submit manufacturer's certification that installer is authorized; include name and title of manufacturer's representative making certification.
- 2. Installer Personnel: At least 2 years of experience installing fire alarm systems.
- 3. Supervisor: NICET level III or IV (3 or 4) certified fire alarm technician; furnish name and address.
- D. Maintenance Contractor: Same entity as installer or different entity with specified qualifications.
- E. Instructor Qualifications: Experienced in technical instruction, understanding fire alarm theory, and able to provide the required training; trained by fire alarm control unit manufacturer.
- F. Qualified personnel includes those persons that are:
 - 1. Factory trained and certified; OR
 - 2. NICET Level III or IV (3 or 4) Fire Alarm certified; OR
 - 3. International Municipal Signal Association Fire Alarm certified; OR
 - 4. Certified by state (Illinois Department of Professional Regulation); OR
 - 5. Trained, qualified, and employed by an organization listed by a national testing laboratory.

1.06 WARRANTY

- A. Provide control panel manufacturer's warranty that system components other than wire and conduit are free from defects and will remain so for 1 year after date of Substantial Completion.
- B. Provide installer's warranty that the installation is free from defects and will remain so for 1 year after date of Substantial Completion.
- C. Contractor shall, as condition precedent to final payment, execute a written guaranty to the Owner. Materials and equipment furnished by him under this Contract shall remain in satisfactory operating condition for a period of one year from the date of the final acceptance of the Work by the Owner. The guaranty shall also include prompt emergency service. All defects or damages due to faulty materials or workmanship shall be repaired or replaced without delay to the Owner's satisfaction and at the Contractor's expense.

1.07 EXISTING CONDITIONS

- A. The existing fire alarm system control panel is a Fire Control Instruments Firevac 7200 system.
 - 1. The existing control panel will be modified and expanded to feed new devices as shown on the floor plans.
 - 2. Provide new equipment compatible with existing devices and system at site.

PART 2 PRODUCTS

2.01 MANUFACTURERS

- A. Initiating Devices and Notification Appliances:
 - 1. Same manufacturer as control units.
 - 2. Provide initiating devices and notification appliances made by the same manufacturer, where possible.
- B. Substitutions: See Section 01 60 00 Product Requirements.

2.02 FIRE ALARM SYSTEM

- A. Fire Alarm System: Provide modifications and extensions to the existing automatic fire detection and alarm system:
 - 1. Provide all components necessary, regardless of whether shown in Contract Documents or not.
 - 2. Protected Premises: Areas denoted on the drawings.
 - 3. Comply with the following; where requirements conflict, order of precedence of requirements is as listed:
 - a. ADA Standards.
 - b. The requirements of the local authority having jurisdiction which is City of Geneva.
 - c. Applicable local codes.
 - d. Contract Documents (drawings and specifications).
 - e. NFPA 72; where the word "should" is used consider that provision mandatory; where conflicts between requirements require deviation from NFPA 72, identify deviations clearly on design documents.
 - 4. Evacuation Alarm: Single smoke zone; general evacuation of entire premises.
 - 5. Zoning: Point addressable system with initiating devices being individually zoned.
 - 6. Existing Control Panel: Make modifications to the existing panel:
 - a. Additional Power Supplies: Adequate to serve control panel modules, remote detectors, keypads, door holders, relays and alarm signaling devices. Include battery-operated emergency power supply with capacity for operating system in standby mode for 60 hours followed by alarm mode for 5 minutes.
- B. Supervising Stations and Fire Department Connections:
 - 1. Existing connections to remain.
- C. Circuits:
 - 1. Initiating Device Circuits (IDC): Class B, Style A.
 - 2. Signaling Line Circuits (SLC) Within Single Building: Class B, Style 0.5.
 - 3. Notification Appliance Circuits (NAC): Class B, Style W.
 - 4. All cabling shall be plenum rated.
- D. Spare Capacity:
 - 1. Initiating Device Circuits: Minimum 25 percent spare capacity.
 - 2. Notification Appliance Circuits: Minimum 25 percent spare capacity.
 - 3. Fire Alarm Control Units: Capable of handling all circuits utilized to capacity without requiring additional components other than plug-in control modules.
- E. Power Sources:
 - 1. Primary: Dedicated branch circuits of the facility power distribution system.
 - 2. Secondary: Storage batteries.
 - 3. Capacity: Sufficient to operate entire system for period specified by NFPA 72.
 - 4. Each Computer System: Provide uninterruptible power supply (UPS).

2.03 EXISTING COMPONENTS

- A. Clearly label components that are "Not In Service."
- B. Remove unused existing components and materials from site and dispose of properly.

2.04 COMPONENTS

A. General:

- 1. Provide flush mounted units where installed in finish areas; in unfinished areas, surface mounted unit are acceptable.
- 2. Provide legible, permanent labels for each control device, using identification used in operation and maintenance data.
- B. Fire Alarm Power Supplies, Initiating Devices, and Notification Appliances: Analog, addressable type; listed by Underwriters Laboratories as suitable for the purpose intended.
- C. Notification Appliances:
 - 1. Combination Horn/Strobes: NFPA 72 and UL 1971; electronic horn rated 90 dBA average at 10 feet. Provide integral 110 candela strobe lamp and flasher. Provide red trim ring for semi-flush mounting. Synchronize strobes within site of each other. Compatible with control panel.
 - Strobes: NFPA 72 and UL 1971; Provide integral 110 candela strobe lamp and flasher. Provide red trim ring for semi-flush mounting. Synchronize strobes within site of each other. Compatible with control panel.
- D. Zone Module Interface:
 - 1. Single zone interface module shall provide an addressable input interface to the control panel for monitoring normally open contact devices. Mount inside NEMA 1 enclosure within 10 feet of first monitored device of zone. Compatible with control panel.
- E. Control Relay Module:
 - 1. Programmable control relay shall be located within 10' of device to be controlled. Temporal sound pattern. Audio shall be synchronized.
- F. Circuit Conductors: Copper or optical fiber; provide 200 feet extra; color code and label.

PART 3 EXECUTION

3.01 EXAMINATION AND PREPARATION

- A. Field inspect existing fire alarm system installation to determine all required interface components necessary for fire alarm system replacement and relocation.
- B. Perform repair work on existing system to eliminate trouble conditions.

3.02 INSTALLATION

- A. Install in accordance with applicable codes, NFPA 72, NFPA 70, and Contract Documents.
- B. Install fire alarm system in accordance with manufacturer's instructions.
 - 1. Install manual station with operating handle 4 feet above floor. Install horn strobe units 7.5 feet above floor.
- C. Conceal all wiring, conduit, boxes, and supports where installed in finished areas.
- D. Obtain Owner's approval of locations of devices, before installation.
- E. Install instruction cards and labels.

3.03 INSPECTION AND TESTING FOR COMPLETION

- A. Perform field inspection and testing of fire alarm system in accordance with Section 01 78 00.
- B. Notify Owner 7 days prior to beginning completion inspections and tests.
- C. Notify authorities having jurisdiction and comply with their requirements for scheduling inspections and tests and for observation by their personnel.
- D. Provide the services of the installer's supervisor or person with equivalent qualifications to supervise inspection and testing, correction, and adjustments.
- E. Prepare for testing by ensuring that all work is complete and correct; perform preliminary tests as required.
- F. Provide all tools, software, and supplies required to accomplish inspection and testing.
- G. Perform inspection and testing in accordance with NFPA 72 and requirements of local authorities; document each inspection and test.
 - 1. Include description of testing and results in test report.
 - 2. Perform 100 percent acceptance test to NFPA 72 standards on system.
- H. Correct defective work, adjust for proper operation, and retest until entire system complies with Contract Documents.

3.04 MANUFACTURER'S FIELD SERVICES

A. Include services of technician to supervise installation, adjustments, final connections, and system testing.

3.05 CLOSEOUT

- A. Closeout Demonstration: Demonstrate proper operation of all functions to Owner.
 - 1. Be prepared to conduct any of the required tests.
 - 2. Have at least one copy of operation and maintenance data, preliminary copy of project record drawings, input/output matrix, and operator instruction chart(s) available during demonstration.
 - 3. Have authorized technical representative of control unit manufacturer present during demonstration.
 - 4. Demonstration may be combined with inspection and testing required by authority having jurisdiction; notify authority having jurisdiction in time to schedule demonstration.
 - 5. Repeat demonstration until successful.
- B. Substantial Completion of the project cannot be achieved until inspection and testing is successful and:
 - 1. Approved operating and maintenance data has been delivered.
 - 2. Spare parts, extra materials, and tools have been delivered.
 - 3. All aspects of operation have been demonstrated to Owner.
 - 4. Final acceptance of the fire alarm system has been given by authorities having jurisdiction.
- C. Perform post-occupancy instruction within 3 months after Substantial Completion.

END OF SECTION