

1 2024 International Building Code

2 ***

3 **Sec 12-17.1 Additions, Insertions, Deletions and Changes**

4 ***

5 107.2.1.2 Data Center Engineered Modeling details is added to
6 read:

7 The code official will require to be filed, engineers report(s)
8 and attestation(s) that the proposed permit details for a data
9 center has been modeled for sound and vibration. The accompanied
10 reports shall demonstrate compliance with all local, State and
11 Federal regulations.

12 ***

13 107.3.4.2 Data Center Testing Deferred Submittals is added to
14 read:

15 The code official will require to be filed, engineers report(s)
16 and attestation(s) that the constructed data center has been tested
17 for sound and vibration. The accompanied testing reports
18 shall demonstrate compliance with all local, State and Federal
19 regulations- prior to requests for temporary or full certificates
20 of occupancy where sound and vibration generating equipment are
21 being added.

22 ***