

DIVISION 12-II-5 FUEL GAS CODE

Sec 12-17.4 Same; Additions, Insertions, Deletions And Changes

Sec 12-17.4 Same; Additions, Insertions, Deletions And Changes

The following sections of the **2024** International Fuel and Gas Code; adopted in section 12-16 is hereby revised as follows:

101.1 is amended to read:

Title. These regulations shall be known as the Fuel Gas Code of The City of Aurora, hereinafter referred to as "this code."

Formatted: Indent: Left: 0.5"

103.1 is amended to read:

The Division of Building and Permits under the Developments Services Department is hereby created and the official in charge thereof shall be known as the building official. Any reference in this code to the code official shall mean the building official. The function of the agency shall be the implementation, administration, and enforcement of the provisions of this code.

Formatted: Indent: Left: 0.5"

Section 106.6.2 Insert: 108.2.1 is added to read:

See International Building Code Section 109

Formatted: Indent: First line: 0.5"

Subsection 106.6.3 shall be changed to read as follows: 108.6 is amended to read

:

106.6.3 The code official shall authorize the refunding of fees per the International Building Code Section 109.6.

Formatted: Indent: Left: 0.5"

113.4 is amended to read: The following Subsection shall be added to section 108.4:

108.4.1

Violation Penalties shall be as prescribed in the International Building Code Section 114.4

Formatted: Indent: Left: 0.5"

The following Subsection shall be added to section 108.5: 113.4.1 is added to read:

108.5.1 Unlawful continuance fines shall be as prescribed in the International Building Code Section 115.3

Formatted: Indent: Left: 0.5"

112.1 is amended to read: Subsection 109 Means of Appeals shall be deleted and the following text inserted:

109.1 Appeals. Appeals to this code shall be conducted as prescribed in the adopted International Building Code.

Formatted: Indent: Left: 0.5"

112.2 is deleted.

112.3 is deleted.

112.4 is deleted

113.4 is amended to read:

Violation Penalties shall be as prescribed in the International Building Code Section 114.4.

Formatted: Indent: Left: 0.5"

301.1.2 Natural Gas Services is added to read:

New R-2 apartment buildings or existing buildings converting to R-2 use shall be served with an independently metered service per dwelling unit.

306.5.3. is added to read:

A hose bib shall be provided within 200 feet of any serviceable equipment located on a roof more than 16 feet above grade plane and greater than 5000 square feet in area. Hose bibs shall be installed in accordance with the Illinois Plumbing Code.

Formatted: Indent: Left: 0.5"

Subsection 403.4.3 403.3.3 Copper and Copper Alloy. Shall be deleted

Subsection 403.4.4 403.3.4 Aluminum. Shall be deleted

Subsection 403.45 Metallic tubing. Shall be deleted

The following Subsection shall be added to section 503.6.11; 503.6.12.1 B Vent support is added to read:

503.6.11.1 B Vent support: B vent support shall be provided horizontally every 5 feet minimum with no screw penetrations unless specifically required by the vent manufacturer and then only when it can be demonstrated that the inner wall of the vent has not been penetrated.

Formatted: Indent: Left: 0.5"

Formatted: Justified, Indent: Left: 0.5", Space After: 7.5 pt, Line spacing: single, Pattern: Clear (White)