



City of Aurora

Fire Prevention Bureau • 5 E Galena BL #G • Aurora, Illinois 60505-3305 • (630) 256-4130
Fax (630) 256-4139

St. Charles Bank & Trust Co.
Richard A. Davis
1001 S. Randall Road
Elgin, IL 60123

Tuesday July 28, 2015

Re: St. Charles Bank & Trust Company - 2287 W. Galena Blvd. - Fpn/R For A 5,000 S.F. Bank
Facility With A 3 Lane Drive Thru
Project # 15-00000125

(630) 563-7916
(866) 074-1593
rdavis2@bankstcharles.com

Dear St. Charles Bank & Trust Co.

Fire Prevention Bureau - The Fire Prevention Bureau has reviewed the proposal and has the following comments.

- ⇒ **With The Following Condition(s) as prescribed in the 2009 International Fire Code as adopted and/or amended by the City of Aurora:**
1. **Provide a 26' wide x 40' long staging area in front of hydrants and centered on hydrants per the International Fire Code, Section D103.1 and Figure D103.1. This applies to the Hydrant in SE corner of the plan.**
 2. **Provide 20' wide fire lanes (face of curb to face of curb) with a vertical clearance of not less than 13'-6" per the International Fire Code, Section 503.2.1. This pertains to the right in/right out on Galena Blvd or a mountable curb.**
 3. **Resubmittal is required for the Fire Prevention Bureau.**

If there are any questions regarding this review, please contact Gary Krienitz at the e-mail address listed below or you may call (630) 256-4130.

Gary Krienitz GKrienitz@aurora-il.org